

Sample Identification\	School	Location	Date Sampled	Pass	Fail	Remediation / Notes
AES-1231-1A	Adams ES	3rd floor across from classroom 308	12/31/14	< 1		
AES-1231-2B	Adams ES	3rd floor across from classroom 308	12/31/14	< 1		
AES-1231-3A	Adams ES	3rd floor across from classroom 316	12/31/14	< 1		
AES-1231-4B	Adams ES	3rd floor across from classroom 316	12/31/14	< 1		
AES-1231-5A	Adams ES	2nd floor across from classroom 206	12/31/14	< 1		
AES-1231-6B	Adams ES	2nd floor across from classroom 206	12/31/14	< 1		
AES-1231-7A	Adams ES	2nd floor inside gym	12/31/14	< 1		
AES-1231-8B	Adams ES	2nd floor inside gym	12/31/14	< 1		
AES-1231-9A	Adams ES	2nd floor across from classroom 210	12/31/14	2		
AES-1231-10B	Adams ES	2nd floor across from classroom 210	12/31/14	1.7		
AES-1231-11A	Adams ES	1st floor across from classroom 110	12/31/14	< 1		
AES-1231-12B	Adams ES	1st floor across from classroom 110	12/31/14	< 1		
AES-1231-13A	Adams ES	1st floor inside cafeteria	12/31/14	< 1		
AES-1231-14B	Adams ES	1st floor inside cafeteria	12/31/14	< 1		
AES-1231-15A	Adams ES	1st floor adjacent to classroom 102	12/31/14	< 1		
AES-1231-16B	Adams ES	1st floor adjacent to classroom 102	12/31/14	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
MAE-0623-1A	Aiton ES	1st Floor main entrance adjacent to women's restroom	6/23/15	< 1		
MAE-0623-1B	Aiton ES	1st Floor main entrance adjacent to women's restroom	6/23/15	< 1		
MAE-0623-2A	Aiton ES	1st Floor hallway across health room	6/23/15	< 1		
MAE-0623-2B	Aiton ES	1st Floor hallway across health room	6/23/15	< 1		
MAE-0623-3A	Aiton ES	1st Floor inside room kindergarten 1	6/23/15	< 1		
MAE-0623-3B	Aiton ES	1st Floor inside room kindergarten 1	6/23/15	< 1		
MAE-0623-4A	Aiton ES	1st Floor inside room kindergarten 2	6/23/15	< 1		
MAE-0623-4B	Aiton ES	1st Floor inside room kindergarten 2	6/23/15	< 1		
MAE-0623-5A	Aiton ES	4th Floor hallway adjacent to room 406	6/23/15	< 1		
MAE-0623-5B	Aiton ES	4th Floor hallway adjacent to room 406	6/23/15	< 1		
MAE-0623-6A	Aiton ES	4th Floor hallway adjacent to multipurpose room	6/23/15	< 1		
MAE-0623-6B	Aiton ES	4th Floor hallway adjacent to multipurpose room	6/23/15	< 1		
MAE-0623-7A	Aiton ES	3rd Floor hallway adjacent to room 305	6/23/15	< 1		
MAE-0623-7B	Aiton ES	3rd Floor hallway adjacent to room 305	6/23/15	< 1		
MAE-0623-8A	Aiton ES	3rd Floor hallway adjacent to room 301	6/23/15	< 1		
MAE-0623-8B	Aiton ES	3rd Floor hallway adjacent to room 301	6/23/15	< 1		
MAE-0623-9A	Aiton ES	2nd Floor hallway adjacent to room 203	6/23/15	< 1		
MAE-0623-9B	Aiton ES	2nd Floor hallway adjacent to room 203	6/23/15	< 1		
MAE-0623-10A	Aiton ES	2nd Floor hallway adjacent to library	6/23/15	< 1		
MAE-0623-10B	Aiton ES	2nd Floor hallway adjacent to library	6/23/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
AE-121-1A	Amidon-Bowen ES	2nd Floor inside classroom A-212	1/21/15	< 1		
AE-121-1B	Amidon-Bowen ES	2nd Floor inside classroom A-212	1/21/15	< 1		
AE-121-2A	Amidon-Bowen ES	2nd Floor inside classroom A-213	1/21/15	< 1		
AE-121-2B	Amidon-Bowen ES	2nd Floor inside classroom A-213	1/21/15	< 1		
AE-121-3A	Amidon-Bowen ES	2nd Floor inside classroom A-208	1/21/15	< 1		
AE-121-3B	Amidon-Bowen ES	2nd Floor inside classroom A-208	1/21/15	< 1		
AE-121-4A	Amidon-Bowen ES	2nd Floor inside classroom A-209	1/21/15	< 1		
AE-121-4B	Amidon-Bowen ES	2nd Floor inside classroom A-209	1/21/15	< 1		
AE-121-5A	Amidon-Bowen ES	2nd Floor inside classroom A-202	1/21/15	< 1		
AE-121-5B	Amidon-Bowen ES	2nd Floor inside classroom A-202	1/21/15	< 1		
AE-121-6A	Amidon-Bowen ES	2nd Floor inside classroom B-223	1/21/15	< 1		
AE-121-6B	Amidon-Bowen ES	2nd Floor inside classroom B-223	1/21/15	< 1		
AE-121-7A	Amidon-Bowen ES	2nd Floor inside classroom B-225	1/21/15	< 1		
AE-121-7B	Amidon-Bowen ES	2nd Floor inside classroom B-225	1/21/15	< 1		

AE-121-8A	Amidon-Bowen ES	2nd Floor inside classroom B-230	1/21/15	1.9		
AE-121-8B	Amidon-Bowen ES	2nd Floor inside classroom B-230	1/21/15	1.3		
AE-121-9A	Amidon-Bowen ES	2nd Floor inside classroom B-232	1/21/15	< 1		
AE-121-9B	Amidon-Bowen ES	2nd Floor inside classroom B-232	1/21/15	< 1		
AE-121-10A	Amidon-Bowen ES	2nd Floor inside classroom B-227	1/21/15	< 1		
AE-121-10B	Amidon-Bowen ES	2nd Floor inside classroom B-227	1/21/15	< 1		
AE-121-11A	Amidon-Bowen ES	2nd Floor inside classroom A-231	1/21/15	< 1		
AE-121-11B	Amidon-Bowen ES	2nd Floor inside classroom A-231	1/21/15	< 1		
AE-121-12A	Amidon-Bowen ES	2nd Floor inside classroom A-236	1/21/15	< 1		
AE-121-12B	Amidon-Bowen ES	2nd Floor inside classroom A-236	1/21/15	< 1		
AE-121-13A	Amidon-Bowen ES	2nd Floor Hallway across the library adjacent to stair area C	1/21/15	< 1		
AE-121-13B	Amidon-Bowen ES	2nd Floor Hallway across the library adjacent to stair area C	1/21/15	< 1		
AE-121-14A	Amidon-Bowen ES	2nd Floor Inside Ms. Barnes room at the library	1/21/15	1.8		
AE-121-14B	Amidon-Bowen ES	2nd Floor Inside Ms. Barnes room at the library	1/21/15	1.7		
AE-121-15A	Amidon-Bowen ES	1st floor inside classroom 161 KG	1/21/15	< 1		
AE-121-15B	Amidon-Bowen ES	1st floor inside classroom 161 KG	1/21/15	< 1		
AE-121-16A	Amidon-Bowen ES	1st Floor Hallway to Gym entrance	1/21/15	< 1		
AE-121-16B	Amidon-Bowen ES	1st Floor Hallway to Gym entrance	1/21/15	< 1		
AE-121-17A	Amidon-Bowen ES	1st Floor inside Gymnasium	1/21/15	< 1		
AE-121-17B	Amidon-Bowen ES	1st Floor inside Gymnasium	1/21/15	< 1		
AE-121-18A	Amidon-Bowen ES	1st Floor inside classroom B-128	1/21/15	< 1		
AE-121-18B	Amidon-Bowen ES	1st Floor inside classroom B-128	1/21/15	< 1		
AE-121-19A	Amidon-Bowen ES	1st floor Hallway adjacent to classroom B-128 (High)	1/21/15	< 1		
AE-121-19B	Amidon-Bowen ES	1st floor Hallway adjacent to classroom B-128 (High)	1/21/15	< 1		
AE-121-20A	Amidon-Bowen ES	1st floor Hallway adjacent to classroom B-128 (Low)	1/21/15	< 1		
AE-121-20B	Amidon-Bowen ES	1st floor Hallway adjacent to classroom B-128 (Low)	1/21/15	< 1		
AE-121-21A	Amidon-Bowen ES	1st floor inside classroom B-126	1/21/15	< 1		
AE-121-21B	Amidon-Bowen ES	1st floor inside classroom B-126	1/21/15	< 1		
AE-121-22A	Amidon-Bowen ES	1st floor inside classroom B-103 (High)	1/21/15	< 1		
AE-121-22B	Amidon-Bowen ES	1st floor inside classroom B-103 (High)	1/21/15	< 1		
AE-121-23A	Amidon-Bowen ES	1st Floor inside classroom A-106 (High)	1/21/15	< 1		
AE-121-23B	Amidon-Bowen ES	1st Floor inside classroom A-106 (High)	1/21/15	< 1		
AE-121-24A	Amidon-Bowen ES	1st Floor inside classroom A-105 (High)	1/21/15	< 1		
AE-121-24B	Amidon-Bowen ES	1st Floor inside classroom A-105 (High)	1/21/15	< 1		
AE-121-25A	Amidon-Bowen ES	1st Floor inside classroom A-107 (High)	1/21/15	2.1		
AE-121-25B	Amidon-Bowen ES	1st Floor inside classroom A-107 (High)	1/21/15	1.6		
AE-121-26A	Amidon-Bowen ES	1st Floor Hallway adjacent to Health Suite	1/21/15	< 1		
AE-121-26B	Amidon-Bowen ES	1st Floor Hallway adjacent to Health Suite	1/21/15	< 1		
AE-121-27A	Amidon-Bowen ES	1st Floor Kitchen hallway adjacent to women rest room	1/21/15	< 1		
AE-121-27B	Amidon-Bowen ES	1st Floor Kitchen hallway adjacent to women rest room	1/21/15	< 1		
AE-121-28A	Amidon-Bowen ES	1st Floor inside classroom A-103 (Low)	1/21/15	< 1		
AE-121-28B	Amidon-Bowen ES	1st Floor inside classroom A-103 (Low)	1/21/15	< 1		
AE-121-29A	Amidon-Bowen ES	1st Floor inside classroom A-106 (Low)	1/21/15	< 1		
AE-121-29B	Amidon-Bowen ES	1st Floor inside classroom A-106 (Low)	1/21/15	< 1		
AE-121-30A	Amidon-Bowen ES	1st Floor inside classroom A-105 (Low)	1/21/15	< 1		
AE-121-30B	Amidon-Bowen ES	1st Floor inside classroom A-105 (Low)	1/21/15	< 1		
AE-121-31A	Amidon-Bowen ES	1st Floor inside classroom A-107 (Low)	1/21/15	< 1		
AE-121-31B	Amidon-Bowen ES	1st Floor inside classroom A-107 (Low)	1/21/15	< 1		
			<b>Percentage of Passed Samples</b>			<b>100.00%</b>
			<b>Percentage of Failed Samples</b>			<b>0.00%</b>
AHS-1230-1A	Anacostia HS	3rd floor hallway adjacent to Classroom M319	12/30/14	< 1		
AHS-1230-2B	Anacostia HS	3rd floor hallway adjacent to Classroom M319	12/30/14	< 1		
AHS-1230-3A	Anacostia HS	3rd floor hallway adjacent to Classroom M303	12/30/14	< 1		
AHS-1230-4B	Anacostia HS	3rd floor hallway adjacent to Classroom M303	12/30/14	< 1		
AHS-1230-5A	Anacostia HS	2nd floor hallway adjacent to Computer Lab N203	12/30/14	< 1		

AHS-1230-6B	Anacostia HS	2nd floor hallway adjacent to Computer Lab N203	12/30/14	< 1		
AHS-1230-7A	Anacostia HS	2nd floor hallway adjacent to Science Lab M220	12/30/14	< 1		
AHS-1230-8B	Anacostia HS	2nd floor hallway adjacent to Science Lab M220	12/30/14	< 1		
AHS-1230-9A	Anacostia HS	2nd floor hallway adjacent to Classroom S204	12/30/14	< 1		
AHS-1230-10B	Anacostia HS	2nd floor hallway adjacent to Classroom S204	12/30/14	< 1		
AHS-1230-11A	Anacostia HS	2nd floor hallway adjacent to Work Room G204	12/30/14	< 1		
AHS-1230-12B	Anacostia HS	2nd floor hallway adjacent to Work Room G204	12/30/14	< 1		
AHS-1230-13A	Anacostia HS	2nd floor hallway across from Computer Lab M212	12/30/14	< 1		
AHS-1230-14B	Anacostia HS	2nd floor hallway across from Computer Lab M212	12/30/14	< 1		
AHS-1230-15A	Anacostia HS	1st floor hallway across from Work Room N110	12/30/14	< 1		
AHS-1230-16B	Anacostia HS	1st floor hallway across from Work Room N110	12/30/14	< 1		
AHS-1230-17A	Anacostia HS	1st floor hallway adjacent to M103 (Admin)	12/30/14	< 1		
AHS-1230-18B	Anacostia HS	1st floor hallway adjacent to M103 (Admin)	12/30/14	< 1		
AHS-1230-19A	Anacostia HS	1st floor hallway adjacent to Classroom S102	12/30/14	< 1		
AHS-1230-20B	Anacostia HS	1st floor hallway adjacent to Classroom S102	12/30/14	< 1		
AHS-1230-21A	Anacostia HS	1st floor hallway across from Gym G102	12/30/14	< 1		
AHS-1230-22B	Anacostia HS	1st floor hallway across from Gym G102	12/30/14	< 1		
AHS-1230-23A	Anacostia HS	Basement floor hallway adjacent to Science Lab S007	12/30/14	< 1		
AHS-1230-24B	Anacostia HS	Basement floor hallway adjacent to Science Lab S007	12/30/14	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BH-0203-1A	Ballou HS	3rd Floor hallway rest room adjacent to elevator 2	2/3/15	< 1		
BH-0203-1B	Ballou HS	3rd Floor hallway rest room adjacent to elevator 2	2/3/15	< 1		
BH-0203-2A	Ballou HS	3rd Floor hallway rest room adjacent to elevator 2	2/3/15	< 1		
BH-0203-2B	Ballou HS	3rd Floor hallway rest room adjacent to elevator 2	2/3/15	< 1		
BH-0203-3A	Ballou HS	3rd Floor hallway adjacent to room 3622	2/3/15	< 1		
BH-0203-3B	Ballou HS	3rd Floor hallway adjacent to room 3622	2/3/15	< 1		
BH-0203-4A	Ballou HS	3rd Floor hallway adjacent to room 3622	2/3/15	< 1		
BH-0203-4B	Ballou HS	3rd Floor hallway adjacent to room 3622	2/3/15	< 1		
BH-0203-5A	Ballou HS	3rd Floor hallway rest room across classroom 3012	2/3/15	< 1		
BH-0203-5B	Ballou HS	3rd Floor hallway rest room across classroom 3012	2/3/15	< 1		
BH-0203-6A	Ballou HS	3rd Floor hallway rest room across classroom 3012	2/3/15	< 1		
BH-0203-6B	Ballou HS	3rd Floor hallway rest room across classroom 3012	2/3/15	< 1		
BH-0203-7A	Ballou HS	3rd Floor hallway rest room across classroom 3026	2/3/15	< 1		
BH-0203-7B	Ballou HS	3rd Floor hallway rest room across classroom 3026	2/3/15	< 1		
BH-0203-8A	Ballou HS	3rd Floor hallway rest room across classroom 3026	2/3/15	< 1		
BH-0203-8B	Ballou HS	3rd Floor hallway rest room across classroom 3026	2/3/15	< 1		
BH-0203-9A	Ballou HS	3rd Floor hallway adjacent to Gym 3210 (high)	2/3/15	< 1		
BH-0203-9B	Ballou HS	3rd Floor hallway adjacent to Gym 3210 (high)	2/3/15	< 1		
BH-0203-10A	Ballou HS	3rd Floor hallway adjacent to Gym 3210 (low)	2/3/15	< 1		
BH-0203-10B	Ballou HS	3rd Floor hallway adjacent to Gym 3210 (low)	2/3/15	< 1		
BH-0203-11A	Ballou HS	3rd Floor hallway adjacent to Gym 3210 (high)	2/3/15	< 1		
BH-0203-11B	Ballou HS	3rd Floor hallway adjacent to Gym 3210 (high)	2/3/15	< 1		
BH-0203-12A	Ballou HS	3rd Floor hallway adjacent to Gym 3210 (low)	2/3/15	< 1		
BH-0203-12B	Ballou HS	3rd Floor hallway adjacent to Gym 3210 (low)	2/3/15	< 1		
BH-0203-13A	Ballou HS	3rd Floor hallway rest room adjacent to room 3200 Track (high)	2/3/15	< 1		
BH-0203-13B	Ballou HS	3rd Floor hallway rest room adjacent to room 3200 Track (high)	2/3/15	< 1		
BH-0203-14A	Ballou HS	3rd Floor hallway rest room adjacent to room 3200 Track (low)	2/3/15	< 1		
BH-0203-14B	Ballou HS	3rd Floor hallway rest room adjacent to room 3200 Track (low)	2/3/15	< 1		
BH-0203-15A	Ballou HS	2nd Floor hallway rest room adjacent to auditorium 2600 (high)	2/3/15	< 1		
BH-0203-15B	Ballou HS	2nd Floor hallway rest room adjacent to auditorium 2600 (high)	2/3/15	< 1		
BH-0203-16A	Ballou HS	2nd Floor hallway rest room adjacent to auditorium 2600 (low)	2/3/15	< 1		
BH-0203-16B	Ballou HS	2nd Floor hallway rest room adjacent to auditorium 2600 (low)	2/3/15	< 1		
BH-0203-17A	Ballou HS	2nd Floor hallway adjacent to room 2623 (high)	2/3/15	< 1		
BH-0203-17B	Ballou HS	2nd Floor hallway adjacent to room 2623 (high)	2/3/15	< 1		

BH-0203-18A	Ballou HS	2nd Floor hallway adjacent to room 2623 (low)	2/3/15	< 1		
BH-0203-18B	Ballou HS	2nd Floor hallway adjacent to room 2623 (low)	2/3/15	< 1		
BH-0203-19A	Ballou HS	2nd Floor hallway rest room across room 2012 (high)	2/3/15	< 1		
BH-0203-19B	Ballou HS	2nd Floor hallway rest room across room 2012 (high)	2/3/15	< 1		
BH-0203-20A	Ballou HS	2nd Floor hallway rest room across room 2012 (low)	2/3/15	< 1		
BH-0203-20B	Ballou HS	2nd Floor hallway rest room across room 2012 (low)	2/3/15	< 1		
BH-0203-21A	Ballou HS	2nd Floor hallway rest room across classroom 2026 (high)	2/3/15	< 1		
BH-0203-21B	Ballou HS	2nd Floor hallway rest room across classroom 2026 (high)	2/3/15	< 1		
BH-0203-22A	Ballou HS	2nd Floor hallway rest room across classroom 2026 (low)	2/3/15	< 1		
BH-0203-22B	Ballou HS	2nd Floor hallway rest room across classroom 2026 (low)	2/3/15	< 1		
BH-0203-23A	Ballou HS	2nd Floor hallway rest room across classroom 2201 (high)	2/3/15	< 1		
BH-0203-23B	Ballou HS	2nd Floor hallway rest room across classroom 2201 (high)	2/3/15	< 1		
BH-0203-24A	Ballou HS	2nd Floor hallway rest room across classroom 2201 (low)	2/3/15	< 1		
BH-0203-24B	Ballou HS	2nd Floor hallway rest room across classroom 2201 (low)	2/3/15	< 1		
BH-0203-25A	Ballou HS	2nd Floor cafeteria adjacent to room 2350 (high)	2/3/15	< 1		
BH-0203-25B	Ballou HS	2nd Floor cafeteria adjacent to room 2350 (high)	2/3/15	< 1		
BH-0203-26A	Ballou HS	2nd Floor cafeteria adjacent to room 2350 (low)	2/3/15	< 1		
BH-0203-26B	Ballou HS	2nd Floor cafeteria adjacent to room 2350 (low)	2/3/15	< 1		
BH-0203-27A	Ballou HS	1st Floor hallway rest room next to elevator 2 (high)	2/3/15	< 1		
BH-0203-27B	Ballou HS	1st Floor hallway rest room next to elevator 2 (high)	2/3/15	< 1		
BH-0203-28A	Ballou HS	1st Floor hallway rest room next to elevator 2 (low)	2/3/15	< 1		
BH-0203-28B	Ballou HS	1st Floor hallway rest room next to elevator 2 (low)	2/3/15	< 1		
BH-0203-29A	Ballou HS	1st Floor hallway adjacent to day care 1630 (high)	2/3/15	< 1		
BH-0203-29B	Ballou HS	1st Floor hallway adjacent to day care 1630 (high)	2/3/15	< 1		
BH-0203-30A	Ballou HS	1st Floor hallway adjacent to day care 1630 (low)	2/3/15	< 1		
BH-0203-30B	Ballou HS	1st Floor hallway adjacent to day care 1630 (low)	2/3/15	< 1		
BH-0203-31A	Ballou HS	1st Floor hallway across room 1012 (high)	2/3/15	< 1		
BH-0203-31B	Ballou HS	1st Floor hallway across room 1012 (high)	2/3/15	< 1		
BH-0203-32A	Ballou HS	1st Floor hallway across room 1012 (low)	2/3/15	< 1		
BH-0203-32B	Ballou HS	1st Floor hallway across room 1012 (low)	2/3/15	< 1		
BH-0203-33A	Ballou HS	1st Floor hallway across class 1026 (high)	2/3/15	2.9		
BH-0203-33B	Ballou HS	1st Floor hallway across class 1026 (high)	2/3/15	< 1		
BH-0203-34A	Ballou HS	1st Floor hallway across class 1026 (low)	2/3/15	< 1		
BH-0203-34B	Ballou HS	1st Floor hallway across class 1026 (low)	2/3/15	< 1		
BH-0203-35A	Ballou HS	1st Floor hallway adjacent to room 1301 (high)	2/3/15	< 1		
BH-0203-35B	Ballou HS	1st Floor hallway adjacent to room 1301 (high)	2/3/15	< 1		
BH-0203-36A	Ballou HS	1st Floor hallway adjacent to room 1301 (low)	2/3/15	< 1		
BH-0203-36B	Ballou HS	1st Floor hallway adjacent to room 1301 (low)	2/3/15	< 1		
BH-0203-37A	Ballou HS	1st Floor hallway behind room 1305, across room 1351 (high)	2/3/15	< 1		
BH-0203-37B	Ballou HS	1st Floor hallway behind room 1305, across room 1351 (high)	2/3/15	< 1		
BH-0203-38A	Ballou HS	1st Floor hallway behind room 1305, across room 1351 (low)	2/3/15	< 1		
BH-0203-38B	Ballou HS	1st Floor hallway behind room 1305, across room 1351 (low)	2/3/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BE-0625-1A	Bancroft ES	Exterior of the building - Southwest corner of the play area (high)	6/25/15	< 1		
BE-0625-1B	Bancroft ES	Exterior of the building - Southwest corner of the play area (high)	6/25/15	< 1		
BE-0625-2A	Bancroft ES	Exterior of the building - Southwest corner of the play area (low)	6/25/15	< 1		
BE-0625-2B	Bancroft ES	Exterior of the building - Southwest corner of the play area (low)	6/25/15	< 1		
BE-0625-3A	Bancroft ES	Exterior of the building – Northwest corner of the play area near the garden (high)	6/25/15	< 1		
BE-0625-3B	Bancroft ES	Exterior of the building – Northwest corner of the play area near the garden (high)	6/25/15	< 1		
BE-0625-4A	Bancroft ES	Exterior of the building – Northwest corner of the play area near the garden (low)	6/25/15	< 1		

BE-0625-4B	Bancroft ES	Exterior of the building – Northwest corner of the play area near the garden (low)	6/25/15	< 1		
BE-0625-5A	Bancroft ES	Exterior of the building – on the side of the stairs (high)	6/25/15	< 1		
BE-0625-5B	Bancroft ES	Exterior of the building – on the side of the stairs (high)	6/25/15	< 1		
BE-0625-6A	Bancroft ES	Exterior of the building – on the side of the stairs (low)	6/25/15	< 1		
BE-0625-6B	Bancroft ES	Exterior of the building – on the side of the stairs (low)	6/25/15	< 1		
BE-0625-7A	Bancroft ES	Exterior of the building – Southwest corner of the upper play area (high)	6/25/15	1.8		
BE-0625-7B	Bancroft ES	Exterior of the building – Southwest corner of the upper play area (high)	6/25/15	1.7		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BHS-0203-1A	Banneker SHS	3rd floor hallway adjacent to Classroom 306	2/3/15	< 1		
BHS-0203-1B	Banneker SHS	3rd floor hallway adjacent to Classroom 306	2/3/15	< 1		
BHS-0203-2A	Banneker SHS	3rd floor hallway adjacent to Classroom 305	2/3/15	< 1		
BHS-0203-2B	Banneker SHS	3rd floor hallway adjacent to Classroom 305	2/3/15	< 1		
BHS-0203-3A	Banneker SHS	3rd floor hallway adjacent to Classroom 315	2/3/15	< 1		
BHS-0203-3B	Banneker SHS	3rd floor hallway adjacent to Classroom 315	2/3/15	< 1		
BHS-0203-4A	Banneker SHS	3rd floor hallway near Stairwell 5	2/3/15	< 1		
BHS-0203-4B	Banneker SHS	3rd floor hallway near Stairwell 5	2/3/15	< 1		
BHS-0203-5A	Banneker SHS	2nd floor hallway near Stairwell 2	2/3/15	< 1		
BHS-0203-5B	Banneker SHS	2nd floor hallway near Stairwell 2	2/3/15	< 1		
BHS-0203-6A	Banneker SHS	2nd floor hallway adjacent to Library	2/3/15	< 1		
BHS-0203-6B	Banneker SHS	2nd floor hallway adjacent to Library	2/3/15	< 1		
BHS-0203-7A	Banneker SHS	2nd floor hallway near Stairwell 6	2/3/15	< 1		
BHS-0203-7B	Banneker SHS	2nd floor hallway near Stairwell 6	2/3/15	< 1		
BHS-0203-8A	Banneker SHS	1st floor hallway adjacent to Principal's Office 102	2/3/15	< 1		
BHS-0203-8B	Banneker SHS	1st floor hallway adjacent to Principal's Office 102	2/3/15	< 1		
BHS-0203-9A	Banneker SHS	1st floor hallway adjacent to Guidance Suite 103	2/3/15	< 1		
BHS-0203-9B	Banneker SHS	1st floor hallway adjacent to Guidance Suite 103	2/3/15	< 1		
BHS-0203-10A	Banneker SHS	1st floor hallway adjacent to Book Room 113	2/3/15	< 1		
BHS-0203-10B	Banneker SHS	1st floor hallway adjacent to Book Room 113	2/3/15	< 1		
BHS-0203-11A	Banneker SHS	1st floor inside Gym (near Stairwell 3)	2/3/15	< 1		
BHS-0203-11B	Banneker SHS	1st floor inside Gym (near Stairwell 3)	2/3/15	< 1		
BHS-0203-12A	Banneker SHS	1st floor inside Gym (near Stairwell 4)	2/3/15	< 1		
BHS-0203-12B	Banneker SHS	1st floor inside Gym (near Stairwell 4)	2/3/15	< 1		
BHS-0203-13A	Banneker SHS	1st floor hallway across from Gym	2/3/15	< 1		
BHS-0203-13B	Banneker SHS	1st floor hallway across from Gym	2/3/15	< 1		
BHS-0203-14A	Banneker SHS	Basement floor hallway across from Storage Room	2/3/15	< 1		
BHS-0203-14B	Banneker SHS	Basement floor hallway across from Storage Room	2/3/15	< 1		
BHS-0203-15A	Banneker SHS	Basement floor hallway adjacent to Maintenance Office 001	2/3/15	< 1		
BHS-0203-15B	Banneker SHS	Basement floor hallway adjacent to Maintenance Office 001	2/3/15	< 1		
BHS-0203-16A	Banneker SHS	Basement floor inside Cafeteria (next to snack machine)	2/3/15	< 1		
BHS-0203-16B	Banneker SHS	Basement floor inside Cafeteria (next to snack machine)	2/3/15	< 1		
BHS-0203-17A	Banneker SHS	Basement floor inside Cafeteria (next to beverage machine)	2/3/15	< 1		
BHS-0203-17B	Banneker SHS	Basement floor inside Cafeteria (next to beverage machine)	2/3/15	< 1		
BHS-0203-18A	Banneker SHS	Basement floor hallway across from Teacher's Dining Room 245	2/3/15	< 1		
BHS-0203-18B	Banneker SHS	Basement floor hallway across from Teacher's Dining Room 245	2/3/15	< 1		
BHS-0203-19A	Banneker SHS	Basement floor hallway adjacent to Head Custodian's Office	2/3/15	< 1		
BHS-0203-19B	Banneker SHS	Basement floor hallway adjacent to Head Custodian's Office	2/3/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BES-0903-1A	Barnard ES	2nd floor across from Art Room 239 (left)	9/3/15	< 1		
BES-0903-1B	Barnard ES	2nd floor across from Art Room 239 (left)	9/3/15	< 1		
BES-0903-2A	Barnard ES	2nd floor across from Art Room 239 (right)	9/3/15	< 1		

BES-0903-2B	Barnard ES	2nd floor across from Art Room 239 (right)	9/3/15	< 1			
BES-0903-3A	Barnard ES	2nd floor adjacent to Classroom 206 (high)	9/3/15	< 1			
BES-0903-3B	Barnard ES	2nd floor adjacent to Classroom 206 (high)	9/3/15	< 1			
BES-0903-4A	Barnard ES	2nd floor adjacent to Classroom 206 (low)	9/3/15	< 1			
BES-0903-4B	Barnard ES	2nd floor adjacent to Classroom 206 (low)	9/3/15	< 1			
BES-0903-5A	Barnard ES	2nd floor adjacent to Classroom 210 (high)	9/3/15	< 1			
BES-0903-5B	Barnard ES	2nd floor adjacent to Classroom 210 (high)	9/3/15	< 1			
BES-0903-6A	Barnard ES	1st floor across from OT Room 121 (low)	9/3/15	< 1			
BES-0903-6B	Barnard ES	1st floor across from OT Room 121 (low)	9/3/15	< 1			
BES-0903-7A	Barnard ES	1st floor adjacent to Classroom 106 (high)	9/3/15	< 1			
BES-0903-7B	Barnard ES	1st floor adjacent to Classroom 106 (high)	9/3/15	< 1			
BES-0903-8A	Barnard ES	1st floor adjacent to Classroom 106 (low)	9/3/15	< 1			
BES-0903-8B	Barnard ES	1st floor adjacent to Classroom 106 (low)	9/3/15	< 1			
BES-0903-9A	Barnard ES	1st floor adjacent to Classroom 109 (high)	9/3/15	< 1			
BES-0903-9B	Barnard ES	1st floor adjacent to Classroom 109 (high)	9/3/15	< 1			
BES-0903-10A	Barnard ES	1st floor adjacent to Classroom 109 (low)	9/3/15	< 1			
BES-0903-10B	Barnard ES	1st floor adjacent to Classroom 109 (low)	9/3/15	< 1			
BES-0903-11A	Barnard ES	1st floor inside Classroom 112 Restroom	9/3/15	< 1			
BES-0903-11B	Barnard ES	1st floor inside Classroom 112 Restroom	9/3/15	< 1			
BES-0903-12A	Barnard ES	1st floor inside Classroom 111 Restroom	9/3/15	< 1			
BES-0903-12B	Barnard ES	1st floor inside Classroom 111 Restroom	9/3/15	< 1			
BES-0903-13A	Barnard ES	1st floor inside Classroom 110 Restroom	9/3/15	< 1			
BES-0903-13B	Barnard ES	1st floor inside Classroom 110 Restroom	9/3/15	< 1			
BES-0903-14A	Barnard ES	1st floor inside Classroom 113 Restroom	9/3/15	2.1			
BES-0903-14B	Barnard ES	1st floor inside Classroom 113 Restroom	9/3/15	2.1			
BES-0903-15A	Barnard ES	1st floor inside Classroom 109 Restroom	9/3/15	1.2			
BES-0903-15B	Barnard ES	1st floor inside Classroom 109 Restroom	9/3/15	< 1			
BES-0903-16A	Barnard ES	1st floor inside Classroom 114 Restroom	9/3/15	8			
BES-0903-16B	Barnard ES	1st floor inside Classroom 114 Restroom	9/3/15	< 1			
BES-0903-17A	Barnard ES	1st floor inside Classroom 106 Restroom	9/3/15	< 1			
BES-0903-17B	Barnard ES	1st floor inside Classroom 106 Restroom	9/3/15	< 1			
BES-0903-18A	Barnard ES	1st floor inside Classroom 118 Restroom	9/3/15	1.8			
BES-0903-18B	Barnard ES	1st floor inside Classroom 118 Restroom	9/3/15	1.8			
BES-0903-19A	Barnard ES	1st floor inside Classroom 105 Restroom	9/3/15	2.2			
BES-0903-19B	Barnard ES	1st floor inside Classroom 105 Restroom	9/3/15	< 1			
BES-0903-20A	Barnard ES	1st floor inside Classroom 120 Restroom	9/3/15	< 1			
BES-0903-20B	Barnard ES	1st floor inside Classroom 120 Restroom	9/3/15	< 1			
			<b>Percentage of Passed Samples</b>			<b>100.00%</b>	
			<b>Percentage of Failed Samples</b>			<b>0.00%</b>	
BES-0108-1A	Beers ES	2nd floor hallway adjacent to Classroom B209	1/8/15	< 1			
BES-0108-1B	Beers ES	2nd floor hallway adjacent to Classroom B209	1/8/15	< 1			
BES-0108-2A	Beers ES	2nd floor hallway adjacent to Classroom B201 (high)	1/8/15	< 1			
BES-0108-2B	Beers ES	2nd floor hallway adjacent to Classroom B201 (high)	1/8/15	< 1			
BES-0108-3A	Beers ES	2nd floor hallway adjacent to Classroom B201 (low)	1/8/15	< 1			
BES-0108-3B	Beers ES	2nd floor hallway adjacent to Classroom B201 (low)	1/8/15	< 1			
BES-0108-4A	Beers ES	2nd floor hallway adjacent to Electric Closet A218	1/8/15	< 1			
BES-0108-4B	Beers ES	2nd floor hallway adjacent to Electric Closet A218	1/8/15	< 1			
BES-0108-5A	Beers ES	2nd floor inside Classroom A207	1/8/15	< 1			
BES-0108-5B	Beers ES	2nd floor inside Classroom A207	1/8/15	< 1			
BES-0108-6A	Beers ES	2nd floor inside Classroom A214	1/8/15	< 1			
BES-0108-6B	Beers ES	2nd floor inside Classroom A214	1/8/15	< 1			
BES-0108-7A	Beers ES	2nd floor inside Classroom A211	1/8/15	< 1			
BES-0108-7B	Beers ES	2nd floor inside Classroom A211	1/8/15	< 1			
BES-0108-8A	Beers ES	2nd floor inside Classroom A216	1/8/15	< 1			
BES-0108-8B	Beers ES	2nd floor inside Classroom A216	1/8/15	< 1			

BES-0108-9A	Beers ES	2nd floor inside Classroom A205	1/8/15	< 1		
BES-0108-9B	Beers ES	2nd floor inside Classroom A205	1/8/15	< 1		
BES-0108-10A	Beers ES	1st floor hallway across from Classroom B106	1/8/15	< 1		
BES-0108-10B	Beers ES	1st floor hallway across from Classroom B106	1/8/15	< 1		
BES-0108-11A	Beers ES	1st floor hallway adjacent to Classroom B101 (high)	1/8/15	< 1		
BES-0108-11B	Beers ES	1st floor hallway adjacent to Classroom B101 (high)	1/8/15	< 1		
BES-0108-12A	Beers ES	1st floor hallway adjacent to Classroom B101 (low)	1/8/15	< 1		
BES-0108-12B	Beers ES	1st floor hallway adjacent to Classroom B101 (low)	1/8/15	< 1		
BES-0108-13A	Beers ES	1st floor hallway adjacent to LAN Closet A113	1/8/15	< 1		
BES-0108-13B	Beers ES	1st floor hallway adjacent to LAN Closet A113	1/8/15	< 1		
BES-0108-14A	Beers ES	1st floor inside Health Suite A115	1/8/15	< 1		
BES-0108-14B	Beers ES	1st floor inside Health Suite A115	1/8/15	< 1		
BES-0108-15A	Beers ES	1st floor inside Classroom A112	1/8/15	< 1		
BES-0108-15B	Beers ES	1st floor inside Classroom A112	1/8/15	< 1		
BES-0108-16A	Beers ES	1st floor inside Classroom A119	1/8/15	< 1		
BES-0108-16B	Beers ES	1st floor inside Classroom A119	1/8/15	< 1		
BES-0108-17A	Beers ES	1st floor inside Classroom A110	1/8/15	< 1		
BES-0108-17B	Beers ES	1st floor inside Classroom A110	1/8/15	< 1		
BES-0108-18A	Beers ES	1st floor inside Classroom A108	1/8/15	< 1		
BES-0108-18B	Beers ES	1st floor inside Classroom A108	1/8/15	< 1		
BES-0108-19A	Beers ES	1st floor inside Classroom A109	1/8/15	< 1		
BES-0108-19B	Beers ES	1st floor inside Classroom A109	1/8/15	< 1		
BES-0108-20A	Beers ES	1st floor hallway adjacent to Auditorium C101 (high)	1/8/15	< 1		
BES-0108-20B	Beers ES	1st floor hallway adjacent to Auditorium C101 (high)	1/8/15	< 1		
BES-0108-21A	Beers ES	1st floor hallway adjacent to Auditorium C101 (low)	1/8/15	< 1		
BES-0108-21B	Beers ES	1st floor hallway adjacent to Auditorium C101 (low)	1/8/15	< 1		
BES-0108-22A	Beers ES	Basement floor inside Cafeteria (high)	1/8/15	< 1		
BES-0108-22B	Beers ES	Basement floor inside Cafeteria (high)	1/8/15	< 1		
BES-0108-23A	Beers ES	Basement floor inside Cafeteria (low)	1/8/15	< 1		
BES-0108-23B	Beers ES	Basement floor inside Cafeteria (low)	1/8/15	< 1		
					<b>Percentage of Passed Samples</b>	<b>100.00%</b>
					<b>Percentage of Failed Samples</b>	<b>0.00%</b>
BES-0121-1B	Brent ES	3rd floor hallway across from Classroom 310	1/21/15	< 1		
BES-0121-2A	Brent ES	3rd floor hallway across from Classroom 304	1/21/15	< 1		
BES-0121-2B	Brent ES	3rd floor hallway across from Classroom 304	1/21/15	< 1		
BES-0121-3A	Brent ES	2nd floor hallway across from Classroom 204	1/21/15	< 1		
BES-0121-3B	Brent ES	2nd floor hallway across from Classroom 204	1/21/15	< 1		
BES-0121-4A	Brent ES	2nd floor hallway across from Classroom 210	1/21/15	< 1		
BES-0121-4B	Brent ES	2nd floor hallway across from Classroom 210	1/21/15	< 1		
BES-0121-5A	Brent ES	2nd floor inside Classroom 204	1/21/15	< 1		
BES-0121-5B	Brent ES	2nd floor inside Classroom 204	1/21/15	< 1		
BES-0121-6A	Brent ES	2nd floor inside Classroom 202	1/21/15	< 1		
BES-0121-6B	Brent ES	2nd floor inside Classroom 202	1/21/15	< 1		
BES-0121-7A	Brent ES	1st floor hallway adjacent to Storage 111	1/21/15	< 1		
BES-0121-7B	Brent ES	1st floor hallway adjacent to Storage 111	1/21/15	< 1		
BES-0121-8A	Brent ES	1st floor inside Classroom 118	1/21/15	< 1		
BES-0121-8B	Brent ES	1st floor inside Classroom 118	1/21/15	< 1		
BES-0121-9A	Brent ES	1st floor inside Classroom 116	1/21/15	< 1		
BES-0121-9B	Brent ES	1st floor inside Classroom 116	1/21/15	< 1		
BES-0121-10A	Brent ES	1st floor inside Classroom 110	1/21/15	< 1		
BES-0121-10B	Brent ES	1st floor inside Classroom 110	1/21/15	< 1		
BES-0121-11A	Brent ES	1st floor inside Classroom 108	1/21/15	< 1		
BES-0121-11B	Brent ES	1st floor inside Classroom 108	1/21/15	2.2		
BES-0121-12A	Brent ES	1st floor inside Classroom 104	1/21/15	< 1		
BES-0121-12B	Brent ES	1st floor inside Classroom 104	1/21/15	< 1		

BES-0121-13A	Brent ES	1st floor inside Classroom 102	1/21/15	< 1		
BES-0121-13B	Brent ES	1st floor inside Classroom 102	1/21/15	< 1		
BES-0121-14A	Brent ES	1st floor inside Multi-Purpose Room	1/21/15	< 1		
BES-0121-14B	Brent ES	1st floor inside Multi-Purpose Room	1/21/15	< 1		
			<b>Percentage of Passed Samples</b>			<b>100.00%</b>
			<b>Percentage of Failed Samples</b>			<b>0.00%</b>
BW-0424-1A	Brightwood EC	3rd Floor hallway adjacent room 307 (high)	4/24/15	< 1		
BW-0424-1B	Brightwood EC	3rd Floor hallway adjacent room 307 (high)	4/24/15	< 1		
BW-0424-2A	Brightwood EC	3rd Floor hallway adjacent room 307 (low)	4/24/15	< 1		
BW-0424-2B	Brightwood EC	3rd Floor hallway adjacent room 307 (low)	4/24/15	< 1		
BW-0424-3A	Brightwood EC	3rd Floor inside classroom 316	4/24/15	< 1		
BW-0424-3B	Brightwood EC	3rd Floor inside classroom 316	4/24/15	< 1		
BW-0424-4A	Brightwood EC	2nd Floor hallway adjacent to room 311 (high)	4/24/15	< 1		
BW-0424-4B	Brightwood EC	2nd Floor hallway adjacent to room 311 (high)	4/24/15	< 1		
BW-0424-5A	Brightwood EC	2nd Floor hallway adjacent to room 311 (low)	4/24/15	< 1		
BW-0424-5B	Brightwood EC	2nd Floor hallway adjacent to room 311 (low)	4/24/15	< 1		
BW-0424-6A	Brightwood EC	1st Floor hallway adjacent to room 123 (high)	4/24/15	< 1		
BW-0424-6B	Brightwood EC	1st Floor hallway adjacent to room 123 (high)	4/24/15	< 1		
BW-0424-7A	Brightwood EC	1st Floor hallway adjacent to room 123 (low)	4/24/15	< 1		
BW-0424-7B	Brightwood EC	1st Floor hallway adjacent to room 123 (low)	4/24/15	< 1		
BW-0424-8A	Brightwood EC	3rd Floor inside classroom 312	4/24/15	< 1		
BW-0424-8B	Brightwood EC	3rd Floor inside classroom 312	4/24/15	< 1		
BW-0424-9A	Brightwood EC	3rd Floor inside classroom 309	4/24/15	< 1		
BW-0424-9B	Brightwood EC	3rd Floor inside classroom 309	4/24/15	< 1		
BW-0424-10A	Brightwood EC	3rd Floor inside classroom 314	4/24/15	< 1		
BW-0424-10B	Brightwood EC	3rd Floor inside classroom 314	4/24/15	< 1		
BW-0424-11A	Brightwood EC	3rd Floor inside classroom 308	4/24/15	< 1		
BW-0424-11B	Brightwood EC	3rd Floor inside classroom 308	4/24/15	< 1		
BW-0424-12A	Brightwood EC	3rd Floor inside classroom 310	4/24/15	< 1		
BW-0424-12B	Brightwood EC	3rd Floor inside classroom 310	4/24/15	< 1		
BW-0424-13A	Brightwood EC	3rd Floor inside classroom 331	4/24/15	< 1		
BW-0424-13B	Brightwood EC	3rd Floor inside classroom 331	4/24/15	< 1		
BW-0424-14A	Brightwood EC	2nd Floor inside class room 208	4/24/15	< 1		
BW-0424-14B	Brightwood EC	2nd Floor inside class room 208	4/24/15	< 1		
BW-0424-15A	Brightwood EC	2nd Floor inside class room 210	4/24/15	< 1		
BW-0424-15B	Brightwood EC	2nd Floor inside class room 210	4/24/15	< 1		
BW-0424-16A	Brightwood EC	2nd Floor inside class room 213	4/24/15	< 1		
BW-0424-16B	Brightwood EC	2nd Floor inside class room 213	4/24/15	< 1		
BW-0424-17A	Brightwood EC	2nd Floor inside class room 212	4/24/15	< 1		
BW-0424-17B	Brightwood EC	2nd Floor inside class room 212	4/24/15	< 1		
BW-0424-18A	Brightwood EC	2nd Floor inside class room 214	4/24/15	< 1		
BW-0424-18B	Brightwood EC	2nd Floor inside class room 214	4/24/15	< 1		
BW-0424-19A	Brightwood EC	2nd Floor inside class room 216	4/24/15	< 1		
BW-0424-19B	Brightwood EC	2nd Floor inside class room 216	4/24/15	< 1		
BW-0424-20A	Brightwood EC	2nd Floor inside class room 218	4/24/15	< 1		
BW-0424-20B	Brightwood EC	2nd Floor inside class room 218	4/24/15	< 1		
BW-0424-21A	Brightwood EC	2nd Floor inside class room 231	4/24/15	< 1		
BW-0424-21B	Brightwood EC	2nd Floor inside class room 231	4/24/15	< 1		
BW-0424-22A	Brightwood EC	2nd Floor inside class room 224	4/24/15	< 1		
BW-0424-22B	Brightwood EC	2nd Floor inside class room 224	4/24/15	< 1		
BW-0424-23A	Brightwood EC	1st Floor inside class room 125	4/24/15	< 1		
BW-0424-23B	Brightwood EC	1st Floor inside class room 125	4/24/15	< 1		
BW-0424-24A	Brightwood EC	1st Floor inside class room 128	4/24/15	< 1		
BW-0424-24B	Brightwood EC	1st Floor inside class room 128	4/24/15	< 1		
BW-0424-25A	Brightwood EC	1st Floor inside class room 130	4/24/15	< 1		

BW-0424-25B	Brightwood EC	1st Floor inside class room 130	4/24/15	< 1		
BW-0424-26A	Brightwood EC	1st Floor inside class room 143	4/24/15	< 1		
BW-0424-26B	Brightwood EC	1st Floor inside class room 143	4/24/15	< 1		
BW-0424-27A	Brightwood EC	1st Floor inside class room 143	4/24/15	< 1		
BW-0424-27B	Brightwood EC	1st Floor inside class room 143	4/24/15	< 1		
BW-0424-28A	Brightwood EC	1st Floor inside class room 147	4/24/15	< 1		
BW-0424-28B	Brightwood EC	1st Floor inside class room 147	4/24/15	< 1		
BW-0424-29A	Brightwood EC	1st Floor inside class room 146	4/24/15	< 1		
BW-0424-29B	Brightwood EC	1st Floor inside class room 146	4/24/15	< 1		
BW-0424-30A	Brightwood EC	1st Floor inside class room 145	4/24/15	< 1		
BW-0424-30B	Brightwood EC	1st Floor inside class room 145	4/24/15	< 1		
BW-0424-31A	Brightwood EC	1st Floor inside class room 136	4/24/15	< 1		
BW-0424-31B	Brightwood EC	1st Floor inside class room 136	4/24/15	< 1		
BW-0424-32A	Brightwood EC	1st Floor inside class room 138	4/24/15	< 1		
BW-0424-32B	Brightwood EC	1st Floor inside class room 138	4/24/15	< 1		
BW-0424-33A	Brightwood EC	1st Floor inside class room 137	4/24/15	< 1		
BW-0424-33B	Brightwood EC	1st Floor inside class room 137	4/24/15	< 1		
				<b>Percentage of Passed Samples</b>		<b>100.00%</b>
				<b>Percentage of Failed Samples</b>		<b>0.00%</b>
BEC-0123-1A	Browne EC	3rd floor hallway adjacent to Classroom 3-337	1/23/15	< 1		
BEC-0123-1B	Browne EC	3rd floor hallway adjacent to Classroom 3-337	1/23/15	< 1		
BEC-0123-2A	Browne EC	3rd floor hallway adjacent to Classroom 3-328	1/23/15	< 1		
BEC-0123-2B	Browne EC	3rd floor hallway adjacent to Classroom 3-328	1/23/15	< 1		
BEC-0123-3A	Browne EC	3rd floor hallway adjacent to Classroom 3-313	1/23/15	< 1		
BEC-0123-3B	Browne EC	3rd floor hallway adjacent to Classroom 3-313	1/23/15	< 1		
BEC-0123-4A	Browne EC	3rd floor hallway adjacent to Classroom 3-307	1/23/15	< 1		
BEC-0123-4B	Browne EC	3rd floor hallway adjacent to Classroom 3-307	1/23/15	< 1		
BEC-0123-5A	Browne EC	2nd floor hallway adjacent to Classroom 2-213	1/23/15	< 1		
BEC-0123-5B	Browne EC	2nd floor hallway adjacent to Classroom 2-213	1/23/15	< 1		
BEC-0123-6A	Browne EC	2nd floor hallway adjacent to Classroom 2-217	1/23/15	< 1		
BEC-0123-6B	Browne EC	2nd floor hallway adjacent to Classroom 2-217	1/23/15	< 1		
BEC-0123-7A	Browne EC	2nd floor hallway adjacent to Classroom 2-269	1/23/15	< 1		
BEC-0123-7B	Browne EC	2nd floor hallway adjacent to Classroom 2-269	1/23/15	< 1		
BEC-0123-8A	Browne EC	2nd floor hallway adjacent to Classroom 2-301	1/23/15	< 1		
BEC-0123-8B	Browne EC	2nd floor hallway adjacent to Classroom 2-301	1/23/15	< 1		
BEC-0123-9A	Browne EC	2nd floor hallway adjacent to Classroom 2-239	1/23/15	< 1		
BEC-0123-9B	Browne EC	2nd floor hallway adjacent to Classroom 2-239	1/23/15	< 1		
BEC-0123-10A	Browne EC	2nd floor hallway adjacent to Classroom 2-235	1/23/15	< 1		
BEC-0123-10B	Browne EC	2nd floor hallway adjacent to Classroom 2-235	1/23/15	< 1		
BEC-0123-11A	Browne EC	1st floor inside Classroom 1-119	1/23/15	< 1		
BEC-0123-11B	Browne EC	1st floor inside Classroom 1-119	1/23/15	< 1		
BEC-0123-12A	Browne EC	1st floor inside Classroom 1-099	1/23/15	1.2		
BEC-0123-12B	Browne EC	1st floor inside Classroom 1-099	1/23/15	< 1		
BEC-0123-13A	Browne EC	1st floor inside Classroom 1-111	1/23/15	< 1		
BEC-0123-13B	Browne EC	1st floor inside Classroom 1-111	1/23/15	< 1		
BEC-0123-14A	Browne EC	1st floor inside Classroom 1-103	1/23/15	1.2		
BEC-0123-14B	Browne EC	1st floor inside Classroom 1-103	1/23/15	1.4		
BEC-0123-15A	Browne EC	1st floor hallway adjacent to Classroom 1-108	1/23/15	< 1		
BEC-0123-15B	Browne EC	1st floor hallway adjacent to Classroom 1-108	1/23/15	< 1		
BEC-0123-16A	Browne EC	1st floor inside Classroom 1-108	1/23/15	< 1		
BEC-0123-16B	Browne EC	1st floor inside Classroom 1-108	1/23/15	< 1		
BEC-0123-17A	Browne EC	1st floor hallway adjacent to Classroom 1-157	1/23/15	< 1		
BEC-0123-17B	Browne EC	1st floor hallway adjacent to Classroom 1-157	1/23/15	< 1		
BEC-0123-18A	Browne EC	1st floor hallway adjacent to Classroom 1-179	1/23/15	< 1		
BEC-0123-18B	Browne EC	1st floor hallway adjacent to Classroom 1-179	1/23/15	< 1		

BEC-0123-19A	Browne EC	1st floor hallway near Classroom 1-193	1/23/15	< 1		
BEC-0123-19B	Browne EC	1st floor hallway near Classroom 1-193	1/23/15	< 1		
BEC-0123-20A	Browne EC	1st floor hallway adjacent to Classroom 1-208	1/23/15	< 1		
BEC-0123-20B	Browne EC	1st floor hallway adjacent to Classroom 1-208	1/23/15	< 1		
BEC-0123-21A	Browne EC	1st floor hallway adjacent to Classroom 1-134	1/23/15	< 1		
BEC-0123-21B	Browne EC	1st floor hallway adjacent to Classroom 1-134	1/23/15	< 1		
BEC-0123-22A	Browne EC	1st floor hallway adjacent to Classroom 1-124	1/23/15	< 1		
BEC-0123-22B	Browne EC	1st floor hallway adjacent to Classroom 1-124	1/23/15	< 1		
BEC-0123-23A	Browne EC	1st floor inside Classroom 1-112	1/23/15	< 1		
BEC-0123-23B	Browne EC	1st floor inside Classroom 1-112	1/23/15	1.1		
BEC-0123-24A	Browne EC	Basement floor inside Cafeteria near Kitchen	1/23/15	< 1		
BEC-0123-24B	Browne EC	Basement floor inside Cafeteria near Kitchen	1/23/15	< 1		
BEC-0123-25A	Browne EC	Basement floor inside Cafeteria other side	1/23/15	< 1		
BEC-0123-25B	Browne EC	Basement floor inside Cafeteria other side	1/23/15	< 1		
BEC-0123-26A	Browne EC	Basement floor inside Gym	1/23/15	< 1		
BEC-0123-26B	Browne EC	Basement floor inside Gym	1/23/15	< 1		
BEC-0123-27A	Browne EC	Basement floor hallway across from Gym	1/23/15	< 1		
BEC-0123-27B	Browne EC	Basement floor hallway across from Gym	1/23/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BM-0204-1A	Bruce - Monroe ES @ Parkview	2nd floor hallway at entrance to Library	2/4/15	< 1		
BM-0204-1B	Bruce - Monroe ES @ Parkview	2nd floor hallway at entrance to Library	2/4/15	< 1		
BM-0204-2A	Bruce - Monroe ES @ Parkview	2nd floor hallway across from Classroom 213	2/4/15	< 1		
BM-0204-2B	Bruce - Monroe ES @ Parkview	2nd floor hallway across from Classroom 213	2/4/15	< 1		
BM-0204-3A	Bruce - Monroe ES @ Parkview	1st floor hallway across from Conference Room 103	2/4/15	< 1		
BM-0204-3B	Bruce - Monroe ES @ Parkview	1st floor hallway across from Conference Room 103	2/4/15	< 1		
BM-0204-4A	Bruce - Monroe ES @ Parkview	1st floor hallway across from Classroom 121	2/4/15	< 1		
BM-0204-4B	Bruce - Monroe ES @ Parkview	1st floor hallway across from Classroom 121	2/4/15	< 1		
BM-0204-5A	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 122	2/4/15	< 1		
BM-0204-5B	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 122	2/4/15	< 1		
BM-0204-6A	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 123	2/4/15	< 1		
BM-0204-6B	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 123	2/4/15	< 1		
BM-0204-7A	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 126	2/4/15	< 1		
BM-0204-7B	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 126	2/4/15	< 1		
BM-0204-8A	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 127	2/4/15	< 1		
BM-0204-8B	Bruce - Monroe ES @ Parkview	1st floor inside Classroom 127	2/4/15	< 1		
BM-0204-9A	Bruce - Monroe ES @ Parkview	1st floor inside Nurse's Office	2/4/15	< 1		
BM-0204-9B	Bruce - Monroe ES @ Parkview	1st floor inside Nurse's Office	2/4/15	< 1		
BM-0204-10A	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 008	2/4/15	< 1		
BM-0204-10B	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 008	2/4/15	< 1		
BM-0204-11A	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 007	2/4/15	< 1		
BM-0204-11B	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 007	2/4/15	< 1		
BM-0204-12A	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 006	2/4/15	< 1		
BM-0204-12B	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 006	2/4/15	< 1		
BM-0204-13A	Bruce - Monroe ES @ Parkview	Ground floor hallway near entrance to Cafeteria	2/4/15	< 1		
BM-0204-13B	Bruce - Monroe ES @ Parkview	Ground floor hallway near entrance to Cafeteria	2/4/15	< 1		
BM-0204-14A	Bruce - Monroe ES @ Parkview	Ground floor hallway across from Auditorium	2/4/15	< 1		
BM-0204-14B	Bruce - Monroe ES @ Parkview	Ground floor hallway across from Auditorium	2/4/15	< 1		
BM-0204-15A	Bruce - Monroe ES @ Parkview	Ground floor hallway near entrance to Gym	2/4/15	< 1		
BM-0204-15B	Bruce - Monroe ES @ Parkview	Ground floor hallway near entrance to Gym	2/4/15	< 1		
BM-0204-16A	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 021	2/4/15	< 1		
BM-0204-16B	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 021	2/4/15	< 1		
BM-0204-17A	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 022	2/4/15	< 1		
BM-0204-17B	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 022	2/4/15	< 1		
BM-0204-18A	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 024	2/4/15	< 1		

BM-0204-18B	Bruce - Monroe ES @ Parkview	Ground floor inside Classroom 024	2/4/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
BH-0121-1A	Brookland EC @ Bunker Hill	1st Floor inside classroom 103	1/21/15	< 1		
BH-0121-1B	Brookland EC @ Bunker Hill	1st Floor inside classroom 103	1/21/15	< 1		
BH-0121-2A	Brookland EC @ Bunker Hill	1st Floor inside classroom 104	1/21/15		55	Filter Installed
BH-0121-2B	Brookland EC @ Bunker Hill	1st Floor inside classroom 104	1/21/15		24	Filter Installed
BH-0121-3A	Brookland EC @ Bunker Hill	1st Floor inside classroom 105	1/21/15	< 1		
BH-0121-3B	Brookland EC @ Bunker Hill	1st Floor inside classroom 105	1/21/15	< 1		
BH-0121-4A	Brookland EC @ Bunker Hill	1st Floor hallway adjacent to storage room 144	1/21/15	< 1		
BH-0121-4B	Brookland EC @ Bunker Hill	1st Floor hallway adjacent to storage room 144	1/21/15	< 1		
BH-0121-5A	Brookland EC @ Bunker Hill	1st Floor inside classroom 106	1/21/15	< 1		
BH-0121-5B	Brookland EC @ Bunker Hill	1st Floor inside classroom 106	1/21/15	< 1		
BH-0121-6A	Brookland EC @ Bunker Hill	1st Floor Main Lobby adjacent to Gym	1/21/15	< 1		
BH-0121-6B	Brookland EC @ Bunker Hill	1st Floor Main Lobby adjacent to Gym	1/21/15	< 1		
BH-0121-7A	Brookland EC @ Bunker Hill	1st Floor inside classroom 120	1/21/15	1.2		
BH-0121-7B	Brookland EC @ Bunker Hill	1st Floor inside classroom 120	1/21/15	< 1		
BH-0121-8A	Brookland EC @ Bunker Hill	1st Floor inside classroom 126	1/21/15	1.4		
BH-0121-8B	Brookland EC @ Bunker Hill	1st Floor inside classroom 126	1/21/15	< 1		
BH-0121-9A	Brookland EC @ Bunker Hill	1st Floor inside classroom 119	1/21/15	< 1		
BH-0121-9B	Brookland EC @ Bunker Hill	1st Floor inside classroom 119	1/21/15	< 1		
BH-0121-10A	Brookland EC @ Bunker Hill	1st Floor inside classroom 125	1/21/15	< 1		
BH-0121-10B	Brookland EC @ Bunker Hill	1st Floor inside classroom 125	1/21/15	< 1		
BH-0121-11A	Brookland EC @ Bunker Hill	1st Floor hallway adjacent to class room 124	1/21/15	< 1		
BH-0121-11B	Brookland EC @ Bunker Hill	1st Floor hallway adjacent to class room 124	1/21/15	< 1		
BH-0121-12A	Brookland EC @ Bunker Hill	1st Floor inside Health Suit	1/21/15	1.5		
BH-0121-12B	Brookland EC @ Bunker Hill	1st Floor inside Health Suit	1/21/15	< 1		
BH-0121-13A	Brookland EC @ Bunker Hill	1st Floor inside Health Suit	1/21/15	< 1		
BH-0121-13B	Brookland EC @ Bunker Hill	1st Floor inside Health Suit	1/21/15	< 1		
BH-0121-14A	Brookland EC @ Bunker Hill	1st Floor hallway adjacent to class room 131	1/21/15	< 1		
BH-0121-14B	Brookland EC @ Bunker Hill	1st Floor hallway adjacent to class room 131	1/21/15	< 1		
BH-0121-15A	Brookland EC @ Bunker Hill	1st Floor inside Teachers Room	1/21/15	5.2		
BH-0121-15B	Brookland EC @ Bunker Hill	1st Floor inside Teachers Room	1/21/15	2.9		
BH-0121-16A	Brookland EC @ Bunker Hill	Basement inside Cafeteria	1/21/15	< 1		
BH-0121-16B	Brookland EC @ Bunker Hill	Basement inside Cafeteria	1/21/15	< 1		
BH-0121-17A	Brookland EC @ Bunker Hill	Basement inside Kitchen	1/21/15	< 1		
BH-0121-17B	Brookland EC @ Bunker Hill	Basement inside Kitchen	1/21/15	< 1		
BH-0121-18A	Brookland EC @ Bunker Hill	Basement inside Kitchen	1/21/15	< 1		
BH-0121-18B	Brookland EC @ Bunker Hill	Basement inside Kitchen	1/21/15	1.8		
BH-0121-19A	Brookland EC @ Bunker Hill	2nd Floor hallway adjacent to Boys Bathroom	1/21/15	< 1		
BH-0121-19B	Brookland EC @ Bunker Hill	2nd Floor hallway adjacent to Boys Bathroom	1/21/15	< 1		
BH-0121-20A	Brookland EC @ Bunker Hill	2nd Floor hallway adjacent to Girls Bathroom	1/21/15	< 1		
BH-0121-20B	Brookland EC @ Bunker Hill	2nd Floor hallway adjacent to Girls Bathroom	1/21/15	< 1		
BH-0121-21A	Brookland EC @ Bunker Hill	2nd Floor hallway adjacent to class room 241	1/21/15	< 1		
BH-0121-21B	Brookland EC @ Bunker Hill	2nd Floor hallway adjacent to class room 241	1/21/15	< 1		
BH-0121-22A	Brookland EC @ Bunker Hill	2nd Floor hallway adjacent to class room 237	1/21/15	< 1		
BH-0121-22B	Brookland EC @ Bunker Hill	2nd Floor hallway adjacent to class room 237	1/21/15	< 1		
<b>Percentage of Passed Samples</b>						<b>95.45%</b>
<b>Percentage of Failed Samples</b>						<b>4.55%</b>
BES-4-24-1A	Burrville ES	2nd Floor inside cafeteria	4/24/15	< 1		
BES-4-24-1B	Burrville ES	2nd Floor inside cafeteria	4/24/15	< 1		
BES-4-24-2A	Burrville ES	2nd Floor inside Teachers' lounge	4/24/15	7.9		
BES-4-24-2B	Burrville ES	2nd Floor inside Teachers' lounge	4/24/15	12		
BES-4-24-3A	Burrville ES	2nd Floor inside classroom 241	4/24/15	< 1		
BES-4-24-3B	Burrville ES	2nd Floor inside classroom 241	4/24/15	< 1		

BES-4-24-4A	Burrville ES	2nd Floor hallway by the Gym	4/24/15	< 1	
BES- 4-24-4B	Burrville ES	2nd Floor hallway by the Gym	4/24/15	< 1	
BES-4-24-5A	Burrville ES	2nd Floor hallway across elevator (high)	4/24/15	< 1	
BES- 4-24-5B	Burrville ES	2nd Floor hallway across elevator (high)	4/24/15	< 1	
BES-4-24-6A	Burrville ES	2nd Floor hallway across elevator (low)	4/24/15	< 1	
BES- 4-24-6B	Burrville ES	2nd Floor hallway across elevator (low)	4/24/15	< 1	
BES-4-24-7A	Burrville ES	1st Floor Hallway adjacent to room 112 (high)	4/24/15	< 1	
BES- 4-24-7B	Burrville ES	1st Floor Hallway adjacent to room 112 (high)	4/24/15	< 1	
BES-4-24-8A	Burrville ES	1st Floor Hallway adjacent to room 112 (low)	4/24/15	< 1	
BES- 4-24-8B	Burrville ES	1st Floor Hallway adjacent to room 112 (low)	4/24/15	< 1	
BES-4-24-9A	Burrville ES	2nd Floor inside classroom 228	4/24/15	< 1	
BES- 4-24-9B	Burrville ES	2nd Floor inside classroom 228	4/24/15	< 1	
BES-4-24-10A	Burrville ES	2nd Floor inside classroom 227	4/24/15	< 1	
BES- 4-24-10B	Burrville ES	2nd Floor inside classroom 227	4/24/15	< 1	
BES-4-24-11A	Burrville ES	2nd Floor hallway across classroom 228 (high)	4/24/15	< 1	
BES- 4-24-11B	Burrville ES	2nd Floor hallway across classroom 228 (high)	4/24/15	< 1	
BES-4-24-12A	Burrville ES	2nd Floor hallway across classroom 228 (low)	4/24/15	< 1	
BES- 4-24-12B	Burrville ES	2nd Floor hallway across classroom 228 (low)	4/24/15	< 1	
BES-4-24-13A	Burrville ES	2nd Floor inside classroom 224	4/24/15	< 1	
BES- 4-24-13B	Burrville ES	2nd Floor inside classroom 224	4/24/15	< 1	
BES-4-24-14A	Burrville ES	2nd Floor inside classroom 223 sink 1	4/24/15	< 1	
BES- 4-24-14B	Burrville ES	2nd Floor inside classroom 223 sink 1	4/24/15	< 1	
BES-4-24-15A	Burrville ES	2nd Floor inside classroom 223 sink 2	4/24/15	< 1	
BES- 4-24-15B	Burrville ES	2nd Floor inside classroom 223 sink 2	4/24/15	< 1	
BES-4-24-16A	Burrville ES	2nd Floor inside classroom 221	4/24/15	< 1	
BES- 4-24-16B	Burrville ES	2nd Floor inside classroom 221	4/24/15	< 1	
BES-4-24-17A	Burrville ES	1st Floor inside classroom 110	4/24/15	2	
BES- 4-24-17B	Burrville ES	1st Floor inside classroom 110	4/24/15	< 1	
BES-4-24-18A	Burrville ES	1st Floor inside classroom 115	4/24/15	< 1	
BES-4-24-18B	Burrville ES	1st Floor inside classroom 115	4/24/15	< 1	
BES-4-24-19A	Burrville ES	1st Floor inside classroom 114	4/24/15	< 1	
BES-4-24-19B	Burrville ES	1st Floor inside classroom 114	4/24/15	< 1	
BES-4-24-20A	Burrville ES	1st Floor inside classroom 112	4/24/15	< 1	
BES-4-24-20B	Burrville ES	1st Floor inside classroom 112	4/24/15	< 1	
BES-4-24-21A	Burrville ES	1st Floor inside classroom 113	4/24/15	< 1	
BES-4-24-21B	Burrville ES	1st Floor inside classroom 113	4/24/15	< 1	
BES-4-24-22A	Burrville ES	1st Floor inside classroom 108	4/24/15	< 1	
BES-4-24-22B	Burrville ES	1st Floor inside classroom 108	4/24/15	< 1	
BES-4-24-23A	Burrville ES	1st Floor hallway adjacent to nurse office	4/24/15	1.7	
BES-4-24-23B	Burrville ES	1st Floor hallway adjacent to nurse office	4/24/15	3	
BES-4-24-24A	Burrville ES	1st Floor adjacent to stairwell 1	4/24/15	7.6	
BES-4-24-24B	Burrville ES	1st Floor adjacent to stairwell 1	4/24/15	6.8	
BES-4-24-25A	Burrville ES	1st Floor hallway adjacent to mechanical room	4/24/15	< 1	
BES-4-24-25B	Burrville ES	1st Floor hallway adjacent to mechanical room	4/24/15	< 1	
BES-4-24-26A	Burrville ES	1st Floor south side of the GYM NW end (high)	4/24/15	< 1	
BES-4-24-26B	Burrville ES	1st Floor south side of the GYM NW end (high)	4/24/15	< 1	
BES-4-24-27A	Burrville ES	1st Floor south side of the GYM NW end (low)	4/24/15	< 1	
BES-4-24-27B	Burrville ES	1st Floor south side of the GYM NW end (low)	4/24/15	< 1	
BES-4-24-28A	Burrville ES	1st Floor south side of the GYM NE end (high)	4/24/15	< 1	
BES-4-24-28B	Burrville ES	1st Floor south side of the GYM NE end (high)	4/24/15	2.4	
BES-4-24-29A	Burrville ES	1st Floor south side of the GYM NE end (low)	4/24/15	< 1	
BES-4-24-29B	Burrville ES	1st Floor south side of the GYM NE end (low)	4/24/15	1.1	
BES-4-24-30A	Burrville ES	1st Floor inside GYM boys RR	4/24/15	< 1	
BES-4-24-30B	Burrville ES	1st Floor inside GYM boys RR	4/24/15	< 1	
BES-4-24-31A	Burrville ES	1st Floor inside GYM girls RR	4/24/15	< 1	

BES-4-24-31B	Burville ES	1st Floor inside GYM girls RR	4/24/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
JB-115-1A	Burroughs EC	1st Floor hallway adjacent to classroom 8	1/15/15	< 1		
JB-115-1B	Burroughs EC	1st Floor hallway adjacent to classroom 8	1/15/15	< 1		
JB-115-2A	Burroughs EC	1st Floor hallway adjacent to classroom 9A	1/15/15	< 1		
JB-115-2B	Burroughs EC	1st Floor hallway adjacent to classroom 9A	1/15/15	< 1		
JB-115-3A	Burroughs EC	Ground Floor Cafeteria Hallway adjacent to rest room (High)	1/15/15	< 1		
JB-115-3B	Burroughs EC	Ground Floor Cafeteria Hallway adjacent to rest room (High)	1/15/15	< 1		
JB-115-4A	Burroughs EC	Ground Floor Cafeteria Hallway adjacent to rest room (Low)	1/15/15	< 1		
JB-115-4B	Burroughs EC	Ground Floor Cafeteria Hallway adjacent to rest room (Low)	1/15/15	< 1		
JB-115-5A	Burroughs EC	1st Floor Hallway across from classroom 14	1/15/15	< 1		
JB-115-5B	Burroughs EC	1st Floor Hallway across from classroom 14	1/15/15	< 1		
JB-115-6A	Burroughs EC	1st Floor Hallway across from classroom 3	1/15/15	< 1		
JB-115-6B	Burroughs EC	1st Floor Hallway across from classroom 3	1/15/15	< 1		
JB-115-7A	Burroughs EC	Ground floor Hallway adjacent to classroom 19	1/15/15	< 1		
JB-115-7B	Burroughs EC	Ground floor Hallway adjacent to classroom 19	1/15/15	< 1		
JB-115-8A	Burroughs EC	Ground floor Hallway adjacent to classroom 20	1/15/15	< 1		
JB-115-8B	Burroughs EC	Ground floor Hallway adjacent to classroom 20	1/15/15	< 1		
JB-115-9A	Burroughs EC	Ground floor inside classroom 20	1/15/15	< 1		
JB-115-9B	Burroughs EC	Ground floor inside classroom 20	1/15/15	< 1		
JB-115-10A	Burroughs EC	Ground floor inside classroom 19	1/15/15	< 1		
JB-115-10B	Burroughs EC	Ground floor inside classroom 19	1/15/15	< 1		
JB-115-11A	Burroughs EC	Ground floor inside classroom 18	1/15/15	< 1		
JB-115-11B	Burroughs EC	Ground floor inside classroom 18	1/15/15	< 1		
JB-115-12A	Burroughs EC	Ground floor inside classroom 21	1/15/15	< 1		
JB-115-12B	Burroughs EC	Ground floor inside classroom 21	1/15/15	< 1		
JB-115-13A	Burroughs EC	Ground floor inside classroom 22	1/15/15	< 1		
JB-115-13B	Burroughs EC	Ground floor inside classroom 22	1/15/15	< 1		
JB-115-14A	Burroughs EC	1st Floor inside classroom 34	1/15/15	< 1		
JB-115-14B	Burroughs EC	1st Floor inside classroom 34	1/15/15	< 1		
JB-115-15A	Burroughs EC	1st Floor inside classroom 35	1/15/15	< 1		
JB-115-15B	Burroughs EC	1st Floor inside classroom 35	1/15/15	< 1		
JB-115-16A	Burroughs EC	Ground floor hallway across from class 27	1/15/15	< 1		
JB-115-16B	Burroughs EC	Ground floor hallway across from class 27	1/15/15	< 1		
JB-115-17A	Burroughs EC	1st Floor inside classroom 25	1/15/15	< 1		
JB-115-17B	Burroughs EC	1st Floor inside classroom 25	1/15/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
EE-0630-1A	C.H.O.I.C.E Academy @ Emery	Third Floor Hallway Across Rm 316	6/30/15	< 1		
EE-0630-1B	C.H.O.I.C.E Academy @ Emery	Third Floor Hallway Across Rm 316	6/30/15	< 1		
EE-0630-2A	C.H.O.I.C.E Academy @ Emery	Third Floor Hallway Across Rm 312	6/30/15	< 1		
EE-0630-2B	C.H.O.I.C.E Academy @ Emery	Third Floor Hallway Across Rm 312	6/30/15	< 1		
EE-0630-3A	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 316	6/30/15	< 1		
EE-0630-3B	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 316	6/30/15	< 1		
EE-0630-4A	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 314	6/30/15	< 1		
EE-0630-4B	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 314	6/30/15	2.3		
EE-0630-5A	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 312	6/30/15	1.9		
EE-0630-5B	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 312	6/30/15	1.1		
EE-0630-6A	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 308	6/30/15	5.9		
EE-0630-6B	C.H.O.I.C.E Academy @ Emery	Third Floor Inside Rm 308	6/30/15	< 1		
EE-0630-7A	C.H.O.I.C.E Academy @ Emery	Third Floor Hallway adjacent to Stairway 1	6/30/15	< 1		
EE-0630-7B	C.H.O.I.C.E Academy @ Emery	Third Floor Hallway adjacent to Stairway 1	6/30/15	< 1		
EE-0630-8A	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway across Rm 218	6/30/15	< 1		
EE-0630-8B	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway across Rm 218	6/30/15	< 1		

EE-0630-9A	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway adjacent to Rm 213	6/30/15	< 1		
EE-0630-9B	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway adjacent to Rm 213	6/30/15	< 1		
EE-0630-10A	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway adjacent to Rm 205	6/30/15	< 1		
EE-0630-10B	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway adjacent to Rm 205	6/30/15	< 1		
EE-0630-11A	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway across Rm 200	6/30/15	< 1		
EE-0630-11B	C.H.O.I.C.E Academy @ Emery	Second Floor Hallway across Rm 200	6/30/15	< 1		
EE-0630-12A	C.H.O.I.C.E Academy @ Emery	First Floor inside Rm 113	6/30/15	< 1		
EE-0630-12B	C.H.O.I.C.E Academy @ Emery	First Floor inside Rm 113	6/30/15	< 1		
EE-0630-13A	C.H.O.I.C.E Academy @ Emery	First Floor inside Rm 112	6/30/15	< 1		
EE-0630-13B	C.H.O.I.C.E Academy @ Emery	First Floor inside Rm 112	6/30/15	< 1		
EE-0630-14A	C.H.O.I.C.E Academy @ Emery	First Floor Hallway adjacent to Rm 110	6/30/15	< 1		
EE-0630-14B	C.H.O.I.C.E Academy @ Emery	First Floor Hallway adjacent to Rm 110	6/30/15	< 1		
EE-0630-15A	C.H.O.I.C.E Academy @ Emery	First Floor Hallway across Rm 102	6/30/15	< 1		
EE-0630-15B	C.H.O.I.C.E Academy @ Emery	First Floor Hallway across Rm 102	6/30/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
CWH-0121-1A	C.W. Harris ES	Health Suite	1/21/15	< 1		
CWH-0121-1B	C.W. Harris ES	Health Suite	1/21/15	< 1		
CWH-0121-2A	C.W. Harris ES	1st Floor – Between Teacher’s Restroom & Custodian Closet in Hallway adjacent to Room 109	1/21/15	< 1		
CWH-0121-2B	C.W. Harris ES	1st Floor – Between Teacher’s Restroom & Custodian Closet in Hallway adjacent to Room 109	1/21/15	< 1		
CWH-0121-3A	C.W. Harris ES	2nd Floor – Between Boy’s Restroom & Custodian Closet in Hallway diagonally from Room 218	1/21/15	< 1		
CWH-0121-3B	C.W. Harris ES	2nd Floor – Between Boy’s Restroom & Custodian Closet in Hallway diagonally from Room 218	1/21/15	< 1		
CWH-0121-4A	C.W. Harris ES	2nd Floor – Between Boy’s Restroom & Custodian Closet in Hallway in front of CWHTV-3 and across from Room 246	1/21/15	< 1		
CWH-0121-4B	C.W. Harris ES	2nd Floor – Between Boy’s Restroom & Custodian Closet in Hallway in front of CWHTV-3 and across from Room 246	1/21/15	< 1		
CWH-0121-5A	C.W. Harris ES	1st Floor – Between Boy’s Restroom & Girl’s Restroom in Hallway before Pre-K Wing Entrance	1/21/15	< 1		
CWH-0121-5B	C.W. Harris ES	1st Floor – Between Boy’s Restroom & Girl’s Restroom in Hallway before Pre-K Wing Entrance	1/21/15	< 1		
CWH-0121-6A	C.W. Harris ES	Multi-purpose Room	1/21/15	< 1		
CWH-0121-6B	C.W. Harris ES	Multi-purpose Room	1/21/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
CZ-0122-1B	Cardozo EC	3rd Floor Hallway adjacent to classroom 3204 (High)	1/22/15	< 1		
CZ-0122-2A	Cardozo EC	3rd Floor Hallway adjacent to classroom 3204 (Low)	1/22/15	< 1		
CZ-0122-2B	Cardozo EC	3rd Floor Hallway adjacent to classroom 3204 (Low)	1/22/15	< 1		
CZ-0122-3A	Cardozo EC	3rd Floor Hallway adjacent to classroom 3502 (High)	1/22/15	< 1		
CZ-0122-3B	Cardozo EC	3rd Floor Hallway adjacent to classroom 3502 (High)	1/22/15	< 1		
CZ-0122-4A	Cardozo EC	3rd Floor Hallway adjacent to classroom 3502 (Low)	1/22/15	< 1		
CZ-0122-4B	Cardozo EC	3rd Floor Hallway adjacent to classroom 3502 (Low)	1/22/15	< 1		
CZ-0122-5A	Cardozo EC	2nd Floor Hallway adjacent to classroom 2204 (High)	1/22/15	< 1		
CZ-0122-5B	Cardozo EC	2nd Floor Hallway adjacent to classroom 2204 (High)	1/22/15	< 1		
CZ-0122-6A	Cardozo EC	2nd Floor Hallway adjacent to classroom 2204 (Low)	1/22/15	< 1		
CZ-0122-6B	Cardozo EC	2nd Floor Hallway adjacent to classroom 2204 (Low)	1/22/15	< 1		
CZ-0122-7A	Cardozo EC	2nd Floor Hallway adjacent to classroom 2602 (High)	1/22/15	< 1		
CZ-0122-7B	Cardozo EC	2nd Floor Hallway adjacent to classroom 2602 (High)	1/22/15	< 1		
CZ-0122-8A	Cardozo EC	2nd Floor Hallway adjacent to classroom 2602 (Low)	1/22/15	< 1		
CZ-0122-8B	Cardozo EC	2nd Floor Hallway adjacent to classroom 2602 (Low)	1/22/15	< 1		
CZ-0122-9A	Cardozo EC	1st Floor Hallway adjacent to classroom 1204 (High)	1/22/15	< 1		
CZ-0122-9B	Cardozo EC	1st Floor Hallway adjacent to classroom 1204 (High)	1/22/15	< 1		

CZ-0122-10A	Cardozo EC	1st Floor Hallway adjacent to classroom 1204 (Low)	1/22/15	< 1		
CZ-0122-10B	Cardozo EC	1st Floor Hallway adjacent to classroom 1204 (Low)	1/22/15	< 1		
CZ-0122-11A	Cardozo EC	1st Floor Hallway adjacent to classroom 1603 (High)	1/22/15	< 1		
CZ-0122-11B	Cardozo EC	1st Floor Hallway adjacent to classroom 1603 (High)	1/22/15	< 1		
CZ-0122-12A	Cardozo EC	1st Floor Hallway adjacent to classroom 1603 (Low)	1/22/15	< 1		
CZ-0122-12B	Cardozo EC	1st Floor Hallway adjacent to classroom 1603 (Low)	1/22/15	< 1		
CZ-0122-13A	Cardozo EC	C Level Hallway adjacent to classroom C205 (High)	1/22/15	< 1		
CZ-0122-13B	Cardozo EC	C Level Hallway adjacent to classroom C205 (High)	1/22/15	< 1		
CZ-0122-14A	Cardozo EC	C Level Hallway adjacent to classroom C205 (Low)	1/22/15	< 1		
CZ-0122-14B	Cardozo EC	C Level Hallway adjacent to classroom C205 (Low)	1/22/15	< 1		
CZ-0122-15A	Cardozo EC	LT Level Hallway adjacent to classroom LT55 (High)	1/22/15	< 1		
CZ-0122-15B	Cardozo EC	LT Level Hallway adjacent to classroom LT55 (High)	1/22/15	< 1		
CZ-0122-16A	Cardozo EC	LT Level Hallway adjacent to classroom LT55 (Low)	1/22/15	< 1		
CZ-0122-16B	Cardozo EC	LT Level Hallway adjacent to classroom LT55 (Low)	1/22/15	< 1		
CZ-0122-17A	Cardozo EC	LT Level Hallway adjacent to classroom LT58 (High)	1/22/15	< 1		
CZ-0122-17B	Cardozo EC	LT Level Hallway adjacent to classroom LT58 (High)	1/22/15	< 1		
CZ-0122-18A	Cardozo EC	LT Level Hallway adjacent to classroom LT58 (Low)	1/22/15	< 1		
CZ-0122-18B	Cardozo EC	LT Level Hallway adjacent to classroom LT58 (Low)	1/22/15	< 1		
CZ-0122-19A	Cardozo EC	T Level Hallway adjacent to room T210	1/22/15	< 1		
CZ-0122-19B	Cardozo EC	T Level Hallway adjacent to room T210	1/22/15	< 1		
CZ-0122-20A	Cardozo EC	LT Level Gym Lobby (High)	1/22/15	< 1		
CZ-0122-20B	Cardozo EC	LT Level Gym Lobby (High)	1/22/15	< 1		
CZ-0122-21A	Cardozo EC	LT Level Gym Lobby (Low)	1/22/15	< 1		
CZ-0122-21B	Cardozo EC	LT Level Gym Lobby (Low)	1/22/15	< 1		
CZ-0122-22A	Cardozo EC	Inside pool area (High)	1/22/15	< 1		
CZ-0122-22B	Cardozo EC	Inside pool area (High)	1/22/15	< 1		
CZ-0122-23A	Cardozo EC	Inside pool area (Low)	1/22/15	< 1		
CZ-0122-23B	Cardozo EC	Inside pool area (Low)	1/22/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
CLE-122-1A	Cleveland ES	3rd Floor Hallway adjacent to south stair well, across classroom 307 (High)	1/22/15	< 1		
CLE-122-1B	Cleveland ES	3rd Floor Hallway adjacent to south stair well, across classroom 307 (High)	1/22/15	< 1		
CLE-122-2A	Cleveland ES	3rd Floor Hallway adjacent to South stair well, across classroom 307 (Low)	1/22/15	< 1		
CLE-122-2B	Cleveland ES	3rd Floor Hallway adjacent to South stair well, across classroom 307 (Low)	1/22/15	< 1		
CLE-122-3A	Cleveland ES	3rd Floor inside classroom 304	1/22/15	< 1		
CLE-122-3B	Cleveland ES	3rd Floor inside classroom 304	1/22/15	< 1		
CLE-122-4A	Cleveland ES	3rd Floor inside classroom 308	1/22/15	< 1		
CLE-122-4B	Cleveland ES	3rd Floor inside classroom 308	1/22/15	< 1		
CLE-122-5A	Cleveland ES	3rd Floor inside classroom 313	1/22/15	< 1		
CLE-122-5B	Cleveland ES	3rd Floor inside classroom 313	1/22/15	< 1		
CLE-122-6A	Cleveland ES	3rd Floor inside classroom 302	1/22/15	< 1		
CLE-122-6B	Cleveland ES	3rd Floor inside classroom 302	1/22/15	< 1		
CLE-122-7A	Cleveland ES	3rd Floor inside classroom 315	1/22/15	< 1		
CLE-122-7B	Cleveland ES	3rd Floor inside classroom 315	1/22/15	< 1		
CLE-122-8A	Cleveland ES	3rd Floor inside classroom 301	1/22/15	< 1		
CLE-122-8B	Cleveland ES	3rd Floor inside classroom 301	1/22/15	< 1		
CLE-122-9A	Cleveland ES	2nd Floor inside classroom 201	1/22/15	< 1		
CLE-122-9B	Cleveland ES	2nd Floor inside classroom 201	1/22/15	< 1		
CLE-122-10A	Cleveland ES	2nd Floor inside classroom 218	1/22/15	< 1		
CLE-122-10B	Cleveland ES	2nd Floor inside classroom 218	1/22/15	< 1		
CLE-122-11A	Cleveland ES	2nd Floor inside classroom 203	1/22/15	< 1		

CLE-122-11B	Cleveland ES	2nd Floor inside classroom 203	1/22/15	< 1		
CLE-122-12A	Cleveland ES	2nd Floor inside classroom 216, B wall side	1/22/15	< 1		
CLE-122-12B	Cleveland ES	2nd Floor inside classroom 216, B wall side	1/22/15	< 1		
CLE-122-13A	Cleveland ES	2nd Floor inside classroom 216, B wall side	1/22/15	< 1		
CLE-122-13B	Cleveland ES	2nd Floor inside classroom 216, B wall side	1/22/15	< 1		
CLE-122-14A	Cleveland ES	2nd Floor inside classroom 216, D wall side	1/22/15	< 1		
CLE-122-14B	Cleveland ES	2nd Floor inside classroom 216, D wall side	1/22/15	< 1		
CLE-122-15A	Cleveland ES	2nd Floor inside classroom 216, D wall side	1/22/15	< 1		
CLE-122-15B	Cleveland ES	2nd Floor inside classroom 216, D wall side	1/22/15	< 1		
CLE-122-16A	Cleveland ES	2nd Floor inside classroom 207	1/22/15	< 1		
CLE-122-16B	Cleveland ES	2nd Floor inside classroom 207	1/22/15	< 1		
CLE-122-17A	Cleveland ES	2nd Floor inside classroom 212	1/22/15	< 1		
CLE-122-17B	Cleveland ES	2nd Floor inside classroom 212	1/22/15	< 1		
CLE-122-18A	Cleveland ES	2nd Floor hallway adjacent to south stair well (high)	1/22/15	< 1		
CLE-122-18B	Cleveland ES	2nd Floor hallway adjacent to south stair well (high)	1/22/15	< 1		
CLE-122-19A	Cleveland ES	2nd Floor hallway adjacent to south stair well (low)	1/22/15	< 1		
CLE-122-19B	Cleveland ES	2nd Floor hallway adjacent to south stair well (low)	1/22/15	< 1		
CLE-122-20A	Cleveland ES	1st Floor hallway adjacent to south stair well (high)	1/22/15	< 1		
CLE-122-20B	Cleveland ES	1st Floor hallway adjacent to south stair well (high)	1/22/15	< 1		
CLE-122-21A	Cleveland ES	1st Floor hallway adjacent to south stair well (low)	1/22/15	< 1		
CLE-122-21B	Cleveland ES	1st Floor hallway adjacent to south stair well (low)	1/22/15	< 1		
CLE-122-22A	Cleveland ES	1st Floor inside classroom 111	1/22/15	< 1		
CLE-122-22B	Cleveland ES	1st Floor inside classroom 111	1/22/15	< 1		
CLE-122-23A	Cleveland ES	1st Floor inside classroom 106	1/22/15	< 1		
CLE-122-23B	Cleveland ES	1st Floor inside classroom 106	1/22/15	< 1		
CLE-122-24A	Cleveland ES	1st Floor inside classroom 103	1/22/15	< 1		
CLE-122-24B	Cleveland ES	1st Floor inside classroom 103	1/22/15	< 1		
CLE-122-25A	Cleveland ES	1st Floor inside classroom 115	1/22/15	< 1		
CLE-122-25B	Cleveland ES	1st Floor inside classroom 115	1/22/15	< 1		
CLE-122-26A	Cleveland ES	1st Floor inside classroom 117	1/22/15	< 1		
CLE-122-26B	Cleveland ES	1st Floor inside classroom 117	1/22/15	< 1		
CLE-122-27A	Cleveland ES	1st Floor inside classroom 120	1/22/15	< 1		
CLE-122-27B	Cleveland ES	1st Floor inside classroom 120	1/22/15	< 1		
CLE-122-28A	Cleveland ES	1st Floor inside classroom 101	1/22/15	< 1		
CLE-122-28B	Cleveland ES	1st Floor inside classroom 101	1/22/15	< 1		
CLE-122-29A	Cleveland ES	Ground floor hallway- entrance lobby. (high)	1/22/15	< 1		
CLE-122-29B	Cleveland ES	Ground floor hallway- entrance lobby. (high)	1/22/15	< 1		
CLE-122-30A	Cleveland ES	Ground floor hallway- entrance lobby. (low)	1/22/15	< 1		
CLE-122-30B	Cleveland ES	Ground floor hallway- entrance lobby. (low)	1/22/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
CH-0122-1A	Columbia Heights EC	4th floor hallway between Boy's and Girl's Rooms (high)	1/22/15	< 1		
CH-0122-1B	Columbia Heights EC	4th floor hallway between Boy's and Girl's Rooms (high)	1/22/15	< 1		
CH-0122-2A	Columbia Heights EC	4th floor hallway between Boy's and Girl's Rooms (low)	1/22/15	< 1		
CH-0122-2B	Columbia Heights EC	4th floor hallway between Boy's and Girl's Rooms (low)	1/22/15	< 1		
CH-0122-3A	Columbia Heights EC	3rd floor hallway between Boy's and Girl's Rooms (high)	1/22/15	< 1		
CH-0122-3B	Columbia Heights EC	3rd floor hallway between Boy's and Girl's Rooms (high)	1/22/15	< 1		
CH-0122-4A	Columbia Heights EC	3rd floor hallway between Boy's and Girl's Rooms (low)	1/22/15	< 1		
CH-0122-4B	Columbia Heights EC	3rd floor hallway between Boy's and Girl's Rooms (low)	1/22/15	< 1		
CH-0122-5A	Columbia Heights EC	2nd floor hallway near elevator (high, right)	1/22/15	< 1		
CH-0122-5B	Columbia Heights EC	2nd floor hallway near elevator (high, right)	1/22/15	< 1		
CH-0122-6A	Columbia Heights EC	2nd floor hallway near elevator (low, right)	1/22/15	< 1		
CH-0122-6B	Columbia Heights EC	2nd floor hallway near elevator (low, right)	1/22/15	< 1		
CH-0122-7A	Columbia Heights EC	2nd floor hallway across from display cases (high, left)	1/22/15	< 1		
CH-0122-7B	Columbia Heights EC	2nd floor hallway across from display cases (high, left)	1/22/15	< 1		

CH-0122-8A	Columbia Heights EC	2nd floor hallway across from display cases (low, left)	1/22/15	< 1		
CH-0122-8B	Columbia Heights EC	2nd floor hallway across from display cases (low, left)	1/22/15	< 1		
CH-0122-9A	Columbia Heights EC	2nd floor hallway across from display cases (high, right)	1/22/15	< 1		
CH-0122-9B	Columbia Heights EC	2nd floor hallway across from display cases (high, right)	1/22/15	< 1		
CH-0122-10A	Columbia Heights EC	2nd floor hallway across from display cases (low, right)	1/22/15	< 1		
CH-0122-10B	Columbia Heights EC	2nd floor hallway across from display cases (low, right)	1/22/15	< 1		
CH-0122-11A	Columbia Heights EC	2nd floor inside Boy's Locker Room (high)	1/22/15	< 1		
CH-0122-11B	Columbia Heights EC	2nd floor inside Boy's Locker Room (high)	1/22/15	< 1		
CH-0122-12A	Columbia Heights EC	2nd floor inside Boy's Locker Room (low)	1/22/15	< 1		
CH-0122-12B	Columbia Heights EC	2nd floor inside Boy's Locker Room (low)	1/22/15	< 1		
CH-0122-13A	Columbia Heights EC	2nd floor inside Girl's Locker Room (high)	1/22/15	< 1		
CH-0122-13B	Columbia Heights EC	2nd floor inside Girl's Locker Room (high)	1/22/15	< 1		
CH-0122-14A	Columbia Heights EC	2nd floor inside Girl's Locker Room (low)	1/22/15	< 1		
CH-0122-14B	Columbia Heights EC	2nd floor inside Girl's Locker Room (low)	1/22/15	< 1		
CH-0122-15A	Columbia Heights EC	1st floor hallway across from Janitor's Closet C135 (high)	1/22/15	< 1		
CH-0122-15B	Columbia Heights EC	1st floor hallway across from Janitor's Closet C135 (high)	1/22/15	< 1		
CH-0122-16A	Columbia Heights EC	1st floor hallway across from Janitor's Closet C135 (low)	1/22/15	< 1		
CH-0122-16B	Columbia Heights EC	1st floor hallway across from Janitor's Closet C135 (low)	1/22/15	< 1		
CH-0122-17A	Columbia Heights EC	1st floor hallway across from Janitor's Closet A146 (high)	1/22/15	< 1		
CH-0122-17B	Columbia Heights EC	1st floor hallway across from Janitor's Closet A146 (high)	1/22/15	< 1		
CH-0122-18A	Columbia Heights EC	1st floor hallway across from Janitor's Closet A146 (low)	1/22/15	< 1		
CH-0122-18B	Columbia Heights EC	1st floor hallway across from Janitor's Closet A146 (low)	1/22/15	< 1		
CH-0122-19A	Columbia Heights EC	1st floor hallway near Cafeteria exit (high)	1/22/15	< 1		
CH-0122-19B	Columbia Heights EC	1st floor hallway near Cafeteria exit (high)	1/22/15	< 1		
CH-0122-20A	Columbia Heights EC	1st floor hallway near Cafeteria exit (low)	1/22/15	< 1		
CH-0122-20B	Columbia Heights EC	1st floor hallway near Cafeteria exit (low)	1/22/15	< 1		
CH-0122-21A	Columbia Heights EC	1st floor hallway across from Art Room D113 (high)	1/22/15	< 1		
CH-0122-21B	Columbia Heights EC	1st floor hallway across from Art Room D113 (high)	1/22/15	< 1		
CH-0122-22A	Columbia Heights EC	1st floor hallway across from Art Room D113 (low)	1/22/15	< 1		
CH-0122-22B	Columbia Heights EC	1st floor hallway across from Art Room D113 (low)	1/22/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
CH-0204-1A	Coolidge HS	3rd Floor hallway adjacent to classroom T313	2/4/15	< 1		
CH-0204-1B	Coolidge HS	3rd Floor hallway adjacent to classroom T313	2/4/15	< 1		
CH-0204-2A	Coolidge HS	3rd Floor hallway adjacent to classroom 314	2/4/15	< 1		
CH-0204-3A	Coolidge HS	3rd Floor hallway adjacent to classroom 314	2/4/15	< 1		
CH-0204-4A	Coolidge HS	3rd Floor hallway adjacent to classroom 331	2/4/15	< 1		
CH-0204-4A	Coolidge HS	3rd Floor hallway adjacent to classroom 331	2/4/15	< 1		
CH-0204-5A	Coolidge HS	3rd Floor hallway across stairway 5	2/4/15	< 1		
CH-0204-5A	Coolidge HS	3rd Floor hallway across stairway 5	2/4/15	< 1		
CH-0204-6A	Coolidge HS	2nd Floor hallway adjacent to classroom 201	2/4/15	< 1		
CH-0204-6A	Coolidge HS	2nd Floor hallway adjacent to classroom 201	2/4/15	< 1		
CH-0204-7A	Coolidge HS	2nd Floor hallway adjacent to classroom 235	2/4/15	< 1		
CH-0204-7A	Coolidge HS	2nd Floor hallway adjacent to classroom 235	2/4/15	< 1		
CH-0204-8A	Coolidge HS	2nd Floor hallway adjacent to classroom 225	2/4/15	< 1		
CH-0204-8B	Coolidge HS	2nd Floor hallway adjacent to classroom 225	2/4/15	< 1		
CH-0204-9A	Coolidge HS	1st floor hallway adjacent to classroom 123	2/4/15	< 1		
CH-0204-9B	Coolidge HS	1st floor hallway adjacent to classroom 123	2/4/15	< 1		
CH-0204-10A	Coolidge HS	1st floor hallway across stair area 5	2/4/15	< 1		
CH-0204-10B	Coolidge HS	1st floor hallway across stair area 5	2/4/15	< 1		
CH-0204-11A	Coolidge HS	1st floor hallway adjacent to classroom 105	2/4/15	< 1		
CH-0204-11B	Coolidge HS	1st floor hallway adjacent to classroom 105	2/4/15	< 1		
CH-0204-12A	Coolidge HS	Ground floor inside Cafeteria	2/4/15	< 1		
CH-0204-12B	Coolidge HS	Ground floor inside Cafeteria	2/4/15	1.4		
CH-0204-13A	Coolidge HS	Ground floor hallway adjacent to B115	2/4/15	< 1		

CH-0204-13B	Coolidge HS	Ground floor hallway adjacent to B115	2/4/15	< 1		
CH-0204-14A	Coolidge HS	1st floor inside Frank R Williams Activity Center next to door 174	2/4/15	< 1		
CH-0204-14B	Coolidge HS	1st floor inside Frank R Williams Activity Center next to door 174	2/4/15	< 1		
CH-0204-15A	Coolidge HS	1st floor inside Frank R Williams Activity Center next to door 173 (High)	2/4/15	7.2		
CH-0204-15B	Coolidge HS	1st floor inside Frank R Williams Activity Center next to door 173 (High)	2/4/15	7.5		
CH-0204-16A	Coolidge HS	1st floor inside Frank R Williams Activity Center next to door 173 (Low)	2/4/15	10		
CH-0204-16B	Coolidge HS	1st floor inside Frank R Williams Activity Center next to door 173 (Low)	2/4/15	7.6		
CH-0204-17A	Coolidge HS	1st floor Frank inside R Williams Activity Center next to door 172	2/4/15		84	Filter Installed
CH-0204-17B	Coolidge HS	1st floor Frank inside R Williams Activity Center next to door 172	2/4/15		71	Filter Installed
CH-0204-18A	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to G locker	2/4/15	< 1		
CH-0204-18B	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to G locker	2/4/15	< 1		
CH-0204-19A	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to stair 1	2/4/15	< 1		
CH-0204-19B	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to stair 1	2/4/15	< 1		
CH-0204-20A	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to door 181	2/4/15	< 1		
CH-0204-20B	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to door 181	2/4/15	< 1		
CH-0204-21A	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to B locker	2/4/15	< 1		
CH-0204-21B	Coolidge HS	Basement floor inside Frank R Williams Activity Center next to B locker	2/4/15	< 1		
CH-0204-22A	Coolidge HS	Basement floor inside Frank R Williams Activity Center adjacent to room B105	2/4/15	< 1		
CH-0204-22B	Coolidge HS	Basement floor inside Frank R Williams Activity Center adjacent to room B105	2/4/15	< 1		
CH-0204-23A	Coolidge HS	Basement floor inside Frank R Williams Activity Center inside girl's locker room	2/4/15	1.1		
CH-0204-23B	Coolidge HS	Basement floor inside Frank R Williams Activity Center inside girl's locker room	2/4/15	< 1		
CH-0204-24A	Coolidge HS	Basement floor inside Frank R Williams Activity Center inside boy's locker room	2/4/15	< 1		
CH-0204-24B	Coolidge HS	Basement floor inside Frank R Williams Activity Center inside boy's locker room	2/4/15	< 1		
CH-0204-25A	Coolidge HS	1st floor inside Gym	2/4/15	< 1		
CH-0204-25B	Coolidge HS	1st floor inside Gym	2/4/15	< 1		
CH-0204-26A	Coolidge HS	Basement floor in front lobby outside Auditorium left	2/4/15		24	Filter Installed
CH-0204-26B	Coolidge HS	Basement floor in front lobby outside Auditorium left	2/4/15		180	Filter Installed
CH-0204-27A	Coolidge HS	Basement floor in front lobby outside Auditorium right	2/4/15		51	Filter Installed
CH-0204-27B	Coolidge HS	Basement floor in front lobby outside Auditorium right	2/4/15		38	Filter Installed
<b>Percentage of Passed Samples</b>						<b>88.89%</b>
<b>Percentage of Failed Samples</b>						<b>11.11%</b>
DCG-0523-1A	DC General	5th floor hallway adjacent to Room 526	5/23/15	< 1		
DCG-0523-1B	DC General	5th floor hallway adjacent to Room 526	5/23/15	< 1		
DCG-0523-2A	DC General	5th floor hallway adjacent to Men's Bathroom 3	5/23/15	< 1		
DCG-0523-2B	DC General	5th floor hallway adjacent to Men's Bathroom 3	5/23/15	< 1		
DCG-0523-3A	DC General	5th floor inside Kitchen	5/23/15	< 1		
DCG-0523-3B	DC General	5th floor inside Kitchen	5/23/15	< 1		
DCG-0523-4A	DC General	4th floor hallway near Men's Bathroom 3	5/23/15	< 1		
DCG-0523-4B	DC General	4th floor hallway near Men's Bathroom 3	5/23/15	< 1		

DCG-0523-5A	DC General	4th floor inside Kitchen	5/23/15	< 1		
DCG-0523-5B	DC General	4th floor inside Kitchen	5/23/15	< 1		
DCG-0523-6A	DC General	4th floor hallway adjacent to Room 424	5/23/15	< 1		
DCG-0523-6B	DC General	4th floor hallway adjacent to Room 424	5/23/15	< 1		
DCG-0523-7A	DC General	3rd floor hallway adjacent to Room 323	5/23/15	< 1		
DCG-0523-7B	DC General	3rd floor hallway adjacent to Room 323	5/23/15	< 1		
DCG-0523-8A	DC General	3rd floor hallway near Room 309	5/23/15	< 1		
DCG-0523-8B	DC General	3rd floor hallway near Room 309	5/23/15	< 1		
DCG-0523-9A	DC General	3rd floor inside Cafeteria	5/23/15	< 1		
DCG-0523-9B	DC General	3rd floor inside Cafeteria	5/23/15	< 1		
DCG-0523-10A	DC General	3rd floor inside Kitchen	5/23/15	14		
DCG-0523-10B	DC General	3rd floor inside Kitchen	5/23/15	1.3		
DCG-0523-11A	DC General	2nd floor hallway adjacent to Room 230	5/23/15	< 1		
DCG-0523-11B	DC General	2nd floor hallway adjacent to Room 230	5/23/15	< 1		
DCG-0523-12A	DC General	2nd floor hallway adjacent to Women's Bathroom 13	5/23/15	< 1		
DCG-0523-12B	DC General	2nd floor hallway adjacent to Women's Bathroom 13	5/23/15	< 1		
DCG-0523-13A	DC General	2nd floor inside Cafeteria	5/23/15	< 1		
DCG-0523-13B	DC General	2nd floor inside Cafeteria	5/23/15	< 1		
DCG-0523-14A	DC General	2nd floor inside Kitchen	5/23/15	< 1		
DCG-0523-14B	DC General	2nd floor inside Kitchen	5/23/15	< 1		
DCG-0523-15A	DC General	2nd floor hallway across from Room 211	5/23/15	< 1		
DCG-0523-15B	DC General	2nd floor hallway across from Room 211	5/23/15	< 1		
DCG-0523-16A	DC General	2nd floor inside Activity Room	5/23/15	< 1		
DCG-0523-16B	DC General	2nd floor inside Activity Room	5/23/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
DM-0205-1A	Deal MS	3rd Floor hallway adjacent to classroom W300	2/5/15	< 1		
DM-0205-1A	Deal MS	3rd Floor hallway adjacent to classroom W300	2/5/15	< 1		
DM-0205-2A	Deal MS	3rd Floor hallway adjacent to classroom E300 (high)	2/5/15	< 1		
DM-0205-2B	Deal MS	3rd Floor hallway adjacent to classroom E300 (high)	2/5/15	< 1		
DM-0205-3A	Deal MS	3rd Floor hallway adjacent to classroom W300 (low)	2/5/15	< 1		
DM-0205-3B	Deal MS	3rd Floor hallway adjacent to classroom W300 (low)	2/5/15	< 1		
DM-0205-4A	Deal MS	2nd Floor hallway adjacent to classroom E200 (high)	2/5/15	< 1		
DM-0205-4B	Deal MS	2nd Floor hallway adjacent to classroom E200 (high)	2/5/15	< 1		
DM-0205-5A	Deal MS	2nd Floor hallway adjacent to classroom E200 (low)	2/5/15	< 1		
DM-0205-5B	Deal MS	2nd Floor hallway adjacent to classroom E200 (low)	2/5/15	< 1		
DM-0205-6A	Deal MS	2nd Floor hallway adjacent to classroom W200	2/5/15	< 1		
DM-0205-6B	Deal MS	2nd Floor hallway adjacent to classroom W200	2/5/15	< 1		
DM-0205-7A	Deal MS	2nd Floor hallway adjacent to classroom W200	2/5/15	< 1		
DM-0205-7B	Deal MS	2nd Floor hallway adjacent to classroom W200	2/5/15	< 1		
DM-0205-8A	Deal MS	1st Floor hallway adjacent to classroom W100	2/5/15	< 1		
DM-0205-8B	Deal MS	1st Floor hallway adjacent to classroom W100	2/5/15	< 1		
DM-0205-9A	Deal MS	1st Floor hallway adjacent to classroom W100	2/5/15	< 1		
DM-0205-9B	Deal MS	1st Floor hallway adjacent to classroom W100	2/5/15	< 1		
DM-0205-10A	Deal MS	1st Floor hallway adjacent to classroom E100	2/5/15	< 1		
DM-0205-10B	Deal MS	1st Floor hallway adjacent to classroom E100	2/5/15	< 1		
DM-0205-11A	Deal MS	1st Floor hallway adjacent to classroom E100	2/5/15	< 1		
DM-0205-11B	Deal MS	1st Floor hallway adjacent to classroom E100	2/5/15	< 1		
DM-0205-12A	Deal MS	Ground floor hallway at cafeteria NG20	2/5/15	< 1		
DM-0205-12B	Deal MS	Ground floor hallway at cafeteria NG20	2/5/15	< 1		
DM-0205-13A	Deal MS	Ground floor inside cafeteria	2/5/15	< 1		
DM-0205-13B	Deal MS	Ground floor inside cafeteria	2/5/15	< 1		
DM-0205-14A	Deal MS	Ground floor inside cafeteria	2/5/15	< 1		
DM-0205-14B	Deal MS	Ground floor inside cafeteria	2/5/15	< 1		
DM-0205-15A	Deal MS	Ground floor hallway adjacent to office CG42 (high)	2/5/15	< 1		

DM-0205-15B	Deal MS	Ground floor hallway adjacent to office CG42 (high)	2/5/15	< 1		
DM-0205-16A	Deal MS	Ground floor hallway adjacent to office CG42 (low)	2/5/15	< 1		
DM-0205-16B	Deal MS	Ground floor hallway adjacent to office CG42 (low)	2/5/15	< 1		
DM-0205-17A	Deal MS	Ground floor hallway adjacent to boys locker room NG12 (high)	2/5/15	< 1		
DM-0205-17B	Deal MS	Ground floor hallway adjacent to boys locker room NG12 (high)	2/5/15	< 1		
DM-0205-18A	Deal MS	Ground floor hallway adjacent to boys locker room NG12 (high)	2/5/15	< 1		
DM-0205-18B	Deal MS	Ground floor hallway adjacent to boys locker room NG12 (high)	2/5/15	< 1		
DM-0205-19A	Deal MS	Ground floor inside the Gym	2/5/15	< 1		
DM-0205-19B	Deal MS	Ground floor inside the Gym	2/5/15	< 1		
DM-0205-20A	Deal MS	Ground floor inside the Gym	2/5/15	< 1		
DM-0205-20B	Deal MS	Ground floor inside the Gym	2/5/15	< 1		
DM-0205-21A	Deal MS	Ground floor hallway rest room across room RG03	2/5/15	< 1		
DM-0205-21B	Deal MS	Ground floor hallway rest room across room RG03	2/5/15	< 1		
DM-0205-22A	Deal MS	Ground floor hallway rest room across room RG03	2/5/15	< 1		
DM-0205-22B	Deal MS	Ground floor hallway rest room across room RG03	2/5/15	< 1		
DM-0205-23A	Deal MS	1st Floor hallway rest room across room R103	2/5/15	< 1		
DM-0205-23B	Deal MS	1st Floor hallway rest room across room R103	2/5/15	< 1		
DM-0205-24A	Deal MS	1st Floor hallway rest room across room R103	2/5/15	< 1		
DM-0205-24B	Deal MS	1st Floor hallway rest room across room R103	2/5/15	< 1		
DM-0205-25A	Deal MS	1st Floor inside classroom R102	2/5/15	< 1		
DM-0205-25B	Deal MS	1st Floor inside classroom R102	2/5/15	< 1		
DM-0205-26A	Deal MS	1st Floor inside classroom R102	2/5/15	< 1		
DM-0205-26B	Deal MS	1st Floor inside classroom R102	2/5/15	< 1		
DM-0205-27A	Deal MS	1st Floor inside classroom R102	2/5/15	< 1		
DM-0205-27B	Deal MS	1st Floor inside classroom R102	2/5/15	< 1		
DM-0205-28A	Deal MS	1st Floor inside classroom R102	2/5/15	< 1		
DM-0205-28B	Deal MS	1st Floor inside classroom R102	2/5/15	< 1		
DM-0205-29A	Deal MS	1st Floor hallway adjacent to classroom R116	2/5/15	< 1		
DM-0205-29B	Deal MS	1st Floor hallway adjacent to classroom R116	2/5/15	< 1		
DM-0205-30A	Deal MS	1st Floor hallway adjacent to classroom R116	2/5/15	< 1		
DM-0205-30B	Deal MS	1st Floor hallway adjacent to classroom R116	2/5/15	< 1		
DM-0205-31A	Deal MS	Ground floor inside classroom RG02	2/5/15	< 1		
DM-0205-31B	Deal MS	Ground floor inside classroom RG02	2/5/15	< 1		
DM-0205-32A	Deal MS	Ground floor inside classroom RG02	2/5/15	1.2		
DM-0205-32B	Deal MS	Ground floor inside classroom RG02	2/5/15	< 1		
DM-0205-33A	Deal MS	Ground floor inside classroom RG02	2/5/15	< 1		
DM-0205-33B	Deal MS	Ground floor inside classroom RG02	2/5/15	< 1		
DM-0205-34A	Deal MS	Ground floor inside classroom RG02	2/5/15	2.3		
DM-0205-34B	Deal MS	Ground floor inside classroom RG02	2/5/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
DES-1224-1A	Drew ES	4Th Floor – Front Room 404	12/24/14	< 1		
DES-1224-2B	Drew ES	4Th Floor – Front Room 404	12/24/14	< 1		
DES-1224-3A	Drew ES	4Th Floor – Front Room 404	12/24/14	< 1		
DES-1224-4B	Drew ES	4Th Floor – Front Room 404	12/24/14	< 1		
DES-1224-5A	Drew ES	4Th Floor – Front Room 400	12/24/14	3.3		
DES-1224-6B	Drew ES	4Th Floor – Front Room 400	12/24/14	< 1		
DES-1224-7A	Drew ES	3rd Floor – Front Room 300	12/24/14	< 1		
DES-1224-8B	Drew ES	3rd Floor – Front Room 300	12/24/14	< 1		
DES-1224-9A	Drew ES	3rd Floor – Front Room 300	12/24/14	< 1		
DES-1224-10B	Drew ES	3rd Floor – Front Room 300	12/24/14	< 1		
DES-1224-11A	Drew ES	3rd Floor – Next to Room 307	12/24/14	< 1		
DES-1224-12B	Drew ES	3rd Floor – Next to Room 307	12/24/14	< 1		
DES-1224-13A	Drew ES	3rd Floor – Next to Room 307	12/24/14	< 1		
DES-1224-14B	Drew ES	3rd Floor – Next to Room 307	12/24/14	< 1		

DES-1224-15A	Drew ES	2nd Floor – In Room 205	12/24/14	< 1		
DES-1224-16B	Drew ES	2nd Floor – In Room 205	12/24/14	< 1		
DES-1224-17A	Drew ES	2nd Floor – In Room 207	12/24/14	< 1		
DES-1224-18B	Drew ES	2nd Floor – In Room 207	12/24/14	< 1		
DES-1224-19A	Drew ES	2nd Floor – Front Room 204	12/24/14	< 1		
DES-1224-20B	Drew ES	2nd Floor – Front Room 204	12/24/14	< 1		
DES-1224-21A	Drew ES	2nd Floor – Front Room 204	12/24/14	< 1		
DES-1224-22B	Drew ES	2nd Floor – Front Room 204	12/24/14	< 1		
DES-1224-23A	Drew ES	2nd Floor – In Room 209	12/24/14	< 1		
DES-1224-24B	Drew ES	2nd Floor – In Room 209	12/24/14	< 1		
DES-1224-25A	Drew ES	2nd Floor – Front Room 200	12/24/14	< 1		
DES-1224-26B	Drew ES	2nd Floor – Front Room 200	12/24/14	< 1		
DES-1224-27A	Drew ES	2nd Floor – Front Room 200	12/24/14	< 1		
DES-1224-28B	Drew ES	2nd Floor – Front Room 200	12/24/14	< 1		
DES-1224-29A	Drew ES	2nd Floor – In Room 213	12/24/14	< 1		
DES-1224-30B	Drew ES	2nd Floor – In Room 213	12/24/14	< 1		
DES-1224-31A	Drew ES	1st Floor – Front Health Room	12/24/14	< 1		
DES-1224-32B	Drew ES	1st Floor – Front Health Room	12/24/14	< 1		
DES-1224-33A	Drew ES	1st Floor – Front Health Room	12/24/14	< 1		
DES-1224-34B	Drew ES	1st Floor – Front Health Room	12/24/14	< 1		
DES-1224-35A	Drew ES	1st Floor – In Room 104	12/24/14	< 1		
DES-1224-36B	Drew ES	1st Floor – In Room 104	12/24/14	< 1		
DES-1224-37A	Drew ES	1st Floor – In Room 108	12/24/14	< 1		
DES-1224-38B	Drew ES	1st Floor – In Room 108	12/24/14	< 1		
DES-1224-39A	Drew ES	1st Floor – In Room 105	12/24/14	< 1		
DES-1224-40B	Drew ES	1st Floor – In Room 105	12/24/14	< 1		
DES-1224-41A	Drew ES	1st Floor – Near Room 105	12/24/14	< 1		
DES-1224-42B	Drew ES	1st Floor – Near Room 105	12/24/14	< 1		
DES-1224-43A	Drew ES	1st Floor – Near Room 105	12/24/14	< 1		
DES-1224-44B	Drew ES	1st Floor – Near Room 105	12/24/14	< 1		
DES-1224-45A	Drew ES	1st Floor – In Room 107	12/24/14	< 1		
DES-1224-46B	Drew ES	1st Floor – In Room 107	12/24/14	< 1		
DES-1224-47A	Drew ES	1st Floor – In Room 106	12/24/14	< 1		
DES-1224-48B	Drew ES	1st Floor – In Room 106	12/24/14	< 1		
DES-1224-49A	Drew ES	1st Floor – In Café	12/24/14	< 1		
DES-1224-50B	Drew ES	1st Floor – In Café	12/24/14	< 1		
DES-1224-51A	Drew ES	1st Floor – In Auditorium	12/24/14	< 1		
DES-1224-52B	Drew ES	1st Floor – In Auditorium	12/24/14	< 1		
DES-1224-53A	Drew ES	1st Floor – In Auditorium	12/24/14	< 1		
DES-1224-54B	Drew ES	1st Floor – In Auditorium	12/24/14	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
DHS-0210-1A	Dunbar HS	4th floor hallway between Men's and Women's Rooms (high)	2/10/15	< 1		
DHS-0210-1B	Dunbar HS	4th floor hallway between Men's and Women's Rooms (high)	2/10/15	< 1		
DHS-0210-2A	Dunbar HS	4th floor hallway between Men's and Women's Rooms (low)	2/10/15	< 1		
DHS-0210-2B	Dunbar HS	4th floor hallway between Men's and Women's Rooms (low)	2/10/15	< 1		
DHS-0210-3A	Dunbar HS	3rd floor hallway between Men's and Women's Rooms (high)	2/10/15	< 1		
DHS-0210-3B	Dunbar HS	3rd floor hallway between Men's and Women's Rooms (high)	2/10/15	< 1		
DHS-0210-4A	Dunbar HS	3rd floor hallway between Men's and Women's Rooms (low)	2/10/15	< 1		
DHS-0210-4B	Dunbar HS	3rd floor hallway between Men's and Women's Rooms (low)	2/10/15	< 1		
DHS-0210-5A	Dunbar HS	2nd floor hallway between Men's and Women's Rooms (high)	2/10/15	< 1		
DHS-0210-5B	Dunbar HS	2nd floor hallway between Men's and Women's Rooms (high)	2/10/15	< 1		
DHS-0210-6A	Dunbar HS	2nd floor hallway between Men's and Women's Rooms (low)	2/10/15	< 1		
DHS-0210-6B	Dunbar HS	2nd floor hallway between Men's and Women's Rooms (low)	2/10/15	< 1		
DHS-0210-7A	Dunbar HS	2nd floor hallway adjacent to Women's Room 270W (high)	2/10/15	< 1		

DHS-0210-7B	Dunbar HS	2nd floor hallway adjacent to Women's Room 270W (high)	2/10/15	< 1		
DHS-0210-8A	Dunbar HS	2nd floor hallway adjacent to Women's Room 270W (low)	2/10/15	< 1		
DHS-0210-8B	Dunbar HS	2nd floor hallway adjacent to Women's Room 270W (low)	2/10/15	< 1		
DHS-0210-9A	Dunbar HS	1st floor hallway adjacent to Women's Room 170W (high)	2/10/15	< 1		
DHS-0210-9B	Dunbar HS	1st floor hallway adjacent to Women's Room 170W (high)	2/10/15	< 1		
DHS-0210-10A	Dunbar HS	1st floor hallway adjacent to Women's Room 170W (low)	2/10/15	< 1		
DHS-0210-10B	Dunbar HS	1st floor hallway adjacent to Women's Room 170W (low)	2/10/15	< 1		
DHS-0210-11A	Dunbar HS	1st floor hallway between Men's and Women's Rooms (high)	2/10/15	< 1		
DHS-0210-11B	Dunbar HS	1st floor hallway between Men's and Women's Rooms (high)	2/10/15	< 1		
DHS-0210-12A	Dunbar HS	1st floor hallway between Men's and Women's Rooms (low)	2/10/15	< 1		
DHS-0210-12B	Dunbar HS	1st floor hallway between Men's and Women's Rooms (low)	2/10/15	< 1		
DHS-0210-13A	Dunbar HS	Basement floor hallway adjacent to Pool Room 060 (high)	2/10/15	< 1		
DHS-0210-13B	Dunbar HS	Basement floor hallway adjacent to Pool Room 060 (high)	2/10/15	< 1		
DHS-0210-14A	Dunbar HS	Basement floor hallway adjacent to Pool Room 060 (low)	2/10/15	< 1		
DHS-0210-14B	Dunbar HS	Basement floor hallway adjacent to Pool Room 060 (low)	2/10/15	< 1		
DHS-0210-15A	Dunbar HS	1st floor inside Gym (high)	2/10/15	< 1		
DHS-0210-15B	Dunbar HS	1st floor inside Gym (high)	2/10/15	< 1		
DHS-0210-16A	Dunbar HS	1st floor inside Gym (low)	2/10/15	< 1		
DHS-0210-16B	Dunbar HS	1st floor inside Gym (low)	2/10/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
DE-1211-1A	Duke Ellington@Garnet Patterson	2nd floor hallway between men's and women's room	12/11/14	< 1		
DE-1211-2B	Duke Ellington@Garnet Patterson	2nd floor hallway between men's and women's room	12/11/14	< 1		
DE-1211-3A	Duke Ellington@Garnet Patterson	1st floor hallway adjacent to room 143	12/11/14	< 1		
DE-1211-4B	Duke Ellington@Garnet Patterson	1st floor hallway adjacent to room 143	12/11/14	< 1		
DE-1211-5A	Duke Ellington@Garnet Patterson	1st floor hallway across from Cafeteria	12/11/14	< 1		
DE-1211-6B	Duke Ellington@Garnet Patterson	1st floor hallway across from Cafeteria	12/11/14	< 1		
DE-1211-7A	Duke Ellington@Garnet Patterson	In B flat building, adjacent to staff restroom	12/11/14	< 1		
DE-1211-8B	Duke Ellington@Garnet Patterson	In B flat building, adjacent to staff restroom	12/11/14	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
EHS-0205-1A	Eastern HS	4th floor hallway across from Classroom E415 (high)	2/5/15	< 1		
EHS-0205-1B	Eastern HS	4th floor hallway across from Classroom E415 (high)	2/5/15	< 1		
EHS-0205-2A	Eastern HS	4th floor hallway across from Classroom E415 (low)	2/5/15	< 1		
EHS-0205-2B	Eastern HS	4th floor hallway across from Classroom E415 (low)	2/5/15	< 1		
EHS-0205-3A	Eastern HS	3rd floor hallway across from Classroom W311 (high)	2/5/15	< 1		
EHS-0205-3B	Eastern HS	3rd floor hallway across from Classroom W311 (high)	2/5/15	< 1		
EHS-0205-4A	Eastern HS	3rd floor hallway across from Classroom W311 (low)	2/5/15	< 1		
EHS-0205-4B	Eastern HS	3rd floor hallway across from Classroom W311 (low)	2/5/15	< 1		
EHS-0205-5A	Eastern HS	3rd floor hallway across from Classroom E316 (high)	2/5/15	< 1		
EHS-0205-5B	Eastern HS	3rd floor hallway across from Classroom E316 (high)	2/5/15	< 1		
EHS-0205-6A	Eastern HS	3rd floor hallway across from Classroom E316 (low)	2/5/15	< 1		
EHS-0205-6B	Eastern HS	3rd floor hallway across from Classroom E316 (low)	2/5/15	< 1		
EHS-0205-7A	Eastern HS	2nd floor hallway across from Classroom W212 (high)	2/5/15	< 1		
EHS-0205-7B	Eastern HS	2nd floor hallway across from Classroom W212 (high)	2/5/15	< 1		
EHS-0205-8A	Eastern HS	2nd floor hallway across from Classroom W212 (low)	2/5/15	< 1		
EHS-0205-8B	Eastern HS	2nd floor hallway across from Classroom W212 (low)	2/5/15	< 1		

EHS-0205-9A	Eastern HS	2nd floor hallway across from Classroom E218 (high)	2/5/15	< 1		
EHS-0205-9B	Eastern HS	2nd floor hallway across from Classroom E218 (high)	2/5/15	< 1		
EHS-0205-10A	Eastern HS	2nd floor hallway across from Classroom E218 (low)	2/5/15	< 1		
EHS-0205-10B	Eastern HS	2nd floor hallway across from Classroom E218 (low)	2/5/15	< 1		
EHS-0205-11A	Eastern HS	1st floor hallway across from Gym (high)	2/5/15	< 1		
EHS-0205-11B	Eastern HS	1st floor hallway across from Gym (high)	2/5/15	< 1		
EHS-0205-12A	Eastern HS	1st floor hallway across from Gym (low)	2/5/15	< 1		
EHS-0205-12B	Eastern HS	1st floor hallway across from Gym (low)	2/5/15	< 1		
EHS-0205-13A	Eastern HS	1st floor hallway across from Health Clinic W130 (high)	2/5/15	< 1		
EHS-0205-13B	Eastern HS	1st floor hallway across from Health Clinic W130 (high)	2/5/15	< 1		
EHS-0205-14A	Eastern HS	1st floor hallway across from Health Clinic W130 (low)	2/5/15	< 1		
EHS-0205-14B	Eastern HS	1st floor hallway across from Health Clinic W130 (low)	2/5/15	< 1		
EHS-0205-15A	Eastern HS	Basement floor inside Cafeteria (high)	2/5/15	< 1		
EHS-020515B	Eastern HS	Basement floor inside Cafeteria (high)	2/5/15	< 1		
EHS-0205-16A	Eastern HS	Basement floor inside Cafeteria (low)	2/5/15	< 1		
EHS-0205-16B	Eastern HS	Basement floor inside Cafeteria (low)	2/5/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
EES W 0518-1A	Eaton ES	3rd Floor hallway	5/18/15	< 1		
EES W 0518-1B	Eaton ES	3rd Floor hallway	5/18/15	< 1		
EES W 0518-2A	Eaton ES	2nd Floor hallway	5/18/15	< 1		
EES W 0518-2B	Eaton ES	2nd Floor hallway	5/18/15	< 1		
EES W 0518-3A	Eaton ES	2nd Floor inside class room 209B	5/18/15	< 1		
EES W 0518-3B	Eaton ES	2nd Floor inside class room 209B	5/18/15	< 1		
EES W 0518-4A	Eaton ES	1st Floor inside office 102D	5/18/15	< 1		
EES W 0518-4B	Eaton ES	1st Floor inside office 102D	5/18/15	< 1		
EES 0518-5A	Eaton ES	1st Floor hallway at main entrance (High)	5/18/15	< 1		
EES 0518-5B	Eaton ES	1st Floor hallway at main entrance (High)	5/18/15	< 1		
EES-0518-6A	Eaton ES	1st Floor hallway at main entrance (low)	5/18/15	< 1		
EES-0518-6B	Eaton ES	1st Floor hallway at main entrance (low)	5/18/15	< 1		
EES E 0518-7A	Eaton ES	3rd Floor hallway adjacent to classroom 313	5/18/15	< 1		
EES E 0518-7B	Eaton ES	3rd Floor hallway adjacent to classroom 313	5/18/15	< 1		
EES E 0518-8A	Eaton ES	2nd Floor hallway adjacent to classroom 218	5/18/15	< 1		
EES E 0518-8B	Eaton ES	2nd Floor hallway adjacent to classroom 218	5/18/15	< 1		
EES E 0518-9A	Eaton ES	1st Floor hallway adjacent to classroom 119	5/18/15	< 1		
EES E 0518-9B	Eaton ES	1st Floor hallway adjacent to classroom 119	5/18/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
EH-0128-1A	Eliot-Hine MS	3rd floor hallway adjacent to Classroom 3-266	1/28/15	< 1		
EH-0128-1B	Eliot-Hine MS	3rd floor hallway adjacent to Classroom 3-266	1/28/15	< 1		
EH-0128-2A	Eliot-Hine MS	3rd floor hallway adjacent to Classroom 3-262	1/28/15	< 1		
EH-0128-2B	Eliot-Hine MS	3rd floor hallway adjacent to Classroom 3-262	1/28/15	< 1		
EH-0128-3A	Eliot-Hine MS	3rd floor hallway adjacent to Staff Resource Room 3-255	1/28/15	< 1		
EH-0128-3B	Eliot-Hine MS	3rd floor hallway adjacent to Staff Resource Room 3-255	1/28/15	< 1		
EH-0128-4A	Eliot-Hine MS	2nd floor hallway adjacent to Computer Lab 2-198	1/28/15	< 1		
EH-0128-4B	Eliot-Hine MS	2nd floor hallway adjacent to Computer Lab 2-198	1/28/15	< 1		
EH-0128-5A	Eliot-Hine MS	2nd floor hallway adjacent to Classroom 2-210	1/28/15	< 1		
EH-0128-5B	Eliot-Hine MS	2nd floor hallway adjacent to Classroom 2-210	1/28/15	< 1		
EH-0128-6A	Eliot-Hine MS	1st floor hallway adjacent to Office 1-152	1/28/15	< 1		
EH-0128-6B	Eliot-Hine MS	1st floor hallway adjacent to Office 1-152	1/28/15	< 1		
EH-0128-7A	Eliot-Hine MS	1st floor hallway adjacent to Classroom 1-166	1/28/15	< 1		
EH-0128-7B	Eliot-Hine MS	1st floor hallway adjacent to Classroom 1-166	1/28/15	< 1		
EH-0128-8A	Eliot-Hine MS	1st floor hallway across from Classroom 1-077	1/28/15	< 1		
EH-0128-8B	Eliot-Hine MS	1st floor hallway across from Classroom 1-077	1/28/15	< 1		
EH-0128-9A	Eliot-Hine MS	1st floor hallway adjacent to Classroom 1-070	1/28/15	< 1		



FS-0128-5A	Francis - Stevens EC	1st Floor inside classroom 101	1/28/15	< 1		
FS-0128-5B	Francis - Stevens EC	1st Floor inside classroom 101	1/28/15	< 1		
FS-0128-6A	Francis - Stevens EC	1st Floor inside classroom 102	1/28/15	< 1		
FS-0128-6B	Francis - Stevens EC	1st Floor inside classroom 102	1/28/15	< 1		
FS-0128-7A	Francis - Stevens EC	1st Floor inside classroom 103	1/28/15	< 1		
FS-0128-7B	Francis - Stevens EC	1st Floor inside classroom 103	1/28/15	< 1		
FS-0128-8A	Francis - Stevens EC	1st Floor hallway adjacent to Library	1/28/15	< 1		
FS-0128-8B	Francis - Stevens EC	1st Floor hallway adjacent to Library	1/28/15	< 1		
FS-0128-9A	Francis - Stevens EC	1st Floor inside cafeteria	1/28/15	< 1		
FS-0128-9B	Francis - Stevens EC	1st Floor inside cafeteria	1/28/15	< 1		
FS-0128-10A	Francis - Stevens EC	1st Floor hallway adjacent to office	1/28/15	< 1		
FS-0128-10B	Francis - Stevens EC	1st Floor hallway adjacent to office	1/28/15	< 1		
FS-0128-11A	Francis - Stevens EC	1st Floor inside classroom 109	1/28/15	< 1		
FS-0128-11B	Francis - Stevens EC	1st Floor inside classroom 109	1/28/15	< 1		
FS-0128-12A	Francis - Stevens EC	1st Floor inside classroom 110	1/28/15	< 1		
FS-0128-12B	Francis - Stevens EC	1st Floor inside classroom 110	1/28/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
GES-0107-1A	Garfield ES	2nd floor hallway across from Room 206 Social Worker	1/7/15	< 1		
GES-0107-2B	Garfield ES	2nd floor hallway across from Room 206 Social Worker	1/7/15	< 1		
GES-0107-3A	Garfield ES	2nd floor hallway across from Room 203 School Psychologist	1/7/15	< 1		
GES-0107-4B	Garfield ES	2nd floor hallway across from Room 203 School Psychologist	1/7/15	< 1		
GES-0107-5A	Garfield ES	2nd floor hallway adjacent to Room 210 Teacher's Lounge	1/7/15	< 1		
GES-0107-6B	Garfield ES	2nd floor hallway adjacent to Room 210 Teacher's Lounge	1/7/15	< 1		
GES-0107-7A	Garfield ES	2nd floor hallway near Classroom 214	1/7/15	< 1		
GES-0107-8B	Garfield ES	2nd floor hallway near Classroom 214	1/7/15	< 1		
GES-0107-9A	Garfield ES	1st floor hallway near Classroom 112	1/7/15	< 1		
GES-0107-10B	Garfield ES	1st floor hallway near Classroom 112	1/7/15	< 1		
GES-0107-11A	Garfield ES	1st floor inside Classroom 111	1/7/15	< 1		
GES-0107-12B	Garfield ES	1st floor inside Classroom 111	1/7/15	< 1		
GES-0224-13A	Garfield ES	1st floor hallway across from Girl's Restroom	1/7/15	< 1		
GES-0107-14B	Garfield ES	1st floor hallway across from Girl's Restroom	1/7/15	< 1		
GES-0107-15A	Garfield ES	1st floor inside Classroom 110	1/7/15	< 1		
GES-0107-16B	Garfield ES	1st floor inside Classroom 110	1/7/15	< 1		
GES-0107-17A	Garfield ES	Basement floor inside Cafeteria adjacent to Kitchen	1/7/15	< 1		
GES-0107-18B	Garfield ES	Basement floor inside Cafeteria adjacent to Kitchen	1/7/15	< 1		
GES-0107-19A	Garfield ES	Basement floor inside Cafeteria near entrance	1/7/15	< 1		
GES-0107-20B	Garfield ES	Basement floor inside Cafeteria near entrance	1/7/15	< 1		
GES-0107-21A	Garfield ES	1st floor hallway adjacent to Main Office	1/7/15	< 1		
GES-0107-22B	Garfield ES	1st floor hallway adjacent to Main Office	1/7/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
GP-1223-1A	Garnet-Patterson MS	3rd floor hallway adjacent to Classroom 312	12/23/14	< 1		
GP-1223-2B	Garnet-Patterson MS	3rd floor hallway adjacent to Classroom 312	12/23/14	< 1		
GP-1223-3A	Garnet-Patterson MS	3rd floor hallway adjacent to Classroom 305	12/23/14	< 1		
GP-1223-4B	Garnet-Patterson MS	3rd floor hallway adjacent to Classroom 305	12/23/14	< 1		
GP-1223-5A	Garnet-Patterson MS	2nd floor hallway adjacent to Classroom 217	12/23/14	< 1		
GP-1223-6B	Garnet-Patterson MS	2nd floor hallway adjacent to Classroom 217	12/23/14	< 1		
GP-1223-7A	Garnet-Patterson MS	2nd floor hallway adjacent to Classroom 214	12/23/14	< 1		
GP-1223-8B	Garnet-Patterson MS	2nd floor hallway adjacent to Classroom 214	12/23/14	< 1		
GP-1223-9A	Garnet-Patterson MS	1st floor hallway adjacent to Classroom 112	12/23/14	< 1		
GP-1223-10B	Garnet-Patterson MS	1st floor hallway adjacent to Classroom 112	12/23/14	< 1		
GP-1223-11A	Garnet-Patterson MS	1st floor hallway between Girl's and Boy's Locker Room	12/23/14	< 1		
GP-1223-12B	Garnet-Patterson MS	1st floor hallway between Girl's and Boy's Locker Room	12/23/14	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>

			Percentage of Failed Samples			0.00%
GES-0821-1A	Garrison ES	First Floor Hallway Adjacent to General Office	8/21/15	< 1		
GES-0821-1B	Garrison ES	First Floor Hallway Adjacent to General Office	8/21/15	< 1		
GES-0821-2A	Garrison ES	First Floor Hallway Across Rm 108	8/21/15	< 1		
GES-0821-2B	Garrison ES	First Floor Hallway Across Rm 108	8/21/15	< 1		
GES-0821-3A	Garrison ES	First Floor inside Rm 109	8/21/15	< 1		
GES-0821-3B	Garrison ES	First Floor inside Rm 109	8/21/15	< 1		
GES-0821-4A	Garrison ES	First Floor inside Rm 110	8/21/15	< 1		
GES-0821-4B	Garrison ES	First Floor inside Rm 110	8/21/15	< 1		
GES-0821-5A	Garrison ES	Second Floor Hallway Across Rm 207	8/21/15	< 1		
GES-0821-5B	Garrison ES	Second Floor Hallway Across Rm 207	8/21/15	< 1		
GES-0821-6A	Garrison ES	Second Floor Hallway Across Rm 211	8/21/15	< 1		
GES-0821-6B	Garrison ES	Second Floor Hallway Across Rm 211	8/21/15	< 1		
GES-0821-7A	Garrison ES	Second Floor inside Health Suite	8/21/15	< 1		
GES-0821-7B	Garrison ES	Second Floor inside Health Suite	8/21/15	< 1		
GES-0821-8A	Garrison ES	Second Floor inside Cafeteria	8/21/15	< 1		
GES-0821-8B	Garrison ES	Second Floor inside Cafeteria	8/21/15	< 1		
GES-0821-9A	Garrison ES	Second Floor Hallway Adjacent to Rm 212	8/21/15	< 1		
GES-0821-9B	Garrison ES	Second Floor Hallway Adjacent to Rm 212	8/21/15	< 1		
GES-0821-10A	Garrison ES	Second Floor Hallway Adjacent to Rm 217	8/21/15	< 1		
GES-0821-10B	Garrison ES	Second Floor Hallway Adjacent to Rm 217	8/21/15	< 1		
GES-0821-11A	Garrison ES	First Floor Hallway Across Rm 123	8/21/15	< 1		
GES-0821-11B	Garrison ES	First Floor Hallway Across Rm 123	8/21/15	< 1		
GES-0821-12A	Garrison ES	First Floor Hallway Across Rm 128	8/21/15	< 1		
GES-0821-12B	Garrison ES	First Floor Hallway Across Rm 128	8/21/15	< 1		
			Percentage of Passed Samples			100.00%
			Percentage of Failed Samples			0.00%
HDC-0501-1A	H.D. Cooke ES	3rd floor hallway adjacent to Girl's RR (high)	5/1/15	< 1		
HDC-0501-1B	H.D. Cooke ES	3rd floor hallway adjacent to Girl's RR (high)	5/1/15	< 1		
HDC-0501-2A	H.D. Cooke ES	3rd floor hallway adjacent to Girl's RR (low)	5/1/15	< 1		
HDC-0501-2B	H.D. Cooke ES	3rd floor hallway adjacent to Girl's RR (low)	5/1/15	< 1		
HDC-0501-3A	H.D. Cooke ES	3rd floor inside Classroom 302	5/1/15	< 1		
HDC-0501-3B	H.D. Cooke ES	3rd floor inside Classroom 302	5/1/15	< 1		
HDC-0501-4A	H.D. Cooke ES	3rd floor inside Classroom 303	5/1/15	< 1		
HDC-0501-4B	H.D. Cooke ES	3rd floor inside Classroom 303	5/1/15	< 1		
HDC-0501-5A	H.D. Cooke ES	3rd floor inside Classroom 304	5/1/15	< 1		
HDC-0501-5B	H.D. Cooke ES	3rd floor inside Classroom 304	5/1/15	< 1		
HDC-0501-6A	H.D. Cooke ES	3rd floor inside Classroom 305	5/1/15	< 1		
HDC-0501-6B	H.D. Cooke ES	3rd floor inside Classroom 305	5/1/15	< 1		
HDC-0501-7A	H.D. Cooke ES	3rd floor inside Classroom 310	5/1/15	< 1		
HDC-0501-7B	H.D. Cooke ES	3rd floor inside Classroom 310	5/1/15	< 1		
HDC-0501-8A	H.D. Cooke ES	3rd floor inside Classroom 311	5/1/15	< 1		
HDC-0501-8B	H.D. Cooke ES	3rd floor inside Classroom 311	5/1/15	< 1		
HDC-0501-9A	H.D. Cooke ES	3rd floor inside Classroom 312	5/1/15	< 1		
HDC-0501-9B	H.D. Cooke ES	3rd floor inside Classroom 312	5/1/15	< 1		
HDC-0501-10A	H.D. Cooke ES	2nd floor inside Classroom 314	5/1/15	< 1		
HDC-0501-10B	H.D. Cooke ES	2nd floor inside Classroom 314	5/1/15	< 1		
HDC-0501-11A	H.D. Cooke ES	2nd floor inside Classroom 221	5/1/15	< 1		
HDC-0501-11B	H.D. Cooke ES	2nd floor inside Classroom 221	5/1/15	< 1		
HDC-0501-12A	H.D. Cooke ES	2nd floor inside Classroom 230	5/1/15	1.1		
HDC-0501-12B	H.D. Cooke ES	2nd floor inside Classroom 230	5/1/15	< 1		
HDC-0501-13A	H.D. Cooke ES	2nd floor inside Classroom 236	5/1/15	3.5		
HDC-0501-13B	H.D. Cooke ES	2nd floor inside Classroom 236	5/1/15	< 1		
HDC-0501-14A	H.D. Cooke ES	2nd floor inside Classroom 231	5/1/15	< 1		
HDC-0501-14B	H.D. Cooke ES	2nd floor inside Classroom 231	5/1/15	< 1		

HDC-0501-15A	H.D. Cooke ES	2nd floor inside Classroom 235	5/1/15	< 1		
HDC-0501-15B	H.D. Cooke ES	2nd floor inside Classroom 235	5/1/15	< 1		
HDC-0501-16A	H.D. Cooke ES	2nd floor inside Classroom 232	5/1/15	< 1		
HDC-0501-16B	H.D. Cooke ES	2nd floor inside Classroom 232	5/1/15	< 1		
HDC-0501-17A	H.D. Cooke ES	2nd floor inside Classroom 234	5/1/15	< 1		
HDC-0501-17B	H.D. Cooke ES	2nd floor inside Classroom 234	5/1/15	< 1		
HDC-0501-18A	H.D. Cooke ES	2nd floor inside Classroom 202	5/1/15	2.7		
HDC-0501-18B	H.D. Cooke ES	2nd floor inside Classroom 202	5/1/15	< 1		
HDC-0501-19A	H.D. Cooke ES	2nd floor inside Classroom 203	5/1/15	< 1		
HDC-0501-19B	H.D. Cooke ES	2nd floor inside Classroom 203	5/1/15	< 1		
HDC-0501-20A	H.D. Cooke ES	2nd floor inside Classroom 204	5/1/15	< 1		
HDC-0501-20B	H.D. Cooke ES	2nd floor inside Classroom 204	5/1/15	< 1		
HDC-0501-21A	H.D. Cooke ES	2nd floor inside Classroom 205	5/1/15	< 1		
HDC-0501-21B	H.D. Cooke ES	2nd floor inside Classroom 205	5/1/15	< 1		
HDC-0501-22A	H.D. Cooke ES	2nd floor hallway adjacent to Girl's RR (high)	5/1/15	< 1		
HDC-0501-22B	H.D. Cooke ES	2nd floor hallway adjacent to Girl's RR (high)	5/1/15	< 1		
HDC-0501-23A	H.D. Cooke ES	2nd floor hallway adjacent to Girl's RR (low)	5/1/15	< 1		
HDC-0501-23B	H.D. Cooke ES	2nd floor hallway adjacent to Girl's RR (low)	5/1/15	< 1		
HDC-0501-24A	H.D. Cooke ES	2nd floor inside Resource Room 241	5/1/15	7.4		
HDC-0501-24B	H.D. Cooke ES	2nd floor inside Resource Room 241	5/1/15	2.3		
HDC-0501-25A	H.D. Cooke ES	2nd floor inside Classroom 213	5/1/15	< 1		
HDC-0501-25B	H.D. Cooke ES	2nd floor inside Classroom 213	5/1/15	< 1		
HDC-0501-26A	H.D. Cooke ES	2nd floor inside Classroom 212	5/1/15	< 1		
HDC-0501-26B	H.D. Cooke ES	2nd floor inside Classroom 212	5/1/15	< 1		
HDC-0501-27A	H.D. Cooke ES	2nd floor inside Classroom 210	5/1/15	< 1		
HDC-0501-27B	H.D. Cooke ES	2nd floor inside Classroom 210	5/1/15	< 1		
HDC-0501-28A	H.D. Cooke ES	2nd floor inside Classroom 211	5/1/15	< 1		
HDC-0501-28B	H.D. Cooke ES	2nd floor inside Classroom 211	5/1/15	< 1		
HDC-0501-29A	H.D. Cooke ES	1st floor inside Gym (high)	5/1/15	< 1		
HDC-0501-29B	H.D. Cooke ES	1st floor inside Gym (high)	5/1/15	< 1		
HDC-0501-30A	H.D. Cooke ES	1st floor inside Gym (low)	5/1/15	< 1		
HDC-0501-30B	H.D. Cooke ES	1st floor inside Gym (low)	5/1/15	< 1		
HDC-0501-31A	H.D. Cooke ES	1st floor inside Classroom 132	5/1/15	< 1		
HDC-0501-31B	H.D. Cooke ES	1st floor inside Classroom 132	5/1/15	< 1		
HDC-0501-32A	H.D. Cooke ES	1st floor inside Classroom 136	5/1/15	< 1		
HDC-0501-32B	H.D. Cooke ES	1st floor inside Classroom 136	5/1/15	< 1		
HDC-0501-33A	H.D. Cooke ES	1st floor inside Classroom 133	5/1/15	< 1		
HDC-0501-33B	H.D. Cooke ES	1st floor inside Classroom 133	5/1/15	< 1		
HDC-0501-34A	H.D. Cooke ES	1st floor inside Classroom 135	5/1/15	< 1		
HDC-0501-34B	H.D. Cooke ES	1st floor inside Classroom 135	5/1/15	< 1		
HDC-0501-35A	H.D. Cooke ES	1st floor hallway adjacent to Girl's RR (high)	5/1/15	< 1		
HDC-0501-35B	H.D. Cooke ES	1st floor hallway adjacent to Girl's RR (high)	5/1/15	< 1		
HDC-0501-36A	H.D. Cooke ES	1st floor hallway adjacent to Girl's RR (low)	5/1/15	< 1		
HDC-0501-36B	H.D. Cooke ES	1st floor hallway adjacent to Girl's RR (low)	5/1/15	< 1		
				<b>Percentage of Passed Samples</b>		<b>100.00%</b>
				<b>Percentage of Failed Samples</b>		<b>0.00%</b>
HMS-0209-1A	Hardy MS	3rd floor hallway across from Classroom 313 (high)	2/9/15	< 1		
HMS-0209-1B	Hardy MS	3rd floor hallway across from Classroom 313 (high)	2/9/15	< 1		
HMS-0209-2A	Hardy MS	3rd floor hallway across from Classroom 313 (low)	2/9/15	< 1		
HMS-0209-2B	Hardy MS	3rd floor hallway across from Classroom 313 (low)	2/9/15	< 1		
HMS-0209-3A	Hardy MS	3rd floor hallway across from Band Room 302 (low)	2/9/15	< 1		
HMS-0209-3B	Hardy MS	3rd floor hallway across from Band Room 302 (low)	2/9/15	< 1		
HMS-0209-4A	Hardy MS	2nd floor hallway across from Production Center 205 (high)	2/9/15	< 1		
HMS-0209-4B	Hardy MS	2nd floor hallway across from Production Center 205 (high)	2/9/15	< 1		
HMS-0209-5A	Hardy MS	2nd floor hallway across from Production Center 205 (low)	2/9/15	< 1		

HMS-0209-5B	Hardy MS	2nd floor hallway across from Production Center 205 (low)	2/9/15	< 1		
HMS-0209-6A	Hardy MS	2nd floor hallway inside Gym (high)	2/9/15	< 1		
HMS-0209-6B	Hardy MS	2nd floor hallway inside Gym (high)	2/9/15	< 1		
HMS-0209-7A	Hardy MS	2nd floor hallway inside Gym (low)	2/9/15	< 1		
HMS-0209-7B	Hardy MS	2nd floor hallway inside Gym (low)	2/9/15	< 1		
HMS-0209-8A	Hardy MS	2nd floor hallway across from Computer Lab 212 (high)	2/9/15	< 1		
HMS-0209-8B	Hardy MS	2nd floor hallway across from Computer Lab 212 (high)	2/9/15	< 1		
HMS-0209-9A	Hardy MS	2nd floor hallway across from Computer Lab 212 (low)	2/9/15	< 1		
HMS-0209-9B	Hardy MS	2nd floor hallway across from Computer Lab 212 (low)	2/9/15	< 1		
HMS-0209-10A	Hardy MS	1st floor hallway across from Computer Lab 119 (high)	2/9/15	< 1		
HMS-0209-10B	Hardy MS	1st floor hallway across from Computer Lab 119 (high)	2/9/15	< 1		
HMS-0209-11A	Hardy MS	1st floor hallway across from Computer Lab 119 (low)	2/9/15	< 1		
HMS-0209-11B	Hardy MS	1st floor hallway across from Computer Lab 119 (low)	2/9/15	< 1		
HMS-0209-12A	Hardy MS	1st floor inside Cafeteria (high)	2/9/15	< 1		
HMS-0209-12B	Hardy MS	1st floor inside Cafeteria (high)	2/9/15	< 1		
HMS-0209-13A	Hardy MS	1st floor inside Cafeteria (low)	2/9/15	< 1		
HMS-0209-13B	Hardy MS	1st floor inside Cafeteria (low)	2/9/15	< 1		
HMS-0209-14A	Hardy MS	1st floor hallway across from Classroom 102 (high)	2/9/15	< 1		
HMS-0209-14B	Hardy MS	1st floor hallway across from Classroom 102 (high)	2/9/15	< 1		
HMS-0209-15A	Hardy MS	1st floor hallway across from Classroom 102 (low)	2/9/15	< 1		
HMS-0209-15B	Hardy MS	1st floor hallway across from Classroom 102 (low)	2/9/15	< 1		
					<b>Percentage of Passed Samples</b>	<b>100.00%</b>
					<b>Percentage of Failed Samples</b>	<b>0.00%</b>
HMS-0501-1A	Hart MS	3rd Floor hallway across class room 306	5/1/15	< 1		
HMS-0501-1B	Hart MS	3rd Floor hallway across class room 306	5/1/15	< 1		
HMS-0501-2A	Hart MS	3rd Floor hallway adjacent to room 321 (high)	5/1/15	< 1		
HMS-0501-2B	Hart MS	3rd Floor hallway adjacent to room 321 (high)	5/1/15	< 1		
HMS-0501-3A	Hart MS	3rd Floor hallway adjacent to room 321 (low)	5/1/15	< 1		
HMS-0501-3B	Hart MS	3rd Floor hallway adjacent to room 321 (low)	5/1/15	< 1		
HMS-0501-4A	Hart MS	2nd Floor Hallway across class room 244 ( high)	5/1/15	< 1		
HMS-0501-4B	Hart MS	2nd Floor Hallway across class room 244 ( high)	5/1/15	< 1		
HMS-0501-5A	Hart MS	2nd Floor Hallway across class room 244 (low)	5/1/15	< 1		
HMS-0501-5B	Hart MS	2nd Floor Hallway across class room 244 ( low)	5/1/15	< 1		
HMS-0501-6A	Hart MS	2nd Floor hallway adjacent to class room 232 (high)	5/1/15	< 1		
HMS-0501-6B	Hart MS	2nd Floor hallway adjacent to class room 232 (high)	5/1/15	< 1		
HMS-0501-7A	Hart MS	2nd Floor hallway adjacent to class room 232 (low)	5/1/15	< 1		
HMS-0501-7B	Hart MS	2nd Floor hallway adjacent to class room 232 (low)	5/1/15	< 1		
HMS-0501-8A	Hart MS	2nd Floor hallway adjacent to class room 226 (high)	5/1/15	< 1		
HMS-0501-8B	Hart MS	2nd Floor hallway adjacent to class room 226 (high)	5/1/15	< 1		
HMS-0501-9A	Hart MS	2nd Floor hallway adjacent to class room 226 (low)	5/1/15	< 1		
HMS-0501-9B	Hart MS	2nd Floor hallway adjacent to class room 226 (low)	5/1/15	< 1		
HMS-0501-10A	Hart MS	2nd Floor hallway adjacent to class room 206 (high)	5/1/15	< 1		
HMS-0501-10B	Hart MS	2nd Floor hallway adjacent to class room 206 (high)	5/1/15	< 1		
HMS-0501-11A	Hart MS	2nd Floor hallway adjacent to class room 206 (low)	5/1/15	< 1		
HMS-0501-11B	Hart MS	2nd Floor hallway adjacent to class room 206 (low)	5/1/15	< 1		
HMS-0501-12A	Hart MS	1st Floor hallway adjacent to class room 119	5/1/15	< 1		
HMS-0501-12B	Hart MS	1st Floor hallway adjacent to class room 119	5/1/15	< 1		
HMS-0501-13A	Hart MS	1st Floor hallway adjacent to class room 131 (high)	5/1/15	< 1		
HMS-0501-13B	Hart MS	1st Floor hallway adjacent to class room 131(high)	5/1/15	< 1		
HMS-0501-14A	Hart MS	1st Floor hallway adjacent to class room 131(low)	5/1/15	< 1		
HMS-0501-14B	Hart MS	1st Floor hallway adjacent to class room 131(low)	5/1/15	< 1		
HMS-0501-15A	Hart MS	1st Floor hallway adjacent to class room 123(high)	5/1/15	< 1		
HMS-0501-15B	Hart MS	1st Floor hallway adjacent to class room 123(high)	5/1/15	< 1		
HMS-0501-16A	Hart MS	1st Floor hallway adjacent to class room 123(low)	5/1/15	< 1		
HMS-0501-16B	Hart MS	1st Floor hallway adjacent to class room 123(low)	5/1/15	< 1		

HMS-0501-17A	Hart MS	Basement Floor hallway adjacent to room 023 (high)	5/1/15	< 1		
HMS-0501-17B	Hart MS	Basement Floor hallway adjacent to room 023 (high)	5/1/15	< 1		
HMS-0501-18A	Hart MS	Basement Floor hallway adjacent to room 023 (low)	5/1/15	< 1		
HMS-0501-18B	Hart MS	Basement Floor hallway adjacent to room 023 (low)	5/1/15	< 1		
HMS-0501-19A	Hart MS	Basement Floor cafeteria	5/1/15	< 1		
HMS-0501-19B	Hart MS	Basement Floor cafeteria	5/1/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
HES-0224-1A	Hearst ES	2nd floor hallway between Boy's and Girl's room (high)	2/24/15	< 1		
HES-0224-1B	Hearst ES	2nd floor hallway between Boy's and Girl's room (high)	2/24/15	< 1		
HES-0224-2A	Hearst ES	2nd floor hallway between Boy's and Girl's room (low)	2/24/15	< 1		
HES-0224-2B	Hearst ES	2nd floor hallway between Boy's and Girl's room (low)	2/24/15	< 1		
HES-0224-3A	Hearst ES	2nd floor inside Classroom 219	2/24/15	< 1		
HES-0224-3B	Hearst ES	2nd floor inside Classroom 219	2/24/15	< 1		
HES-0224-4A	Hearst ES	2nd floor inside Classroom 218	2/24/15	< 1		
HES-0224-4B	Hearst ES	2nd floor inside Classroom 218	2/24/15	< 1		
HES-0224-5A	Hearst ES	2nd floor inside Classroom 210	2/24/15	< 1		
HES-0224-5B	Hearst ES	2nd floor inside Classroom 210	2/24/15	< 1		
HES-0224-6A	Hearst ES	1st floor inside Classroom 110	2/24/15	< 1		
HES-0224-6B	Hearst ES	1st floor inside Classroom 110	2/24/15	< 1		
HES-0224-7A	Hearst ES	1st floor inside Classroom 114	2/24/15	< 1		
HES-0224-7B	Hearst ES	1st floor inside Classroom 114	2/24/15	< 1		
HES-0224-8A	Hearst ES	1st floor inside Classroom 118	2/24/15	< 1		
HES-0224-8B	Hearst ES	1st floor inside Classroom 118	2/24/15	< 1		
HES-0224-9A	Hearst ES	1st floor inside Classroom 122	2/24/15	< 1		
HES-0224-9B	Hearst ES	1st floor inside Classroom 122	2/24/15	< 1		
HES-0224-10A	Hearst ES	1st floor hallway between Boy's and Girl's room (high)	2/24/15	< 1		
HES-0224-10B	Hearst ES	1st floor hallway between Boy's and Girl's room (high)	2/24/15	< 1		
HES-0224-11A	Hearst ES	1st floor hallway between Boy's and Girl's room (low)	2/24/15	< 1		
HES-0224-11B	Hearst ES	1st floor hallway between Boy's and Girl's room (low)	2/24/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
HES-0818-1A	Hendley ES	Room 107	8/18/15	1.8		
HES-0818-1B	Hendley ES	Room 107	8/18/15	< 1		
HES-0818-2A	Hendley ES	Room 108	8/18/15	1.6		
HES-0818-2B	Hendley ES	Room 108	8/18/15	< 1		
HES-0818-3A	Hendley ES	Room 110	8/18/15	2.4		
HES-0818-3B	Hendley ES	Room 110	8/18/15	< 1		
HES-0818-4A	Hendley ES	Hall way Adjacent to 109	8/18/15	< 1		
HES-0818-4B	Hendley ES	Hall way Adjacent to 109	8/18/15	< 1		
HES-0818-5A	Hendley ES	Basement G13	8/18/15	1.4		
HES-0818-5B	Hendley ES	Basement G13	8/18/15	< 1		
HES-0818-6A	Hendley ES	Basement G11	8/18/15	2.8		
HES-0818-6B	Hendley ES	Basement G11	8/18/15	< 1		
HES-0818-7A	Hendley ES	Hall Way Adjacent to G10	8/18/15	< 1		
HES-0818-7B	Hendley ES	Hall Way Adjacent to G10	8/18/15	< 1		
HES-0818-8A	Hendley ES	Inside Cafeteria	8/18/15	< 1		
HES-0818-8B	Hendley ES	Inside Cafeteria	8/18/15	< 1		
HES-0818-9A	Hendley ES	Inside G14	8/18/15	< 1		
HES-0818-9B	Hendley ES	Inside G14	8/18/15	< 1		
HES-0818-10A	Hendley ES	Hall way Adjacent to G15	8/18/15	< 1		
HES-0818-10B	Hendley ES	Hall way Adjacent to G15	8/18/15	< 1		
HES-0818-11A	Hendley ES	G17	8/18/15	< 1		
HES-0818-11B	Hendley ES	G17	8/18/15	< 1		
HES-0818-12A	Hendley ES	G16	8/18/15	1.7		

HES-0818-12B	Hendley ES	G16	8/18/15	< 1			
HES-0818-13A	Hendley ES	G15	8/18/15		35	Filter Installed.	
HES-0818-13B	Hendley ES	G15	8/18/15	2.1			
HES-0818-14A	Hendley ES	Across Exit Stairs 2 (High)	8/18/15	< 1			
HES-0818-14B	Hendley ES	Across Exit Stairs 2 (High)	8/18/15	< 1			
HES-0818-15A	Hendley ES	Across Exit Stairs 2 (Low)	8/18/15	< 1			
HES-0818-15B	Hendley ES	Across Exit Stairs 2 (Low)	8/18/15	< 1			
HES-0818-16A	Hendley ES	Across Exit Stairs 1 (High)	8/18/15	< 1			
HES-0818-16B	Hendley ES	Across Exit Stairs 1 (High)	8/18/15	< 1			
HES-0818-17A	Hendley ES	Across Exit Stairs 1 (Low)	8/18/15	< 1			
HES-0818-17B	Hendley ES	Across Exit Stairs 1 (Low)	8/18/15	< 1			
HES-0818-18A	Hendley ES	Across Exit Stairs 2 (High)	8/18/15	< 1			
HES-0818-18B	Hendley ES	Across Exit Stairs 2 (High)	8/18/15	< 1			
HES-0818-19A	Hendley ES	Across Exit Stairs 2 (Low)	8/18/15	< 1			
HES-0818-19B	Hendley ES	Across Exit Stairs 2 (Low)	8/18/15	< 1			
HES-0818-20A	Hendley ES	Across Exit Stairs 1 (Low)	8/18/15	< 1			
HES-0818-20B	Hendley ES	Across Exit Stairs 1 (Low)	8/18/15	< 1			
HES-0818-21A	Hendley ES	1ST Floor Hall Way Adjacent 111	8/18/15	< 1			
HES-0818-21B	Hendley ES	1ST Floor Hall Way Adjacent 111	8/18/15	< 1			
					<b>Percentage of Passed Samples</b>		<b>97.62%</b>
					<b>Percentage of Failed Samples</b>		<b>2.38%</b>
HE-0324-1A	Houston ES	2nd Floor hallway across classroom 209	3/24/15	< 1			
HE-0324-1B	Houston ES	2nd Floor hallway across classroom 209	3/24/15	< 1			
HE-0324-2A	Houston ES	2nd Floor hallway across classroom 205	3/24/15	< 1			
HE-0324-2B	Houston ES	2nd Floor hallway across classroom 205	3/24/15	< 1			
HE-0324-3A	Houston ES	1st Floor hallway across classroom 109	3/24/15	< 1			
HE-0324-3B	Houston ES	1st Floor hallway across classroom 109	3/24/15	< 1			
HE-0324-4A	Houston ES	1st Floor hallway across classroom 105	3/24/15	< 1			
HE-0324-4B	Houston ES	1st Floor hallway across classroom 105	3/24/15	< 1			
HE-0324-5A	Houston ES	1st Floor inside staff lounge	3/24/15	< 1			
HE-0324-5B	Houston ES	1st Floor inside staff lounge	3/24/15	< 1			
HE-0324-6A	Houston ES	1st floor across staff lounge	3/24/15	< 1			
HE-0324-6B	Houston ES	1st floor across staff lounge	3/24/15	< 1			
HE-0324-7A	Houston ES	1st Floor inside classroom 147	3/24/15	< 1			
HE-0324-7B	Houston ES	1st Floor inside classroom 147	3/24/15	< 1			
HE-0324-8A	Houston ES	1st Floor inside classroom 148	3/24/15	1.8			
HE-0324-8B	Houston ES	1st Floor inside classroom 148	3/24/15	< 1			
HE-0324-9A	Houston ES	1st Floor hallway adjacent to classroom 156	3/24/15	< 1			
HE-0324-9B	Houston ES	1st Floor hallway adjacent to classroom 156	3/24/15	< 1			
HE-0324-10A	Houston ES	1st Floor inside cafeteria	3/24/15	< 1			
HE-0324-10B	Houston ES	1st Floor inside cafeteria	3/24/15	< 1			
					<b>Percentage of Passed Samples</b>		<b>100.00%</b>
					<b>Percentage of Failed Samples</b>		<b>0.00%</b>
EB-0225-1A	Hyde/Addison ES	2nd Floor hallway adjacent to Janitor closet 204 (high)	2/25/15	< 1			
EB-0225-1B	Hyde/Addison ES	2nd Floor hallway adjacent to Janitor closet 204 (high)	2/25/15	< 1			
EB-0225-2A	Hyde/Addison ES	2nd Floor hallway adjacent to Janitor closet 204 (low)	2/25/15	< 1			
EB-0225-2B	Hyde/Addison ES	2nd Floor hallway adjacent to Janitor closet 204 (low)	2/25/15	< 1			
EB-0225-3A	Hyde/Addison ES	1st Floor hallway adjacent to room 113 (high)	2/25/15	< 1			
EB-0225-3B	Hyde/Addison ES	1st Floor hallway adjacent to room 113 (high)	2/25/15	< 1			
EB-0225-4A	Hyde/Addison ES	1st Floor hallway adjacent to room 113 (low)	2/25/15	< 1			
EB-0225-4B	Hyde/Addison ES	1st Floor hallway adjacent to room 113 (low)	2/25/15	< 1			
EB-0225-5A	Hyde/Addison ES	Basement floor hallway adjacent to room B03 (high)	2/25/15	< 1			
EB-0225-5B	Hyde/Addison ES	Basement floor hallway adjacent to room B03 (high)	2/25/15	< 1			
EB-0225-6A	Hyde/Addison ES	Basement floor hallway adjacent to room B03 (low)	2/25/15	< 1			
EB-0225-6B	Hyde/Addison ES	Basement floor hallway adjacent to room B03 (low)	2/25/15	< 1			



JOES-0820-16B	J.O. Wilson ES	Second Floor inside Rm 220	8/20/15	< 1		
JOES-0820-17A	J.O. Wilson ES	Second Floor inside Rm 221	8/20/15	< 1		
JOES-0820-17B	J.O. Wilson ES	Second Floor inside Rm 221	8/20/15	< 1		
JOES-0820-18A	J.O. Wilson ES	Second Floor inside Rm 221	8/20/15	< 1		
JOES-0820-18B	J.O. Wilson ES	Second Floor inside Rm 221	8/20/15	< 1		
JOES-0820-19A	J.O. Wilson ES	Second Floor inside Rm 212	8/20/15	< 1		
JOES-0820-19B	J.O. Wilson ES	Second Floor inside Rm 212	8/20/15	< 1		
JOES-0820-20A	J.O. Wilson ES	Second Floor inside Rm 222	8/20/15	< 1		
JOES-0820-20B	J.O. Wilson ES	Second Floor inside Rm 222	8/20/15	< 1		
JOES-0820-21A	J.O. Wilson ES	Second Floor Hallway Adjacent to Rm 214	8/20/15	< 1		
JOES-0820-21B	J.O. Wilson ES	Second Floor Hallway Adjacent to Rm 214	8/20/15	< 1		
JOES-0820-22A	J.O. Wilson ES	Second Floor Hallway Adjacent to Rm 208	8/20/15	< 1		
JOES-0820-22B	J.O. Wilson ES	Second Floor Hallway Adjacent to Rm 208	8/20/15	< 1		
JOES-0820-23A	J.O. Wilson ES	Second Floor Hallway Across to Rm 201	8/20/15	< 1		
JOES-0820-23B	J.O. Wilson ES	Second Floor Hallway Across to Rm 201	8/20/15	< 1		
JOES-0820-24A	J.O. Wilson ES	Third Floor Hallway Adjacent to Rm 321	8/20/15	< 1		
JOES-0820-24B	J.O. Wilson ES	Third Floor Hallway Adjacent to Rm 321	8/20/15	< 1		
JOES-0820-25A	J.O. Wilson ES	Third Floor Hallway Adjacent to Rm 329	8/20/15	< 1		
JOES-0820-25B	J.O. Wilson ES	Third Floor Hallway Adjacent to Rm 329	8/20/15	< 1		
JOES-0820-26A	J.O. Wilson ES	Third Floor Hallway Adjacent to Rm 328	8/20/15	< 1		
JOES-0820-26B	J.O. Wilson ES	Third Floor Hallway Adjacent to Rm 328	8/20/15	< 1		
JOES-0820-27A	J.O. Wilson ES	Third Floor Hallway Across to Rm 301	8/20/15	< 1		
JOES-0820-27B	J.O. Wilson ES	Third Floor Hallway Across to Rm 301	8/20/15	< 1		
JOES-0820-28A	J.O. Wilson ES	Third Floor Hallway Adjacent to Rm 308	8/20/15	< 1		
JOES-0820-28B	J.O. Wilson ES	Third Floor Hallway Adjacent to Rm 308	8/20/15	< 1		
JOES-0820-29A	J.O. Wilson ES	Third Floor Hallway Adjacent to Rm 312	8/20/15	< 1		
JOES-0820-29B	J.O. Wilson ES	Third Floor Hallway Adjacent to Rm 312	8/20/15	< 1		
JOES-0820-30A	J.O. Wilson ES	Third Floor inside Rm 322	8/20/15	< 1		
JOES-0820-30B	J.O. Wilson ES	Third Floor inside Rm 322	8/20/15	< 1		
<b>Percentage of Passed Samples</b>						<b>98.33%</b>
<b>Percentage of Failed Samples</b>						<b>1.67%</b>
JE-0309-1A	Janney ES	3rd Floor inside classroom 317	3/9/15	< 1		
JE-0309-1B	Janney ES	3rd Floor inside classroom 317	3/9/15	< 1		
JE-0309-2A	Janney ES	3rd Floor hallway across classroom 317 ( high)	3/9/15	< 1		
JE-0309-2B	Janney ES	3rd Floor hallway across classroom 317 ( high)	3/9/15	< 1		
JE-0309-3A	Janney ES	3rd Floor hallway across classroom 317 ( low)	3/9/15	< 1		
JE-0309-3B	Janney ES	3rd Floor hallway across classroom 317 ( low)	3/9/15	< 1		
JE-0309-4A	Janney ES	3rd Floor inside classroom 315	3/9/15	< 1		
JE-0309-4B	Janney ES	3rd Floor inside classroom 315	3/9/15	< 1		
JE-0309-5A	Janney ES	3rd Floor inside classroom 313	3/9/15	< 1		
JE-0309-5B	Janney ES	3rd Floor inside classroom 313	3/9/15	< 1		
JE-0309-6A	Janney ES	3rd Floor hallway adjacent to classroom 310	3/9/15	< 1		
JE-0309-6B	Janney ES	3rd Floor hallway adjacent to classroom 310	3/9/15	< 1		
JE-0309-7A	Janney ES	3rd Floor inside classroom 308	3/9/15	< 1		
JE-0309-7B	Janney ES	3rd Floor inside classroom 308	3/9/15	< 1		
JE-0309-8A	Janney ES	3rd Floor inside classroom 309	3/9/15	< 1		
JE-0309-8B	Janney ES	3rd Floor inside classroom 309	3/9/15	< 1		
JE-0309-9A	Janney ES	3rd Floor inside classroom 306	3/9/15	< 1		
JE-0309-9B	Janney ES	3rd Floor inside classroom 306	3/9/15	< 1		
JE-0309-10A	Janney ES	3rd Floor inside classroom 307	3/9/15	< 1		
JE-0309-10B	Janney ES	3rd Floor inside classroom 307	3/9/15	< 1		
JE-0309-11A	Janney ES	3rd Floor hallway adjacent to classroom 307	3/9/15	< 1		
JE-0309-11B	Janney ES	3rd Floor hallway adjacent to classroom 307	3/9/15	< 1		
JE-0309-12A	Janney ES	3rd Floor inside classroom 304	3/9/15	< 1		
JE-0309-12B	Janney ES	3rd Floor inside classroom 304	3/9/15	< 1		

JE-0309-13A	Janney ES	3rd Floor inside classroom 303	3/9/15	< 1		
JE-0309-13B	Janney ES	3rd Floor inside classroom 303	3/9/15	< 1		
JE-0309-14A	Janney ES	3rd Floor inside classroom 302	3/9/15	< 1		
JE-0309-14B	Janney ES	3rd Floor inside classroom 302	3/9/15	< 1		
JE-0309-15A	Janney ES	3rd Floor hallway adjacent to classroom 301	3/9/15	< 1		
JE-0309-15B	Janney ES	3rd Floor hallway adjacent to classroom 301	3/9/15	< 1		
JE-0309-16A	Janney ES	3rd Floor inside classroom 301	3/9/15	< 1		
JE-0309-16B	Janney ES	3rd Floor inside classroom 301	3/9/15	< 1		
JE-0309-17A	Janney ES	3rd Floor inside classroom 300	3/9/15	< 1		
JE-0309-17B	Janney ES	3rd Floor inside classroom 300	3/9/15	< 1		
JE-0309-18A	Janney ES	2nd Floor inside classroom 201	3/9/15	< 1		
JE-0309-18B	Janney ES	2nd Floor inside classroom 201	3/9/15	< 1		
JE-0309-19A	Janney ES	2nd Floor inside classroom 200	3/9/15	< 1		
JE-0309-19B	Janney ES	2nd Floor inside classroom 200	3/9/15	< 1		
JE-0309-20A	Janney ES	2nd Floor hallway adjacent to classroom 201	3/9/15	< 1		
JE-0309-20B	Janney ES	2nd Floor hallway adjacent to classroom 201	3/9/15	< 1		
JE-0309-21A	Janney ES	2nd Floor inside classroom 202	3/9/15	< 1		
JE-0309-21B	Janney ES	2nd Floor inside classroom 202	3/9/15	< 1		
JE-0309-22A	Janney ES	2nd Floor inside classroom 203	3/9/15	< 1		
JE-0309-22B	Janney ES	2nd Floor inside classroom 203	3/9/15	< 1		
JE-0309-23A	Janney ES	2nd Floor hallway adjacent to classroom 207	3/9/15	< 1		
JE-0309-23B	Janney ES	2nd Floor hallway adjacent to classroom 207	3/9/15	< 1		
JE-0309-24A	Janney ES	2nd Floor inside classroom 207	3/9/15	< 1		
JE-0309-24B	Janney ES	2nd Floor inside classroom 207	3/9/15	< 1		
JE-0309-25A	Janney ES	2nd Floor inside classroom 206	3/9/15	< 1		
JE-0309-25B	Janney ES	2nd Floor inside classroom 206	3/9/15	< 1		
JE-0309-26A	Janney ES	2nd Floor inside classroom 208	3/9/15	< 1		
JE-0309-26B	Janney ES	2nd Floor inside classroom 208	3/9/15	< 1		
JE-0309-27A	Janney ES	2nd Floor inside classroom 209	3/9/15	< 1		
JE-0309-27B	Janney ES	2nd Floor inside classroom 209	3/9/15	< 1		
JE-0309-28A	Janney ES	2nd Floor inside classroom 210 A	3/9/15	< 1		
JE-0309-28B	Janney ES	2nd Floor inside classroom 210 A	3/9/15	< 1		
JE-0309-29A	Janney ES	2nd Floor hallway adjacent to classroom 210	3/9/15	< 1		
JE-0309-29B	Janney ES	2nd Floor hallway adjacent to classroom 210	3/9/15	< 1		
JE-0309-30A	Janney ES	2nd Floor inside classroom 212	3/9/15	< 1		
JE-0309-30B	Janney ES	2nd Floor inside classroom 212	3/9/15	< 1		
JE-0309-31A	Janney ES	2nd Floor inside classroom 213	3/9/15	< 1		
JE-0309-31B	Janney ES	2nd Floor inside classroom 213	3/9/15	< 1		
JE-0309-32A	Janney ES	2nd Floor inside classroom 215	3/9/15	< 1		
JE-0309-32B	Janney ES	2nd Floor inside classroom 215	3/9/15	< 1		
JE-0309-33A	Janney ES	2nd Floor inside classroom 217	3/9/15	< 1		
JE-0309-33B	Janney ES	2nd Floor inside classroom 217	3/9/15	< 1		
JE-0309-34A	Janney ES	2nd Floor hallway adjacent to classroom (high)	3/9/15	< 1		
JE-0309-34B	Janney ES	2nd Floor hallway adjacent to classroom (high)	3/9/15	< 1		
JE-0309-35A	Janney ES	2nd Floor hallway adjacent to classroom (low)	3/9/15	< 1		
JE-0309-35B	Janney ES	2nd Floor hallway adjacent to classroom (low)	3/9/15	< 1		
JE-0309-36A	Janney ES	1st Floor inside classroom 117	3/9/15	< 1		
JE-0309-36B	Janney ES	1st Floor inside classroom 117	3/9/15	< 1		
JE-0309-37A	Janney ES	1st Floor inside classroom 115	3/9/15	< 1		
JE-0309-37B	Janney ES	1st Floor inside classroom 115	3/9/15	< 1		
JE-0309-38A	Janney ES	1st Floor hallway adjacent to classroom 115 (high)	3/9/15	< 1		
JE-0309-38B	Janney ES	1st Floor hallway adjacent to classroom 115 (high)	3/9/15	< 1		
JE-0309-39A	Janney ES	1st Floor hallway adjacent to classroom 115 (low)	3/9/15	< 1		
JE-0309-39B	Janney ES	1st Floor hallway adjacent to classroom 115 (low)	3/9/15	< 1		
JE-0309-40A	Janney ES	1st Floor hallway adjacent to classroom 113	3/9/15	< 1		

JE-0309-40B	Janney ES	1st Floor hallway adjacent to classroom 113	3/9/15	< 1		
JE-0309-41A	Janney ES	1st Floor inside classroom 112	3/9/15	< 1		
JE-0309-41B	Janney ES	1st Floor inside classroom 112	3/9/15	< 1		
JE-0309-42A	Janney ES	1st Floor hallway adjacent to classroom 110	3/9/15	< 1		
JE-0309-42B	Janney ES	1st Floor hallway adjacent to classroom 110	3/9/15	< 1		
JE-0309-43A	Janney ES	1st Floor inside classroom 110	3/9/15	< 1		
JE-0309-43B	Janney ES	1st Floor inside classroom 110	3/9/15	< 1		
JE-0309-44A	Janney ES	1st Floor inside classroom 108	3/9/15	4.1		
JE-0309-44B	Janney ES	1st Floor inside classroom 108	3/9/15	2.3		
JE-0309-45A	Janney ES	1st Floor inside classroom 109	3/9/15	< 1		
JE-0309-45B	Janney ES	1st Floor inside classroom 109	3/9/15	< 1		
JE-0309-46A	Janney ES	1st Floor inside classroom 107	3/9/15	< 1		
JE-0309-46B	Janney ES	1st Floor inside classroom 107	3/9/15	< 1		
JE-0309-47A	Janney ES	1st Floor inside classroom 106	3/9/15	< 1		
JE-0309-47B	Janney ES	1st Floor inside classroom 106	3/9/15	< 1		
JE-0309-48A	Janney ES	1st Floor hallway adjacent to classroom 107	3/9/15	< 1		
JE-0309-48B	Janney ES	1st Floor hallway adjacent to classroom 107	3/9/15	< 1		
JE-0309-49A	Janney ES	1st Floor hallway adjacent to health suite	3/9/15	< 1		
JE-0309-49B	Janney ES	1st Floor hallway adjacent to health suite	3/9/15	< 1		
JE-0309-50A	Janney ES	1st Floor inside health suite	3/9/15	< 1		
JE-0309-50B	Janney ES	1st Floor inside health suite	3/9/15	< 1		
JE-0309-51A	Janney ES	Ground Floor hallway across library	3/9/15	< 1		
JE-0309-51B	Janney ES	Ground Floor hallway across library	3/9/15	< 1		
JE-0309-52A	Janney ES	Ground floor inside classroom L10 Sink4 (1st from left - clockwise)	3/9/15	< 1		
JE-0309-52B	Janney ES	Ground floor inside classroom L10 Sink4 (clockwise)	3/9/15	< 1		
JE-0309-53A	Janney ES	Ground floor inside classroom L10 Sink3 (clockwise)	3/9/15	< 1		
JE-0309-53B	Janney ES	Ground floor inside classroom L10 Sink3 (clockwise)	3/9/15	< 1		
JE-0309-54A	Janney ES	Ground floor inside classroom L10 Sink2 (clockwise)	3/9/15	< 1		
JE-0309-54B	Janney ES	Ground floor inside classroom L10 Sink2 (clockwise)	3/9/15	< 1		
JE-0309-55A	Janney ES	Ground floor inside classroom L10 Sink1 (clockwise)	3/9/15	< 1		
JE-0309-55B	Janney ES	Ground floor inside classroom L10 Sink1 (clockwise)	3/9/15	< 1		
JE-0309-56A	Janney ES	Ground floor inside classroom L11	3/9/15	< 1		
JE-0309-56B	Janney ES	Ground floor inside classroom L11	3/9/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
JFES-0821-1A	Jefferson MS	Basement Hallway Adjacent to B20	8/21/15	< 1		
JFES-0821-1B	Jefferson MS	Basement Hallway Adjacent to B20	8/21/15	< 1		
JFES-0821-2A	Jefferson MS	Basement Hallway Adjacent to 003	8/21/15	< 1		
JFES-0821-2B	Jefferson MS	Basement Hallway Adjacent to 003	8/21/15	< 1		
JFES-0821-3A	Jefferson MS	Basement inside Boys' Locker Room	8/21/15	< 1		
JFES-0821-3B	Jefferson MS	Basement inside Boys' Locker Room	8/21/15	< 1		
JFES-0821-4A	Jefferson MS	Basement inside Girls' Locker Room	8/21/15	< 1		
JFES-0821-4B	Jefferson MS	Basement inside Girls' Locker Room	8/21/15	< 1		
JFES-0821-5A	Jefferson MS	Basement inside cafeteria	8/21/15	< 1		
JFES-0821-5B	Jefferson MS	Basement inside cafeteria	8/21/15	< 1		
JFES-0821-6A	Jefferson MS	Basement Hallway Adjacent to B01	8/21/15	< 1		
JFES-0821-6B	Jefferson MS	Basement Hallway Adjacent to B01	8/21/15	< 1		
JFES-0821-7A	Jefferson MS	First Floor Hallway Adjacent to 105	8/21/15	< 1		
JFES-0821-7B	Jefferson MS	First Floor Hallway Adjacent to 105	8/21/15	< 1		
JFES-0821-8A	Jefferson MS	Second Floor Hallway Adjacent to 207	8/21/15	< 1		
JFES-0821-8B	Jefferson MS	Second Floor Hallway Adjacent to 207	8/21/15	< 1		
JFES-0821-9A	Jefferson MS	Second Floor Hallway Across Rm 218	8/21/15	< 1		
JFES-0821-9B	Jefferson MS	Second Floor Hallway Across Rm 218	8/21/15	< 1		
JFES-0821-10A	Jefferson MS	Third Floor Hallway Adjacent to Rm 301	8/21/15	< 1		
JFES-0821-10B	Jefferson MS	Third Floor Hallway Adjacent to Rm 301	8/21/15	< 1		

JFES-0821-11A	Jefferson MS	Third Floor Hallway Across Rm 306	8/21/15	< 1		
JFES-0821-11B	Jefferson MS	Third Floor Hallway Across Rm 306	8/21/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
JMS-0501-1A	Johnson Hoyden MS	4th Floor hallway across class room 424	5/1/15	1.3		
JMS-0501-1B	Johnson Hoyden MS	4th Floor hallway across class room 424	5/1/15	5.4		
JMS-0501-2A	Johnson Hoyden MS	4th Floor hallway across room 420	5/1/15	< 1		
JMS-0501-2B	Johnson Hoyden MS	4th Floor hallway across room 420	5/1/15	< 1		
JMS-0501-3A	Johnson Hoyden MS	4th Floor hallway adjacent to room 416	5/1/15	< 1		
JMS-0501-3B	Johnson Hoyden MS	4th Floor hallway adjacent to room 416	5/1/15	< 1		
JMS-0501-4A	Johnson Hoyden MS	3rd Floor Hallway across class room 326A	5/1/15	< 1		
JMS-0501-4B	Johnson Hoyden MS	3rd Floor Hallway across class room 326A	5/1/15	< 1		
JMS-0501-5A	Johnson Hoyden MS	3rd Floor Hallway across class room 323 (high)	5/1/15	< 1		
JMS-0501-5B	Johnson Hoyden MS	3rd Floor Hallway across class room 323 (high)	5/1/15	< 1		
JMS-0501-6A	Johnson Hoyden MS	3 rd Floor Hallway across class room 323 (low)	5/1/15	< 1		
JMS-0501-6B	Johnson Hoyden MS	3rd Floor Hallway across class room 323 (low)	5/1/15	< 1		
JMS-0501-7A	Johnson Hoyden MS	3rd Floor Hallway across class room 315A (high)	5/1/15	< 1		
JMS-0501-7B	Johnson Hoyden MS	3rd Floor Hallway across class room 315A (high)	5/1/15	< 1		
JMS-0501-8A	Johnson Hoyden MS	3rd Floor Hallway across class room 315A (low)	5/1/15	< 1		
JMS-0501-8B	Johnson Hoyden MS	3rd Floor Hallway across class room 315A (low)	5/1/15	< 1		
JMS-0501-9A	Johnson Hoyden MS	2nd Floor hallway across class room 229	5/1/15	< 1		
JMS-0501-9B	Johnson Hoyden MS	2nd Floor hallway across class room 229	5/1/15	< 1		
JMS-0501-10A	Johnson Hoyden MS	2nd Floor hallway adjacent to class room 225A (high)	5/1/15	< 1		
JMS-0501-10B	Johnson Hoyden MS	2nd Floor hallway adjacent to class room 225A (high)	5/1/15	< 1		
JMS-0501-11A	Johnson Hoyden MS	2nd Floor hallway adjacent to class room 225A (low)	5/1/15	< 1		
JMS-0501-11B	Johnson Hoyden MS	2nd Floor hallway adjacent to class room 225A (low)	5/1/15	< 1		
JMS-0501-12A	Johnson Hoyden MS	2nd Floor hallway adjacent to class room 216	5/1/15	< 1		
JMS-0501-12B	Johnson Hoyden MS	2nd Floor hallway adjacent to class room 216	5/1/15	< 1		
JMS-0501-13A	Johnson Hoyden MS	1st Floor hallway across nurse site (high)	5/1/15	< 1		
JMS-0501-13B	Johnson Hoyden MS	1st Floor hallway across nurse site (high)	5/1/15	< 1		
JMS-0501-14A	Johnson Hoyden MS	1st Floor hallway across nurse site (low)	5/1/15	< 1		
JMS-0501-14B	Johnson Hoyden MS	1st Floor hallway across nurse site (low)	5/1/15	< 1		
JMS-0501-15A	Johnson Hoyden MS	1st Floor hallway adjacent to class room 108	5/1/15	< 1		
JMS-0501-15B	Johnson Hoyden MS	1st Floor hallway adjacent to class room 108	5/1/15	< 1		
JMS-0501-16A	Johnson Hoyden MS	1st Floor lobby adjacent to auditorium	5/1/15	< 1		
JMS-0501-16B	Johnson Hoyden MS	1st Floor lobby adjacent to auditorium	5/1/15	< 1		
JMS-0501-17A	Johnson Hoyden MS	1st Floor entrance lobby across gymnasium	5/1/15	< 1		
JMS-0501-17B	Johnson Hoyden MS	1st Floor entrance lobby across gymnasium	5/1/15	< 1		
JMS-0501-18A	Johnson Hoyden MS	Basement Floor inside cafeteria adjacent to Kitchen	5/1/15	< 1		
JMS-0501-18B	Johnson Hoyden MS	Basement Floor inside cafeteria adjacent to Kitchen	5/1/15	< 1		
JMS-0501-19A	Johnson Hoyden MS	Basement Floor inside cafeteria	5/1/15	< 1		
JMS-0501-19B	Johnson Hoyden MS	Basement Floor inside cafeteria	5/1/15	< 1		
JMS-0501-20A	Johnson Hoyden MS	Basement Floor inside rec room/Weight room	5/1/15	< 1		
JMS-0501-20B	Johnson Hoyden MS	Basement Floor inside rec room/Weight room	5/1/15	< 1		
JMS-0501-21A	Johnson Hoyden MS	Basement Floor B wing adjacent to storage room	5/1/15	< 1		
JMS-0501-21B	Johnson Hoyden MS	Basement Floor B wing adjacent to storage room	5/1/15	< 1		
JMS-0501-22A	Johnson Hoyden MS	1st Floor b wing adjacent to conference room	5/1/15	< 1		
JMS-0501-22B	Johnson Hoyden MS	1st Floor b wing adjacent to conference room	5/1/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
KM-0616-1A	Kelly Miller MS	3rd Floor hallway adjacent to A320 janitor closet (High)	6/16/15	< 1		
KM-0616-1B	Kelly Miller MS	3rd Floor hallway adjacent to A320 janitor closet (High)	6/16/15	< 1		
KM-0616-2A	Kelly Miller MS	3rd Floor hallway adjacent to A320 janitor closet (low)	6/16/15	< 1		
KM-0616-2B	Kelly Miller MS	3rd Floor hallway adjacent to A320 janitor closet (low)	6/16/15	< 1		
KM-0616-3A	Kelly Miller MS	3rd Floor hallway adjacent to elevator (high)	6/16/15	< 1		

KM-0616-3B	Kelly Miller MS	3rd Floor hallway adjacent to elevator (high)	6/16/15	< 1		
KM-0616-4A	Kelly Miller MS	3rd Floor hallway adjacent to elevator (low)	6/16/15	< 1		
KM-0616-4B	Kelly Miller MS	3rd Floor hallway adjacent to elevator (low)	6/16/15	< 1		
KM-0616-5A	Kelly Miller MS	2nd Floor hallway adjacent to A218 elevator equipment room (High)	6/16/15	< 1		
KM-0616-5B	Kelly Miller MS	2nd Floor hallway adjacent to A218 elevator equipment room (High)	6/16/15	< 1		
KM-0616-6A	Kelly Miller MS	2nd Floor hallway adjacent to A218 elevator equipment room (low)	6/16/15	< 1		
KM-0616-6B	Kelly Miller MS	2nd Floor hallway adjacent to A218 elevator equipment room (low)	6/16/15	< 1		
KM-0616-7A	Kelly Miller MS	2nd Floor hallway adjacent to elevator (high)	6/16/15	< 1		
KM-0616-7B	Kelly Miller MS	2nd Floor hallway adjacent to elevator (high)	6/16/15	< 1		
KM-0616-8A	Kelly Miller MS	2nd Floor hallway adjacent to elevator (low)	6/16/15	< 1		
KM-0616-8B	Kelly Miller MS	2nd Floor hallway adjacent to elevator (low)	6/16/15	< 1		
KM-0616-9A	Kelly Miller MS	1st Floor hallway adjacent to elevator (high)	6/16/15	< 1		
KM-0616-9B	Kelly Miller MS	1st Floor hallway adjacent to elevator (high)	6/16/15	< 1		
KM-0616-10A	Kelly Miller MS	1st Floor hallway adjacent to elevator (low)	6/16/15	< 1		
KM-0616-10B	Kelly Miller MS	1st Floor hallway adjacent to elevator (low)	6/16/15	< 1		
KM-0616-11A	Kelly Miller MS	1st Floor hallway adjacent to room A118 (high)	6/16/15	< 1		
KM-0616-11B	Kelly Miller MS	1st Floor hallway adjacent to room A118 (high)	6/16/15	< 1		
KM-0616-12A	Kelly Miller MS	1st Floor hallway adjacent to room A118 (low)	6/16/15	< 1		
KM-0616-12B	Kelly Miller MS	1st Floor hallway adjacent to room A118 (low)	6/16/15	< 1		
KM-0616-13A	Kelly Miller MS	1st Floor across C123 LAN Room (high)	6/16/15	< 1		
KM-0616-13B	Kelly Miller MS	1st Floor across C123 LAN Room (high)	6/16/15	< 1		
KM-0616-14A	Kelly Miller MS	1st Floor across C123 LAN Room (low)	6/16/15	< 1		
KM-0616-14B	Kelly Miller MS	1st Floor across C123 LAN Room (low)	6/16/15	< 1		
KM-0616-15A	Kelly Miller MS	1st Floor inside class room B135	6/16/15	< 1		
KM-0616-15B	Kelly Miller MS	1st Floor inside class room B135	6/16/15	< 1		
KM-0616-16A	Kelly Miller MS	1st Floor inside the GYM adjacent to Girls locker room	6/16/15	< 1		
KM-0616-16B	Kelly Miller MS	1st Floor inside the GYM adjacent to Girls locker room	6/16/15	< 1		
KM-0616-17A	Kelly Miller MS	1st Floor inside the GYM adjacent to room D122	6/16/15	< 1		
KM-0616-17B	Kelly Miller MS	1st Floor inside the GYM adjacent to room D122	6/16/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
KE-0319-1A	Ketcham ES	1st Floor inside classroom B116	3/19/15	1.8		
KE-0319-1B	Ketcham ES	1st Floor inside classroom B116	3/19/15	< 1		
KE-0319-2A	Ketcham ES	1st Floor inside classroom B114	3/19/15	2.2		
KE-0319-2B	Ketcham ES	1st Floor inside classroom B114	3/19/15	< 1		
KE-0319-3A	Ketcham ES	1st Floor inside classroom B113	3/19/15	6.1		
KE-0319-3B	Ketcham ES	1st Floor inside classroom B113	3/19/15	2.6		
KE-0319-4A	Ketcham ES	1st Floor inside classroom B112	3/19/15	1.4		
KE-0319-4B	Ketcham ES	1st Floor inside classroom B112	3/19/15	< 1		
KE-0319-5A	Ketcham ES	1st Floor hallway adjacent to music room A102	3/19/15	< 1		
KE-0319-5B	Ketcham ES	1st Floor hallway adjacent to music room A102	3/19/15	< 1		
KE-0319-6A	Ketcham ES	1st Floor inside classroom A101	3/19/15	< 1		
KE-0319-6B	Ketcham ES	1st Floor inside classroom A101	3/19/15	< 1		
KE-0319-7A	Ketcham ES	Ground Floor hallway adjacent to girls rest room across storage room 2	3/19/15	< 1		
KE-0319-7B	Ketcham ES	Ground Floor hallway adjacent to girls rest room across storage room 2	3/19/15	< 1		
KE-0319-8A	Ketcham ES	1st floor inside cafeteria	3/19/15	< 1		
KE-0319-8B	Ketcham ES	1st floor inside cafeteria	3/19/15	< 1		
KE-0319-9A	Ketcham ES	3rd Floor hallway adjacent to rest room across classroom B312	3/19/15	< 1		
KE-0319-9B	Ketcham ES	3rd Floor hallway adjacent to rest room across classroom B312	3/19/15	< 1		
KE-0319-10A	Ketcham ES	2nd Floor hallway adjacent to rest room across classroom B211	3/19/15	1.2		
KE-0319-10B	Ketcham ES	2nd Floor hallway adjacent to rest room across classroom B211	3/19/15	4.7		
KE-0319-11A	Ketcham ES	1st Floor hallway across classroom B109	3/19/15	6.8		
KE-0319-11B	Ketcham ES	1st Floor hallway across classroom B109	3/19/15	7.9		

		Percentage of Passed Samples			100.00%
		Percentage of Failed Samples			0.00%
KES-0219-1A	Key ES	2nd floor adjacent to Classroom 2099	2/19/15	< 1	
KES-0219-1B	Key ES	2nd floor adjacent to Classroom 209	2/19/15	< 1	
KES-0219-2A	Key ES	2nd floor inside Classroom 212	2/19/15	< 1	
KES-0219-2B	Key ES	2nd floor inside Classroom 212	2/19/15	< 1	
KES-0219-3A	Key ES	2nd floor inside Classroom 211	2/19/15	< 1	
KES-0219-3B	Key ES	2nd floor inside Classroom 211	2/19/15	< 1	
KES-0219-4A	Key ES	2nd floor inside Classroom 209	2/19/15	< 1	
KES-0219-4B	Key ES	2nd floor inside Classroom 209	2/19/15	< 1	
KES-0219-5A	Key ES	2nd floor inside Classroom 210	2/19/15	< 1	
KES-0219-5B	Key ES	2nd floor inside Classroom 210	2/19/15	< 1	
KES-0219-6A	Key ES	2nd floor inside Classroom 208	2/19/15	< 1	
KES-0219-6B	Key ES	2nd floor inside Classroom 208	2/19/15	< 1	
KES-0219-7A	Key ES	2nd floor inside Classroom 207	2/19/15	< 1	
KES-0219-7B	Key ES	2nd floor inside Classroom 207	2/19/15	< 1	
KES-0219-8A	Key ES	2nd floor inside Classroom 206 (left)	2/19/15	< 1	
KES-0219-8B	Key ES	2nd floor inside Classroom 206 (left)	2/19/15	< 1	
KES-0219-9A	Key ES	2nd floor inside Classroom 206 (right)	2/19/15	< 1	
KES-0219-9B	Key ES	2nd floor inside Classroom 206 (right)	2/19/15	< 1	
KES-0219-10A	Key ES	2nd floor inside Classroom 205	2/19/15	< 1	
KES-0219-10B	Key ES	2nd floor inside Classroom 205	2/19/15	< 1	
KES-0219-11A	Key ES	2nd floor hallway adjacent to Classroom 204	2/19/15	< 1	
KES-0219-11B	Key ES	2nd floor hallway adjacent to Classroom 204	2/19/15	< 1	
KES-0219-12A	Key ES	2nd floor inside Classroom 204	2/19/15	< 1	
KES-0219-12B	Key ES	2nd floor inside Classroom 204	2/19/15	< 1	
KES-0219-13A	Key ES	2nd floor inside Classroom 203	2/19/15	< 1	
KES-0219-13B	Key ES	2nd floor inside Classroom 203	2/19/15	< 1	
KES-0219-14A	Key ES	2nd floor inside Classroom 202	2/19/15	< 1	
KES-0219-14B	Key ES	2nd floor inside Classroom 202	2/19/15	< 1	
KES-0219-15A	Key ES	2nd floor inside Classroom 201	2/19/15	< 1	
KES-0219-15B	Key ES	2nd floor inside Classroom 201	2/19/15	< 1	
KES-0219-16A	Key ES	1st floor inside Classroom 101	2/19/15	< 1	
KES-0219-16B	Key ES	1st floor inside Classroom 101	2/19/15	< 1	
KES-0219-17A	Key ES	1st floor inside Classroom 102	2/19/15	< 1	
KES-0219-17B	Key ES	1st floor inside Classroom 102	2/19/15	< 1	
KES-0219-18A	Key ES	1st floor inside Classroom 103	2/19/15	< 1	
KES-0219-18B	Key ES	1st floor inside Classroom 103	2/19/15	< 1	
KES-0219-19A	Key ES	1st floor inside Classroom 104	2/19/15	< 1	
KES-0219-19B	Key ES	1st floor inside Classroom 104	2/19/15	< 1	
KES-0219-20A	Key ES	1st floor hallway adjacent to Classroom 104	2/19/15	< 1	
KES-0219-20B	Key ES	1st floor hallway adjacent to Classroom 104	2/19/15	< 1	
KES-0219-21A	Key ES	1st floor hallway adjacent to Classroom 103	2/19/15	< 1	
KES-0219-21B	Key ES	1st floor hallway adjacent to Classroom 103	2/19/15	< 1	
KES-0219-22A	Key ES	1st floor inside Classroom 105	2/19/15	< 1	
KES-0219-22B	Key ES	1st floor inside Classroom 105	2/19/15	< 1	
KES-0219-23A	Key ES	1st floor inside Classroom 106	2/19/15	< 1	
KES-0219-23B	Key ES	1st floor inside Classroom 106	2/19/15	< 1	
KES-0219-24A	Key ES	Basement floor hallway between Boy's and Girl's Rooms.	2/19/15	< 1	
KES-0219-24B	Key ES	Basement floor hallway between Boy's and Girl's Rooms.	2/19/15	< 1	
		Percentage of Passed Samples			100.00%
		Percentage of Failed Samples			0.00%
KES-0826-1A	Kimball ES	1st Floor hallway near 115	8/26/15	< 1	
KES-0826-1B	Kimball ES	1st Floor hallway near 115	8/26/15	< 1	
KES-0826-2A	Kimball ES	1st Floor hallway adjacent to 112	8/26/15	< 1	

KES-0826-2B	Kimball ES	1st Floor hallway adjacent to 112	8/26/15	< 1		
KES-0826-3A	Kimball ES	Inside Rm 109	8/26/15	< 1		
KES-0826-3B	Kimball ES	Inside Rm 109	8/26/15	< 1		
KES-0826-4A	Kimball ES	Inside RM 102	8/26/15	< 1		
KES-0826-4B	Kimball ES	Inside RM 102	8/26/15	< 1		
KES-0826-5A	Kimball ES	1st Floor hallway near Auditorium	8/26/15	< 1		
KES-0826-5B	Kimball ES	1st Floor hallway near Auditorium	8/26/15	< 1		
KES-0826-6A	Kimball ES	1st Floor hallway across 102	8/26/15	< 1		
KES-0826-6B	Kimball ES	1st Floor hallway across 102	8/26/15	< 1		
KES-0826-7A	Kimball ES	1st Floor hallway across 104	8/26/15	< 1		
KES-0826-7B	Kimball ES	1st Floor hallway across 104	8/26/15	< 1		
KES-0826-8A	Kimball ES	2nd Floor hallway adjacent to 200	8/26/15	< 1		
KES-0826-8B	Kimball ES	2nd Floor hallway adjacent to 200	8/26/15	< 1		
KES-0826-9A	Kimball ES	2nd Floor hallway adjacent to 203	8/26/15	< 1		
KES-0826-9B	Kimball ES	2nd Floor hallway adjacent to 203	8/26/15	< 1		
KES-0826-10A	Kimball ES	2nd Floor adjacent to Teacher's lounge	8/26/15	< 1		
KES-0826-10B	Kimball ES	2nd Floor adjacent to Teacher's lounge	8/26/15	< 1		
KES-08 26-11A	Kimball ES	2nd Floor adjacent to 212	8/26/15	< 1		
KES-0826-11B	Kimball ES	2nd Floor adjacent to 212	8/26/15	< 1		
KES-0826-12A	Kimball ES	1st Floor adjacent to 108	8/26/15	< 1		
KES-0826-12B	Kimball ES	1st Floor adjacent to 108	8/26/15	< 1		
KES-0826 -13A	Kimball ES	Adjacent to Custodian's	8/26/15	< 1		
KES-0826-13B	Kimball ES	Adjacent to Custodian's	8/26/15	< 1		
KES-0826-14A	Kimball ES	Across 004	8/26/15	< 1		
KES-0826-14B	Kimball ES	Across 004	8/26/15	< 1		
KES-0826-15A	Kimball ES	2nd Floor near Custodian	8/26/15	< 1		
KES-0826-15B	Kimball ES	2nd Floor near Custodian	8/26/15	< 1		
KES-0826-16A	Kimball ES	Inside Cafeteria	8/26/15	< 1		
KES-0826-16B	Kimball ES	Inside Cafeteria	8/26/15	< 1		
KES-0826-17A	Kimball ES	Inside Nurse's suite sink with a filter	8/26/15	< 1		
KES-0826-17B	Kimball ES	Inside Nurse's suite sink with a filter	8/26/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
KM-0319-1A	Kramer MS	3rd Floor hallway adjacent to room 306 (high)	3/19/15	< 1		
KM-0319-1B	Kramer MS	3rd Floor hallway adjacent to room 306 (high)	3/19/15	< 1		
KM-0319-2A	Kramer MS	3rd Floor hallway adjacent to room 306 (low)	3/19/15	< 1		
KM-0319-2B	Kramer MS	3rd Floor hallway adjacent to room 306 (low)	3/19/15	< 1		
KM-0319-3A	Kramer MS	3rd Floor hallway adjacent to room 301 (high)	3/19/15	< 1		
KM-0319-3B	Kramer MS	3rd Floor hallway adjacent to room 301 (high)	3/19/15	< 1		
KM-0319-4A	Kramer MS	3rd Floor hallway adjacent to room 301 (low)	3/19/15	< 1		
KM-0319-4B	Kramer MS	3rd Floor hallway adjacent to room 301 (low)	3/19/15	< 1		
KM-0319-5A	Kramer MS	3rd Floor hallway adjacent to boys rest room 381 (high)	3/19/15	< 1		
KM-0319-5B	Kramer MS	3rd Floor hallway adjacent to boys rest room 381 (high)	3/19/15	< 1		
KM-0319-6A	Kramer MS	3rd Floor hallway adjacent to boys rest room 381 (low)	3/19/15	< 1		
KM-0319-6B	Kramer MS	3rd Floor hallway adjacent to boys rest room 381 (low)	3/19/15	< 1		
KM-0319-7A	Kramer MS	2nd Floor hallway adjacent to classroom 204 (high)	3/19/15	< 1		
KM-0319-7B	Kramer MS	2nd Floor hallway adjacent to classroom 204 (high)	3/19/15	< 1		
KM-0319-8A	Kramer MS	2nd Floor hallway adjacent to classroom 204 (low)	3/19/15	< 1		
KM-0319-8B	Kramer MS	2nd Floor hallway adjacent to classroom 204 (low)	3/19/15	< 1		
KM-0319-9A	Kramer MS	2nd Floor hallway adjacent to boys rest room 281 (high)	3/19/15	< 1		
KM-0319-9B	Kramer MS	2nd Floor hallway adjacent to boys rest room 281 (high)	3/19/15	< 1		
KM-0319-10A	Kramer MS	2nd Floor hallway adjacent to boys rest room 281 (low)	3/19/15	< 1		
KM-0319-10B	Kramer MS	2nd Floor hallway adjacent to boys rest room 281 (low)	3/19/15	< 1		
KM-0319-11A	Kramer MS	2nd Floor hallway adjacent to room 201 (high)	3/19/15	< 1		
KM-0319-11B	Kramer MS	2nd Floor hallway adjacent to room 201 (high)	3/19/15	< 1		

KM-0319-12A	Kramer MS	2nd Floor hallway adjacent to room 201 (low)	3/19/15	< 1		
KM-0319-12B	Kramer MS	2nd Floor hallway adjacent to room 201 (low)	3/19/15	< 1		
KM-0319-13A	Kramer MS	1st Floor hallway adjacent to administration office 102 (high)	3/19/15	< 1		
KM-0319-13B	Kramer MS	1st Floor hallway adjacent to administration office 102 (high)	3/19/15	< 1		
KM-0319-14A	Kramer MS	1st Floor hallway adjacent to administration office 102 (low)	3/19/15	< 1		
KM-0319-14B	Kramer MS	1st Floor hallway adjacent to administration office 102 (low)	3/19/15	< 1		
KM-0319-15A	Kramer MS	1st Floor hallway adjacent to electrical closet 100A	3/19/15	< 1		
KM-0319-15B	Kramer MS	1st Floor hallway adjacent to electrical closet 100A	3/19/15	< 1		
KM-0319-16A	Kramer MS	1st Floor hallway adjacent to administration office 117 Auditorium across gym (high)	3/19/15	< 1		
KM-0319-16B	Kramer MS	1st Floor hallway adjacent to administration office 117 Auditorium across gym (high)	3/19/15	< 1		
KM-0319-17A	Kramer MS	1st Floor hallway adjacent to administration office 117 Auditorium across gym (low)	3/19/15	< 1		
KM-0319-17B	Kramer MS	1st Floor hallway adjacent to administration office 117 Auditorium across gym (low)	3/19/15	< 1		
KM-0319-18A	Kramer MS	Basement Floor hallway adjacent to Cafeteria 20 (high)	3/19/15	< 1		
KM-0319-18B	Kramer MS	Basement Floor hallway adjacent to Cafeteria 20 (high)	3/19/15	< 1		
KM-0319-19A	Kramer MS	Basement Floor hallway adjacent to Cafeteria 20 (low)	3/19/15	< 1		
KM-0319-19B	Kramer MS	Basement Floor hallway adjacent to Cafeteria 20 (low)	3/19/15	< 1		
KM-0319-20A	Kramer MS	Basement Floor hallway adjacent to custodian office (high)	3/19/15	< 1		
KM-0319-20B	Kramer MS	Basement Floor hallway adjacent to custodian office (high)	3/19/15	< 1		
KM-0319-21A	Kramer MS	Basement Floor hallway adjacent to custodian office (low)	3/19/15	< 1		
KM-0319-21B	Kramer MS	Basement Floor hallway adjacent to custodian office (low)	3/19/15	< 1		
KM-0319-22A	Kramer MS	Basement Floor hallway across storage 15 (high)	3/19/15	< 1		
KM-0319-22B	Kramer MS	Basement Floor hallway across storage 15 (high)	3/19/15	< 1		
KM-0319-23A	Kramer MS	Basement Floor hallway across storage 15 (low)	3/19/15	< 1		
KM-0319-23B	Kramer MS	Basement Floor hallway across storage 15 (low)	3/19/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
LES-0903-1A	Lafayette ES (Trailers F,G&H)	Trailer F hallway across from Room F110 (high, right)	9/3/15	< 1		
LES-0903-1B	Lafayette ES (Trailers F,G&H)	Trailer F hallway across from Room F110 (high, right)	9/3/15	< 1		
LES-0903-2A	Lafayette ES (Trailers F,G&H)	Trailer F hallway across from Room F110 (low, right)	9/3/15	< 1		
LES-0903-2B	Lafayette ES (Trailers F,G&H)	Trailer F hallway across from Room F110 (low, right)	9/3/15	< 1		
LES-0903-3A	Lafayette ES (Trailers F,G&H)	Trailer G hallway across from Room G102 (high, right)	9/3/15	< 1		
LES-0903-3B	Lafayette ES (Trailers F,G&H)	Trailer G hallway across from Room G102 (high, right)	9/3/15	14		
LES-0903-4A	Lafayette ES (Trailers F,G&H)	Trailer G hallway across from Room G102 (low, right)	9/3/15	< 1		
LES-0903-4B	Lafayette ES (Trailers F,G&H)	Trailer G hallway across from Room G102 (low, right)	9/3/15	7		
LES-0903-5A	Lafayette ES (Trailers F,G&H)	Trailer H hallway across from Room H102 (high, right)	9/3/15	< 1		
LES-0903-5B	Lafayette ES (Trailers F,G&H)	Trailer H hallway across from Room H102 (high, right)	9/3/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
LEC-0324-1A	Langdon ES	2nd Floor inside classroom 212	3/24/15	< 1		
LEC-0324-1B	Langdon ES	2nd Floor inside classroom 212	3/24/15	< 1		
LEC-0324-2A HI	Langdon ES	2nd floor hallway in front of 212- high	3/24/15	< 1		
LEC-0324-2B HI	Langdon ES	2nd floor hallway in front of 212- high	3/24/15	< 1		
LEC-0324-2A LO	Langdon ES	2nd floor hallway in front of 212- low	3/24/15	< 1		
LEC-0324-2B LO	Langdon ES	2nd floor hallway in front of 212- low	3/24/15	< 1		
LEC-0324-3A HI	Langdon ES	2nd floor hallway, next to 204- high	3/24/15	< 1		
LEC-0324-3B HI	Langdon ES	2nd floor hallway, next to 204- high	3/24/15	< 1		
LEC-0324-3A LO	Langdon ES	2nd floor hallway, next to 204- low	3/24/15	< 1		
LEC-0324-3B LO	Langdon ES	2nd floor hallway, next to 204- low	3/24/15	< 1		
LEC-0324-4A	Langdon ES	2nd floor, Learning Center 2B by boys room	3/24/15	< 1		
LEC-0324-4B	Langdon ES	2nd floor, Learning Center 2B by boys room	3/24/15	< 1		
LEC-0324-5A	Langdon ES	2nd floor hallway, next to 226	3/24/15	< 1		

LEC-0324-5B	Langdon ES	2nd floor hallway, next to 226	3/24/15	< 1		
LEC-0324-6A	Langdon ES	2nd floor hallway in front of room 232/Multipurpose room	3/24/15	2.2		
LEC-0324-6B	Langdon ES	2nd floor hallway in front of room 232/Multipurpose room	3/24/15	< 1		
LEC-0324-7A	Langdon ES	2nd floor hallway, next to room 120	3/24/15	< 1		
LEC-0324-7B	Langdon ES	2nd floor hallway, next to room 120	3/24/15	< 1		
LEC-0324-8A	Langdon ES	1st floor, room 124	3/24/15	< 1		
LEC-0324-8B	Langdon ES	1st floor, room 124	3/24/15	< 1		
LEC-0324-9A	Langdon ES	1st Floor, Early childhood center, next to teachers and boys rest rooms	3/24/15	< 1		
LEC-0324-9B	Langdon ES	1st Floor, Early childhood center, next to teachers and boys rest rooms	3/24/15	< 1		
LEC-0324-10A	Langdon ES	1st Floor, Gym	3/24/15	< 1		
LEC-0324-10B	Langdon ES	1st Floor, Gym	3/24/15	< 1		
LEC-0324-11A	Langdon ES	1st floor, room 103	3/24/15	< 1		
LEC-0324-11B	Langdon ES	1st floor, room 103	3/24/15	< 1		
LEC-0324-12A HI	Langdon ES	1st floor hallway, next to room 104- high	3/24/15	< 1		
LEC-0324-12B HI	Langdon ES	1st floor hallway, next to room 104- high	3/24/15	< 1		
LEC-0324-12A LO	Langdon ES	1st floor hallway, next to room 104- low	3/24/15	< 1		
LEC-0324-12B LO	Langdon ES	1st floor hallway, next to room 104 – low	3/24/15	< 1		
LEC-0324-13A	Langdon ES	1st floor, room 102	3/24/15	< 1		
LEC-0324-13B	Langdon ES	1st floor, room 102	3/24/15	< 1		
LEC-0324-14A	Langdon ES	1st floor, room 101	3/24/15	< 1		
LEC-0324-14B	Langdon ES	1st floor, room 101	3/24/15	< 1		
LEC-0324-15A	Langdon ES	1st floor, room 101	3/24/15	< 1		
LEC-0324-15B	Langdon ES	1st floor, room 106	3/24/15	< 1		
LEC-0324-16A HI	Langdon ES	1st floor, room 106	3/24/15	< 1		
LEC-0324-16B HI	Langdon ES	1st floor hallway in front of room 105- high	3/24/15	< 1		
LEC-0324-16A LO	Langdon ES	1st floor hallway in front of room 105- high	3/24/15	< 1		
LEC-0324-16B LO	Langdon ES	1st floor hallway in front of room 105- low	3/24/15	< 1		
LEC-0324-17A	Langdon ES	1st floor hallway in front of room 105- low	3/24/15	< 1		
LEC-0324-17B	Langdon ES	1st floor, room 109	3/24/15	< 1		
LEC-0324-18A	Langdon ES	1st floor, room 109	3/24/15	< 1		
LEC-0324-18B	Langdon ES	1st floor, room 107	3/24/15	< 1		
LEC-0324-19A	Langdon ES	1st floor, room 107	3/24/15	< 1		
LEC-0324-19B	Langdon ES	1st floor, room 108	3/24/15	< 1		
LEC-0324-20A	Langdon ES	1st floor, room 108	3/24/15	< 1		
LEC-0324-20B	Langdon ES	1st floor, room 110	3/24/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
LES-1205-1A	Langley ES	3rd floor hallway adjacent to classroom 301	12/5/14	< 1		
LES-1205-2B	Langley ES	3rd floor hallway adjacent to classroom 301	12/5/14	< 1		
LES-1205-3A	Langley ES	3rd floor hallway adjacent to classroom 304	12/5/14	< 1		
LES-1205-4B	Langley ES	3rd floor hallway adjacent to classroom 304	12/5/14	< 1		
LES-1205-5A	Langley ES	2nd floor hallway adjacent to classroom 201	12/5/14	< 1		
LES-1205-6B	Langley ES	2nd floor hallway adjacent to classroom 201	12/5/14	< 1		
LES-1205-7A	Langley ES	2nd floor hallway adjacent to classroom 204	12/5/14	< 1		
LES-1205-8B	Langley ES	2nd floor hallway adjacent to classroom 204	12/5/14	< 1		
LES-1205-9A	Langley ES	1st floor hallway adjacent to electric room 104	12/5/14	< 1		
LES-1205-10B	Langley ES	1st floor hallway adjacent to electric room 104	12/5/14	< 1		
LES-1205-11A	Langley ES	1st floor hallway adjacent to principal's office 155	12/5/14	< 1		
LES-1205-12B	Langley ES	1st floor hallway adjacent to principal's office 155	12/5/14	< 1		
LES-1205-13A	Langley ES	1st floor inside classroom 133	12/5/14	< 1		
LES-1205-14B	Langley ES	1st floor inside classroom 133	12/5/14	< 1		
LES-1205-15A	Langley ES	1st floor inside classroom 125	12/5/14	< 1		
LES-1205-16B	Langley ES	1st floor inside classroom 125	12/5/14	< 1		

LES-1205-17A	Langley ES	1st floor inside classroom 122	12/5/14	< 1		
LES-1205-18B	Langley ES	1st floor inside classroom 122	12/5/14	< 1		
LES-1205-19A	Langley ES	1st floor inside classroom 113	12/5/14	< 1		
LES-1205-20B	Langley ES	1st floor inside classroom 113	12/5/14	< 1		
LES-1205-21A	Langley ES	Basement floor hallway adjacent to gym B01	12/5/14	< 1		
LES-1205-22B	Langley ES	Basement floor hallway adjacent to gym B01	12/5/14	< 1		
LES-1205-23A	Langley ES	Sub-basement floor hallway at entrance to cafeteria	12/5/14	< 1		
LES-1205-24B	Langley ES	Sub-basement floor hallway at entrance to cafeteria	12/5/14	< 1		
LES-1205-25A	Langley ES	3rd floor inside staff room	12/5/14	< 1		
LES-1205-26B	Langley ES	3rd floor inside staff room	12/5/14	< 1		
LES-1205-27A	Langley ES	2nd floor inside classroom 211	12/5/14	< 1		
LES-1205-28B	Langley ES	2nd floor inside classroom 211	12/5/14	< 1		
LES-1205-29A	Langley ES	2nd floor inside classroom 217	12/5/14	< 1		
LES-1205-30B	Langley ES	2nd floor inside classroom 217	12/5/14	< 1		
LES-1205-31A	Langley ES	2nd floor inside classroom 208	12/5/14	< 1		
LES-1205-32B	Langley ES	2nd floor inside classroom 208	12/5/14	< 1		
LES-1205-33A	Langley ES	1st floor inside classroom 143	12/5/14	< 1		
LES-1205-34B	Langley ES	1st floor inside classroom 143	12/5/14	< 1		
LES-1205-35A	Langley ES	1st floor inside classroom 149	12/5/14	< 1		
LES-1205-36B	Langley ES	1st floor inside classroom 149	12/5/14	< 1		
LES-1205-37A	Langley ES	1st floor inside teacher's lounge	12/5/14	2.3		
LES-1205-38B	Langley ES	1st floor inside teacher's lounge	12/5/14	< 1		
LES-1205-39A	Langley ES	Basement floor hallway adjacent to gym B02	12/5/14	< 1		
LES-1205-40B	Langley ES	Basement floor hallway adjacent to gym B02	12/5/14	< 1		
LES-1205-41A	Langley ES	Sub-basement floor hallway near equipment storage SB34	12/5/14	< 1		
LES-1205-42B	Langley ES	Sub-basement floor hallway near equipment storage SB34	12/5/14	1.1		
LES-1205-43A	Langley ES	1st floor inside classroom 147	12/5/14	< 1		
LES-1205-44B	Langley ES	1st floor inside classroom 147	12/5/14	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
LBES-0806-1A	Lasalle-Backus EC	Basement inside Classroom G010	8/6/15	< 1		
LBES-0806-1B	Lasalle-Backus EC	Basement inside Classroom G010	8/6/15	< 1		
LBES-0806-2A	Lasalle-Backus EC	Basement inside Classroom G011	8/6/15	< 1		
LBES-0806-2B	Lasalle-Backus EC	Basement inside Classroom G011	8/6/15	< 1		
LBES-0806-3A	Lasalle-Backus EC	Basement inside Classroom G009	8/6/15	< 1		
LBES-0806-3B	Lasalle-Backus EC	Basement inside Classroom G009	8/6/15	< 1		
LBES-0806-4A	Lasalle-Backus EC	Basement inside Classroom G007	8/6/15	< 1		
LBES-0806-4B	Lasalle-Backus EC	Basement inside Classroom G007	8/6/15	< 1		
LBES-0806-5A	Lasalle-Backus EC	Basement Hallway Adjacent to G008	8/6/15	< 1		
LBES-0806-5B	Lasalle-Backus EC	Basement Hallway Adjacent to G008	8/6/15	< 1		
LBES-0806-6A	Lasalle-Backus EC	Basement inside Classroom G005	8/6/15	< 1		
LBES-0806-6B	Lasalle-Backus EC	Basement inside Classroom G005	8/6/15	< 1		
LBES-0806-7A	Lasalle-Backus EC	Inside Cafeteria	8/6/15	< 1		
LBES-0806-7B	Lasalle-Backus EC	Inside Cafeteria	8/6/15	< 1		
LBES-0806-8A	Lasalle-Backus EC	Third floor hallway across Rm 307	8/6/15	< 1		
LBES-0806-8B	Lasalle-Backus EC	Third floor hallway across Rm 307	8/6/15	< 1		
LBES-0806-9A	Lasalle-Backus EC	Second floor hallway across Rm 207	8/6/15	< 1		
LBES-0806-9B	Lasalle-Backus EC	Second floor hallway across Rm 207	8/6/15	< 1		
LBES-0806-10A	Lasalle-Backus EC	Second floor hallway adjacent to Rm 208	8/6/15	< 1		
LBES-0806-10B	Lasalle-Backus EC	Second floor hallway adjacent to Rm 208	8/6/15	< 1		
LBES-0806-11A	Lasalle-Backus EC	First floor hallway across Rm105	8/6/15	< 1		
LBES-0806-11B	Lasalle-Backus EC	First floor hallway across Rm 105	8/6/15	< 1		
LBES-0806-12A	Lasalle-Backus EC	First floor hallway adjacent to Rm113	8/6/15	< 1		
LBES-0806-12B	Lasalle-Backus EC	First floor hallway adjacent to Rm 113	8/6/15	< 1		
LBES-0806-13A	Lasalle-Backus EC	First floor Inside Nurses Rm 115	8/6/15	7		

LBES-0806-13B	Lasalle-Backus EC	First floor Inside Nurses Rm 115	8/6/15	5.7		
LBES-0806-14A	Lasalle-Backus EC	First floor hallway across Rm 122	8/6/15	< 1		
LBES-0806-14B	Lasalle-Backus EC	First floor hallway across Rm 122	8/6/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
LE-1230-1A	Leckie ES	3rd Floor Hallway adjacent to Classroom 309	12/30/14	1.4		
LE-1230-2B	Leckie ES	3rd floor Hallway adjacent to Classroom 309	12/30/14	2		
LE-1230-3A	Leckie ES	3rd Floor Inside Class room 303	12/30/14	1.9		
LE-1230-4B	Leckie ES	3rd Floor Inside Class room 303	12/30/14	1.4		
LE-1230-5A	Leckie ES	2nd Floor Hallway adjacent Classroom 202	12/30/14	< 1		
LE-1230-6B	Leckie ES	2nd Floor Hallway adjacent Classroom 202	12/30/14	< 1		
LE-1230-7A	Leckie ES	2nd Floor Hallway adjacent Classroom 212	12/30/14	< 1		
LE-1230-8B	Leckie ES	2nd Floor Hallway adjacent to Classroom 212	12/30/14	< 1		
LE-1230-9A	Leckie ES	1st Floor Hallway adjacent to Classroom 122	12/30/14	< 1		
LE-1230-10B	Leckie ES	1st Floor Hallway adjacent to Classroom 122	12/30/14	1.1		
LE-1230-11A	Leckie ES	1st Floor Hallway adjacent to Classroom 122	12/30/14	< 1		
LE-1230-12B	Leckie ES	1st Floor Hallway adjacent to Classroom 122	12/30/14	< 1		
LE-1230-13A	Leckie ES	1st Floor Inside the Classroom 115	12/30/14	< 1		
LE-1230-14B	Leckie ES	1st Floor Inside the Classroom 115	12/30/14	< 1		
LE-1230-15A	Leckie ES	1st Floor Inside the Classroom 122	12/30/14	< 1		
LE-1230-16B	Leckie ES	1st Floor Inside the Classroom 122	12/30/14	< 1		
LE-1230-17A	Leckie ES	1st Floor Inside the Classroom 120	12/30/14	< 1		
LE-1230-18B	Leckie ES	1st Floor Inside the Classroom 120	12/30/14	< 1		
LE-1230-19A	Leckie ES	1st Floor Inside the Classroom 113	12/30/14	< 1		
LE-1230-20B	Leckie ES	1st Floor Inside the Classroom 113	12/30/14	< 1		
LE-1230-21A	Leckie ES	1st Floor Inside the Classroom 111	12/30/14	< 1		
LE-1230-22B	Leckie ES	1st Floor Inside the Classroom 111	12/30/14	< 1		
LE-1230-23A	Leckie ES	1st Floor Gym/Cafeteria	12/30/14	< 1		
LE-1230-24B	Leckie ES	1st Floor Gym/Cafeteria	12/30/14	< 1		
LE-1230-25A	Leckie ES	Ground Floor Inside Classroom 016	12/30/14	< 1		
LE-1230-26B	Leckie ES	Ground Floor Inside Classroom 016	12/30/14	< 1		
LE-1230-27A	Leckie ES	Ground Floor Inside Classroom 018	12/30/14	< 1		
LE-1230-28B	Leckie ES	Ground Floor Inside Classroom 018	12/30/14	< 1		
LE-1230-29A	Leckie ES	Ground Floor Inside the Classroom 014	12/30/14	< 1		
LE-1230-30B	Leckie ES	Ground Floor Inside the Classroom 014	12/30/14	< 1		
LE-1230-31A	Leckie ES	Ground Floor Inside the Classroom 012	12/30/14	< 1		
LE-1230-32B	Leckie ES	Ground Floor Inside the Classroom 012	12/30/14	< 1		
LE-1230-33A	Leckie ES	Ground Floor Hallway adjacent to Classroom 008	12/30/14	< 1		
LE-1230-34B	Leckie ES	Ground Floor Hallway adjacent to Classroom 008	12/30/14	< 1		
LE-1230-35A	Leckie ES	Ground Floor Hallway adjacent to Classroom 008	12/30/14	< 1		
LE-1230-36B	Leckie ES	Ground Floor Hallway adjacent to Class room 008	12/30/14	< 1		
LE-1230-37A	Leckie ES	1st Floor Hallway adjacent to Classroom 104	12/30/14	< 1		
LE-1230-38B	Leckie ES	1st Floor Hallway adjacent to Class room 104	12/30/14	< 1		
LE-1230-39A	Leckie ES	1st Floor Hallway adjacent to Classroom 104	12/30/14	1.2		
LE-1230-40B	Leckie ES	1st Floor Hallway adjacent to Classroom 104	12/30/14	1.4		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
LOES-0820-1A	Logan ES	First Floor Hallway Adjacent to Rm 109	8/20/15	< 1		
LOES-0820-1B	Logan ES	First Floor Hallway Adjacent to Rm 109	8/20/15	< 1		
LOES-0820-2A	Logan ES	Second Floor Hallway Adjacent to Rm 212	8/20/15	< 1		
LOES-0820-2B	Logan ES	Second Floor Hallway Adjacent to Rm 212	8/20/15	< 1		
LOES-0820-3A	Logan ES	Second Floor Hallway Adjacent to Rm 202 (high)	8/20/15	< 1		
LOES-0820-3B	Logan ES	Second Floor Hallway Adjacent to Rm 202 (high)	8/20/15	1.5		
LOES-0820-4A	Logan ES	Second Floor Hallway Adjacent to Rm 202 (low)	8/20/15	< 1		
LOES-0820-4B	Logan ES	Second Floor Hallway Adjacent to Rm 202 (low)	8/20/15	2.2		

LOES-0820-5A	Logan ES	First Floor Hallway Adjacent to Rm 101	8/20/15	< 1		
LOES-0820-5B	Logan ES	First Floor Hallway Adjacent to Rm 101	8/20/15	< 1		
LOES-0820-6A	Logan ES	First Floor Hallway between restrooms (left)	8/20/15		15	Filter Installed.
LOES-0820-6B	Logan ES	First Floor Hallway between restrooms (left)	8/20/15		15	Filter Installed.
LOES-0820-7A	Logan ES	First Floor Hallway between restrooms (middle)	8/20/15		16	Filter Installed.
LOES-0820-7B	Logan ES	First Floor Hallway between restrooms (middle)	8/20/15		13	Filter Installed.
LOES-0820-8A	Logan ES	First Floor Hallway between restrooms (right)	8/20/15		320	Filter Installed.
LOES-0820-8B	Logan ES	First Floor Hallway between restrooms (right)	8/20/15	9.7		
LOES-0820-9A	Logan ES	First Floor inside cafeteria	8/20/15	< 1		
LOES-0820-9B	Logan ES	First Floor inside cafeteria	8/20/15	4		
<b>Percentage of Passed Samples</b>						<b>72.22%</b>
<b>Percentage of Failed Samples</b>						<b>27.78%</b>
LT-0505-1A	Ludlow Taylor ES	3rd floor inside Classroom 325	5/5/15	< 1		
LT-0505-1B	Ludlow Taylor ES	3rd floor inside Classroom 325	5/5/15	< 1		
LT-0505-2A	Ludlow Taylor ES	3rd floor inside Classroom 314	5/5/15	< 1		
LT-0505-2B	Ludlow Taylor ES	3rd floor inside Classroom 314	5/5/15	< 1		
LT-0505-3A	Ludlow Taylor ES	3rd floor inside Classroom 323	5/5/15	1.4		
LT-0505-3B	Ludlow Taylor ES	3rd floor inside Classroom 323	5/5/15	< 1		
LT-0505-4A	Ludlow Taylor ES	3rd floor inside Classroom 321	5/5/15	< 1		
LT-0505-4B	Ludlow Taylor ES	3rd floor inside Classroom 321	5/5/15	< 1		
LT-0505-5A	Ludlow Taylor ES	3rd floor hallway adjacent to Stairwell A (high)	5/5/15	< 1		
LT-0505-5B	Ludlow Taylor ES	3rd floor hallway adjacent to Stairwell A (high)	5/5/15	< 1		
LT-0505-6A	Ludlow Taylor ES	3rd floor hallway adjacent to Stairwell A (low)	5/5/15	< 1		
LT-0505-6B	Ludlow Taylor ES	3rd floor hallway adjacent to Stairwell A (low)	5/5/15	< 1		
LT-0505-7A	Ludlow Taylor ES	3rd floor inside Classroom 306	5/5/15	< 1		
LT-0505-7B	Ludlow Taylor ES	3rd floor inside Classroom 306	5/5/15	< 1		
LT-0505-8A	Ludlow Taylor ES	3rd floor inside Classroom 304	5/5/15	< 1		
LT-0505-8B	Ludlow Taylor ES	3rd floor inside Classroom 304	5/5/15	< 1		
LT-0505-9A	Ludlow Taylor ES	3rd floor inside Classroom 307	5/5/15	< 1		
LT-0505-9B	Ludlow Taylor ES	3rd floor inside Classroom 307	5/5/15	< 1		
LT-0505-10A	Ludlow Taylor ES	3rd floor hallway adjacent to Stairwell B (high)	5/5/15	< 1		
LT-0505-10B	Ludlow Taylor ES	3rd floor hallway adjacent to Stairwell B (high)	5/5/15	< 1		
LT-0505-11A	Ludlow Taylor ES	3rd floor hallway adjacent to Stairwell B (low)	5/5/15	< 1		
LT-0505-11B	Ludlow Taylor ES	3rd floor hallway adjacent to Stairwell B (low)	5/5/15	< 1		
LT-0505-12A	Ludlow Taylor ES	3rd floor inside Classroom 301	5/5/15	1.3		
LT-0505-12B	Ludlow Taylor ES	3rd floor inside Classroom 301	5/5/15	< 1		
LT-0505-13A	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell B (high)	5/5/15	< 1		
LT-0505-13B	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell B (high)	5/5/15	< 1		
LT-0505-14A	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell B (low)	5/5/15	< 1		
LT-0505-14B	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell B (low)	5/5/15	< 1		
LT-05-5-15A	Ludlow Taylor ES	2nd floor inside Classroom 200 near window	5/5/15	< 1		
LT-0505-15B	Ludlow Taylor ES	2nd floor inside Classroom 200 near window	5/5/15	< 1		
LT-0505-16A	Ludlow Taylor ES	2nd floor inside Classroom 200 near door	5/5/15	< 1		
LT-0505-16B	Ludlow Taylor ES	2nd floor inside Classroom 200 near door	5/5/15	< 1		
LT-0505-17A	Ludlow Taylor ES	2nd floor inside Classroom 204	5/5/15	< 1		
LT-0505-17B	Ludlow Taylor ES	2nd floor inside Classroom 204	5/5/15	< 1		
LT-0505-18A	Ludlow Taylor ES	2nd floor inside Classroom 207	5/5/15	1		
LT-0505-18B	Ludlow Taylor ES	2nd floor inside Classroom 207	5/5/15	< 1		
LT-0505-19A	Ludlow Taylor ES	2nd floor inside Classroom 206	5/5/15	< 1		
LT-0505-19B	Ludlow Taylor ES	2nd floor inside Classroom 206	5/5/15	< 1		
LT-0505-20A	Ludlow Taylor ES	2nd floor inside Classroom 210	5/5/15	< 1		
LT-0505-20B	Ludlow Taylor ES	2nd floor inside Classroom 210	5/5/15	< 1		
LT-0505-21A	Ludlow Taylor ES	2nd floor inside Classroom 212	5/5/15	< 1		
LT-0505-21B	Ludlow Taylor ES	2nd floor inside Classroom 212	5/5/15	< 1		
LT-0505-22A	Ludlow Taylor ES	2nd floor inside Classroom 217	5/5/15	< 1		

LT-0505-22B	Ludlow Taylor ES	2nd floor inside Classroom 217	5/5/15	< 1		
LT-0505-23A	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell A (high)	5/5/15	< 1		
LT-0505-23B	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell A (high)	5/5/15	< 1		
LT-0505-24A	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell A (low)	5/5/15	< 1		
LT-0505-24B	Ludlow Taylor ES	2nd floor hallway adjacent to Stairwell A (low)	5/5/15	< 1		
LT-0505-25A	Ludlow Taylor ES	2nd floor inside Classroom 216	5/5/15	< 1		
LT-0505-25B	Ludlow Taylor ES	2nd floor inside Classroom 216	5/5/15	< 1		
LT-0505-26A	Ludlow Taylor ES	2nd floor inside Classroom 223	5/5/15	< 1		
LT-0505-26B	Ludlow Taylor ES	2nd floor inside Classroom 223	5/5/15	< 1		
LT-0505-27A	Ludlow Taylor ES	2nd floor inside Workroom 215	5/5/15	7.7		
LT-0505-27B	Ludlow Taylor ES	2nd floor inside Workroom 215	5/5/15	< 1		
LT-0505-28A	Ludlow Taylor ES	1st floor hallway adjacent to Stairwell A (high)	5/5/15	< 1		
LT-0505-28B	Ludlow Taylor ES	1st floor hallway adjacent to Stairwell A (high)	5/5/15	< 1		
LT-0505-29A	Ludlow Taylor ES	1st floor hallway adjacent to Stairwell A (low)	5/5/15	< 1		
LT-0505-29B	Ludlow Taylor ES	1st floor hallway adjacent to Stairwell A (low)	5/5/15	< 1		
LT-0505-30A	Ludlow Taylor ES	1st floor inside Health Suite	5/5/15	< 1		
LT-0505-30B	Ludlow Taylor ES	1st floor inside Health Suite	5/5/15	< 1		
LT-0505-31A	Ludlow Taylor ES	1st floor hallway across from Multi-Purpose Room	5/5/15	< 1		
LT-0505-31B	Ludlow Taylor ES	1st floor hallway across from Multi-Purpose Room	5/5/15	< 1		
LT-0505-32A	Ludlow Taylor ES	2nd floor inside Classroom 201	5/5/15	< 1		
LT-0505-32B	Ludlow Taylor ES	2nd floor inside Classroom 201	5/5/15	< 1		
LT-0505-33A	Ludlow Taylor ES	1st floor inside Parent Center	5/5/15	1.4		
LT-0505-33B	Ludlow Taylor ES	1st floor inside Parent Center	5/5/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
LMHS-0811-1A	Luke C. Moore HS	First floor hallway adjacent to room 112 (high)	8/11/15	< 1		
LMHS-0811-1B	Luke C. Moore HS	First floor hallway adjacent to room 112 (high)	8/11/15	< 1		
LMHS-0811-2A	Luke C. Moore HS	First floor hallway adjacent to room 112 (low)	8/11/15	< 1		
LMHS-0811-2B	Luke C. Moore HS	First floor hallway adjacent to room 112 (low)	8/11/15	< 1		
LMHS-0811-3A	Luke C. Moore HS	Second hallway adjacent to women's room	8/11/15	< 1		
LMHS-0811-3B	Luke C. Moore HS	Second hallway adjacent to women's room	8/11/15	< 1		
LMHS-0811-4A	Luke C. Moore HS	Second hallway adjacent to men's room	8/11/15	< 1		
LMHS-0811-4B	Luke C. Moore HS	Second hallway adjacent to men's room	8/11/15	< 1		
LMHS-0811-5A	Luke C. Moore HS	Basement hallway adjacent to room B22 (high)	8/11/15	< 1		
LMHS-0811-5B	Luke C. Moore HS	Basement hallway adjacent to room B22 (high)	8/11/15	< 1		
LMHS-0811-6A	Luke C. Moore HS	Basement hallway adjacent to room B22 (low)	8/11/15	< 1		
LMHS-0811-6B	Luke C. Moore HS	Basement hallway adjacent to room B22 (low)	8/11/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
TES-0603-1A	M.L. King ES	3rd Floor hallway across class room 324 (high)	6/3/15	< 1		
TES-0603-1B	M.L. King ES	3rd Floor hallway across class room 324 (high)	6/3/15	< 1		
TES-0603-2A	M.L. King ES	3rd Floor hallway across class room 324 (low)	6/3/15	< 1		
TES-0603-2B	M.L. King ES	3rd Floor hallway across class room 324 (low)	6/3/15	< 1		
TES-0603-3A	M.L. King ES	3rd Floor hallway across class room 316 (high)	6/3/15	< 1		
TES-0603-3B	M.L. King ES	3rd Floor hallway across class room 316 (high)	6/3/15	< 1		
TES-0603-4A	M.L. King ES	3rd Floor hallway across class room 316 (low)	6/3/15	< 1		
TES-0603-4B	M.L. King ES	3rd Floor hallway across class room 316 (low)	6/3/15	< 1		
TES-0603-5A	M.L. King ES	3rd Floor hallway adjacent to room (high)	6/3/15	< 1		
TES-0603-5B	M.L. King ES	3rd Floor hallway adjacent to room (high)	6/3/15	< 1		
TES-0603-6A	M.L. King ES	3rd Floor hallway adjacent to room (low)	6/3/15	< 1		
TES-0603-6B	M.L. King ES	3rd Floor hallway adjacent to room (low)	6/3/15	< 1		
TES-0603-7A	M.L. King ES	3rd Floor hallway adjacent to janitor closet 302 (high)	6/3/15	< 1		
TES-0603-7B	M.L. King ES	3rd Floor hallway adjacent to janitor closet 302 (high)	6/3/15	< 1		
TES-0603-8A	M.L. King ES	3rd Floor hallway adjacent to janitor closet 302 (low)	6/3/15	< 1		
TES-0603-8B	M.L. King ES	3rd Floor hallway adjacent to janitor closet 302 (low)	6/3/15	< 1		

TES-0603-9A	M.L. King ES	2nd Floor hallway across room 203 (high)	6/3/15	< 1		
TES-0603-9B	M.L. King ES	2nd Floor hallway across room 203 (high)	6/3/15	< 1		
TES-0603-10A	M.L. King ES	2nd Floor hallway across room 203 (low)	6/3/15	< 1		
TES-0603-10B	M.L. King ES	2nd Floor hallway across room 203 (low)	6/3/15	< 1		
TES-0603-11A	M.L. King ES	2nd Floor hallway across library (high)	6/3/15	< 1		
TES-0603-11B	M.L. King ES	2nd Floor hallway across library (high)	6/3/15	< 1		
TES-0603-12A	M.L. King ES	2nd Floor hallway across library (low)	6/3/15	< 1		
TES-0603-12B	M.L. King ES	2nd Floor hallway across library (low)	6/3/15	< 1		
TES-0603-13A	M.L. King ES	2nd Floor hallway across stair B (high)	6/3/15	< 1		
TES-0603-13B	M.L. King ES	2nd Floor hallway across stair B (high)	6/3/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
MJH-1209-1A	MacFarland JHS	3rd floor hallway adjacent to classroom 300	12/9/14	< 1		
MJH-1209-2B	MacFarland JHS	3rd floor hallway adjacent to classroom 300	12/9/14	< 1		
MJH-1209-3A	MacFarland JHS	3rd floor hallway adjacent to classroom 302	12/9/14	< 1		
MJH-1209-4B	MacFarland JHS	3rd floor hallway adjacent to classroom 302	12/9/14	< 1		
MJH-1209-5A	MacFarland JHS	2nd floor hallway adjacent to classroom 203	12/9/14	< 1		
MJH-1209-6B	MacFarland JHS	2nd floor hallway adjacent to classroom 203	12/9/14	< 1		
MJH-1209-7A	MacFarland JHS	2nd floor hallway adjacent to classroom 252	12/9/14	< 1		
MJH-1209-8B	MacFarland JHS	2nd floor hallway adjacent to classroom 252	12/9/14	< 1		
MJH-1209-9A	MacFarland JHS	1st floor hallway adjacent to classroom 152	12/9/14	< 1		
MJH-1209-10B	MacFarland JHS	1st floor hallway adjacent to classroom 152	12/9/14	< 1		
MJH-1209-11A	MacFarland JHS	Basement floor inside Cafeteria	12/9/14	< 1		
MJH-1209-12B	MacFarland JHS	Basement floor inside Cafeteria	12/9/14	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
MXES-0819-1A	Malcolm X ES @ Green	Third Floor Hallway Adjacent to Rm 316	8/19/15	< 1		
MXES-0819-1B	Malcolm X ES @ Green	Third Floor Hallway Adjacent to Rm 316	8/19/15	< 1		
MXES-0819-2A	Malcolm X ES @ Green	Third Floor Hallway Adjacent to Rm 307	8/19/15	< 1		
MXES-0819-2B	Malcolm X ES @ Green	Third Floor Hallway Adjacent to Rm 307	8/19/15	< 1		
MXES-0819-3A	Malcolm X ES @ Green	Second Floor Hallway Adjacent to Rm 217	8/19/15	< 1		
MXES-0819-3B	Malcolm X ES @ Green	Second Floor Hallway Adjacent to Rm 217	8/19/15	3.6		
MXES-0819-4A	Malcolm X ES @ Green	Second Floor Hallway Adjacent to Rm 207	8/19/15	< 1		
MXES-0819-4B	Malcolm X ES @ Green	Second Floor Hallway Adjacent to Rm 207	8/19/15	< 1		
MXES-0819-5A	Malcolm X ES @ Green	Second Floor Hallway Adjacent to Rm 214	8/19/15	< 1		
MXES-0819-5B	Malcolm X ES @ Green	Second Floor Hallway Adjacent to Rm 214	8/19/15	< 1		
MXES-0819-6A	Malcolm X ES @ Green	First Floor Hallway Adjacent to Rm 130	8/19/15	4.7		
MXES-0819-6B	Malcolm X ES @ Green	First Floor Hallway Adjacent to Rm 130	8/19/15	2.2		
MXES-0819-7A	Malcolm X ES @ Green	First Floor inside Rm 131	8/19/15	< 1		
MXES-0819-7B	Malcolm X ES @ Green	First Floor inside Rm 131	8/19/15	< 1		
MXES-0819-8A	Malcolm X ES @ Green	First Floor Hallway Across Rm 132	8/19/15	< 1		
MXES-0819-8B	Malcolm X ES @ Green	First Floor Hallway Across Rm 132	8/19/15	< 1		
MXES-0819-9A	Malcolm X ES @ Green	First Floor inside multipurpose Room	8/19/15	< 1		
MXES-0819-9B	Malcolm X ES @ Green	First Floor inside multipurpose Room	8/19/15	< 1		
MXES-0819-10A	Malcolm X ES @ Green	First Floor Hallway Adjacent to Rm 115	8/19/15	< 1		
MXES-0819-10B	Malcolm X ES @ Green	First Floor Hallway Adjacent to Rm 115	8/19/15	< 1		
MXES-0819-11A	Malcolm X ES @ Green	First Floor Hallway Adjacent to Teacher's Lounge	8/19/15	< 1		
MXES-0819-11B	Malcolm X ES @ Green	First Floor Hallway Adjacent to Teacher's Lounge	8/19/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
MDL-4-21-1A	Mamie D Lee ES	CLASSROOM 20	4/21/15	< 1		
MDL-4-21-1B	Mamie D Lee ES	CLASSROOM 20	4/21/15	< 1		
MDL-4-21-2A	Mamie D Lee ES	CLASSROOM 21	4/21/15	< 1		
MDL-4-21-2B	Mamie D Lee ES	CLASSROOM 21	4/21/15	< 1		
MDL-4-21-3A	Mamie D Lee ES	CLASSROOM 22	4/21/15	8.2		

MDL-4-21-3B	Mamie D Lee ES	CLASSROOM 22	4/21/15	< 1		
MDL-4-21-4A	Mamie D Lee ES	CLASSROOM 23	4/21/15	< 1		
MDL-4-21-4B	Mamie D Lee ES	CLASSROOM 23	4/21/15	< 1		
MDL-4-21-5A	Mamie D Lee ES	CLASSROOM 24	4/21/15	< 1		
MDL-4-21-5B	Mamie D Lee ES	CLASSROOM 24	4/21/15	1.4		
MDL-4-21-6A	Mamie D Lee ES	CLASSROOM 25	4/21/15	< 1		
MDL-4-21-6B	Mamie D Lee ES	CLASSROOM 26	4/21/15	< 1		
MDL-4-21-7A	Mamie D Lee ES	CLASSROOM 27	4/21/15	< 1		
MDL-4-21-7B	Mamie D Lee ES	CLASSROOM 27	4/21/15	< 1		
MDL-4-21-8A	Mamie D Lee ES	CLASSROOM 28	4/21/15	< 1		
MDL-4-21-8B	Mamie D Lee ES	CLASSROOM 28	4/21/15	< 1		
MDL-4-21-9A	Mamie D Lee ES	CLASSROOM 29	4/21/15	< 1		
MDL-4-21-9B	Mamie D Lee ES	CLASSROOM 29	4/21/15	< 1		
MDL-4-21-10A	Mamie D Lee ES	CLASSROOM 19	4/21/15	< 1		
MDL-4-21-10B	Mamie D Lee ES	CLASSROOM 19	4/21/15	< 1		
MDL-4-21-11A	Mamie D Lee ES	CLASSROOM 18	4/21/15	< 1		
MDL-4-21-11B	Mamie D Lee ES	CLASSROOM 18	4/21/15	< 1		
MDL-4-21-12A	Mamie D Lee ES	CLASSROOM 16	4/21/15	< 1		
MDL-4-21-12B	Mamie D Lee ES	CLASSROOM 16	4/21/15	< 1		
MDL-4-21-13A	Mamie D Lee ES	CLASSROOM 17	4/21/15	< 1		
MDL-4-21-13B	Mamie D Lee ES	CLASSROOM 17	4/21/15	< 1		
MDL-4-21-14A	Mamie D Lee ES	CLASSROOM 15	4/21/15	< 1		
MDL-4-21-14B	Mamie D Lee ES	CLASSROOM 15	4/21/15	< 1		
MDL-4-21-15A	Mamie D Lee ES	CLASSROOM 14	4/21/15	< 1		
MDL-4-21-15B	Mamie D Lee ES	CLASSROOM 14	4/21/15	< 1		
MDL-4-21-16A	Mamie D Lee ES	CLASSROOM 14	4/21/15	< 1		
MDL-4-21-16B	Mamie D Lee ES	CLASSROOM 14	4/21/15	< 1		
MDL-4-21-17A	Mamie D Lee ES	1ST FLOOR CORRIDOR WEST	4/21/15	< 1		
MDL-4-21-17B	Mamie D Lee ES	1ST FLOOR CORRIDOR WEST	4/21/15	< 1		
MDL-4-21-18A	Mamie D Lee ES	CLASSROOM 13	4/21/15	< 1		
MDL-4-21-18B	Mamie D Lee ES	CLASSROOM 13	4/21/15	< 1		
MDL-4-21-19A	Mamie D Lee ES	CLASSROOM 12	4/21/15	< 1		
MDL-4-21-19B	Mamie D Lee ES	CLASSROOM 12	4/21/15	< 1		
MDL-4-21-20A	Mamie D Lee ES	CLASSROOM 11	4/21/15	< 1		
MDL-4-21-20B	Mamie D Lee ES	CLASSROOM 11	4/21/15	< 1		
MDL-4-21-21A	Mamie D Lee ES	CLASSROOM 10	4/21/15	< 1		
MDL-4-21-21B	Mamie D Lee ES	CLASSROOM 10	4/21/15	< 1		
MDL-4-21-22A	Mamie D Lee ES	2ND FLOOR CORRIDOR WEST	4/21/15	< 1		
MDL-4-21-22B	Mamie D Lee ES	2ND FLOOR CORRIDOR WEST	4/21/15	< 1		
MDL-4-21-23A	Mamie D Lee ES	DENTAL/NURSES OFFICE	4/21/15	< 1		
MDL-4-21-23B	Mamie D Lee ES	DENTAL/NURSES OFFICE	4/21/15	< 1		
MDL-4-21-24A	Mamie D Lee ES	KITCHEN	4/21/15	< 1		
MDL-4-21-24B	Mamie D Lee ES	KITCHEN	4/21/15	< 1		
MDL-4-21-25A	Mamie D Lee ES	CAFETERIA	4/21/15	< 1		
MDL-4-21-25B	Mamie D Lee ES	CAFETERIA	4/21/15	< 1		
MDL-4-21-26A	Mamie D Lee ES	1ST FLOOR EAST CORRIDOR	4/21/15	< 1		
MDL-4-21-26B	Mamie D Lee ES	1ST FLOOR EAST CORRIDOR	4/21/15	< 1		
					<b>Percentage of Passed Samples</b>	<b>100.00%</b>
					<b>Percentage of Failed Samples</b>	<b>0.00%</b>
ME-0622-1A	Mann ES	2nd Floor hallway adjacent to room 229	6/22/15	< 1		
ME-0622-1B	Mann ES	2nd Floor hallway adjacent to room 229	6/22/15	< 1		
ME-0622-2A	Mann ES	2nd Floor hallway adjacent to room 235	6/22/15	< 1		
ME-0622-2B	Mann ES	2nd Floor hallway adjacent to room 235	6/22/15	< 1		
ME-0622-3A	Mann ES	2nd Floor hallway adjacent to room 226	6/22/15	< 1		
ME-0622-3B	Mann ES	2nd Floor hallway adjacent to room 226	6/22/15	< 1		

ME-0622-4A	Mann ES	1st Floor adjacent to room 156 A	6/22/15	< 1		
ME-0622-4B	Mann ES	1st Floor hallway adjacent to room 156A	6/22/15	< 1		
ME-0622-5A	Mann ES	1st Floor hallway adjacent to room 150	6/22/15	< 1		
ME-0622-5B	Mann ES	1st Floor hallway adjacent to room 150	6/22/15	< 1		
ME-0622-6A	Mann ES	1st Floor inside classroom 138	6/22/15	< 1		
ME-0622-6B	Mann ES	1st Floor inside classroom 138	6/22/15	< 1		
ME-0622-7A	Mann ES	1st Floor inside classroom 142	6/22/15	< 1		
ME-0622-7B	Mann ES	1st Floor inside classroom 142	6/22/15	< 1		
ME-0622-8A	Mann ES	1st Floor inside classroom 146	6/22/15	< 1		
ME-0622-8B	Mann ES	1st Floor inside classroom 146	6/22/15	< 1		
ME-0622-9A	Mann ES	1st Floor inside classroom 150	6/22/15	< 1		
ME-0622-9B	Mann ES	1st Floor inside classroom 150	6/22/15	< 1		
ME-0622-10A	Mann ES	1st Floor inside classroom 154	6/22/15	< 1		
ME-0622-10B	Mann ES	1st Floor inside classroom 154	6/22/15	< 1		
ME-0622-11A	Mann ES	1st Floor hallway adjacent to health suite 157B	6/22/15	< 1		
ME-0622-11B	Mann ES	1st Floor hallway adjacent to health suite 157B	6/22/15	< 1		
ME-0622-12A	Mann ES	1st Floor hallway adjacent to room 134	6/22/15	< 1		
ME-0622-12B	Mann ES	1st Floor hallway adjacent to room 134	6/22/15	< 1		
ME-0622-13A	Mann ES	3rd Floor hallway adjacent to Room 303	6/22/15	< 1		
ME-0622-13B	Mann ES	3rd Floor hallway adjacent to Room 303	6/22/15	< 1		
ME-0622-14A	Mann ES	3rd Floor hallway adjacent to Elevator Machine room 317	6/22/15	< 1		
ME-0622-14B	Mann ES	3rd Floor hallway adjacent to Elevator Machine room 317	6/22/15	< 1		
			<b>Percentage of Passed Samples</b>			<b>100.00%</b>
			<b>Percentage of Failed Samples</b>			<b>0.00%</b>
MR-1210-1A	Marie Reed LC	2nd floor adjacent to Teacher's Room	12/10/14	< 1		
MR-1210-2B	Marie Reed LC	2nd floor adjacent to Teacher's Room	12/10/14	< 1		
MR-1210-3A	Marie Reed LC	2nd floor adjacent to Electric Box H2-WA	12/10/14	< 1		
MR-1210-4B	Marie Reed LC	2nd floor adjacent to Electric Box H2-WA	12/10/14	< 1		
MR-1210-5A	Marie Reed LC	2nd floor adjacent to Custodian Closet 4	12/10/14	< 1		
MR-1210-6B	Marie Reed LC	2nd floor adjacent to Custodian Closet 4	12/10/14	< 1		
MR-1210-7A	Marie Reed LC	2nd floor near Arts and Science Room 1	12/10/14	< 1		
MR-1210-8B	Marie Reed LC	2nd floor near Arts and Science Room 1	12/10/14	< 1		
MR-1210-9A	Marie Reed LC	2nd floor adjacent to Custodian Closet 1	12/10/14	< 1		
MR-1210-10B	Marie Reed LC	2nd floor adjacent to Custodian Closet 1	12/10/14	< 1		
MR-1210-11A	Marie Reed LC	2nd floor near Arts and Science Room 6	12/10/14	< 1		
MR-1210-12B	Marie Reed LC	2nd floor near Arts and Science Room 6	12/10/14	< 1		
MR-1210-13A	Marie Reed LC	2nd floor near Arts and Science Room 7	12/10/14	< 1		
MR-1210-14B	Marie Reed LC	2nd floor near Arts and Science Room 7	12/10/14	< 1		
MR-1210-15A	Marie Reed LC	2nd floor adjacent to Custodian Closet 2	12/10/14	< 1		
MR-1210-16B	Marie Reed LC	2nd floor adjacent to Custodian Closet 2	12/10/14	< 1		
MR-1210-17A	Marie Reed LC	1st floor inside small Cafeteria	12/10/14	< 1		
MR-1210-18B	Marie Reed LC	1st floor inside small Cafeteria	12/10/14	< 1		
MR-1210-19A	Marie Reed LC	1st floor near Main Office	12/10/14	< 1		
MR-1210-20B	Marie Reed LC	1st floor near Main Office	12/10/14	< 1		
MR-1210-21A	Marie Reed LC	1st floor inside Main Office adj to Principal's Office	12/10/14	< 1		
MR-1210-22B	Marie Reed LC	1st floor inside Main Office adj to Principal's Office	12/10/14	1.8		
MR-1210-23A	Marie Reed LC	1st floor at Main Entrance	12/10/14	< 1		
MR-1210-24B	Marie Reed LC	1st floor at Main Entrance	12/10/14	< 1		
MR-1210-25A	Marie Reed LC	Basement floor adjacent to Boy's Room	12/10/14	1.4		
MR-1210-26B	Marie Reed LC	Basement floor adjacent to Boy's Room	12/10/14	< 1		
MR-1210-27A	Marie Reed LC	Basement floor adjacent to Girl's Room	12/10/14	< 1		
MR-1210-28B	Marie Reed LC	Basement floor adjacent to Girl's Room	12/10/14	< 1		
MR-1210-29A	Marie Reed LC	Basement floor inside Gym	12/10/14	< 1		
MR-1210-30B	Marie Reed LC	Basement floor inside Gym	12/10/14	< 1		
MR-1210-31A	Marie Reed LC	1st floor at entrance to large Cafeteria	12/10/14	< 1		

MR-1210-32B	Marie Reed LC	1st floor at entrance to large Cafeteria	12/10/14	< 1		
MR-1210-33A	Marie Reed LC	Basement floor adjacent to Girl's Dressing Room	12/10/14	2.5		
MR-1210-34B	Marie Reed LC	Basement floor adjacent to Girl's Dressing Room	12/10/14	2.8		
MR-1210-35A	Marie Reed LC	1st floor across from Storage Room 11	12/10/14	< 1		
MR-1210-36B	Marie Reed LC	1st floor across from Storage Room 11	12/10/14	< 1		
MR-1210-37A	Marie Reed LC	1st floor between Stairwell 7 and sink	12/10/14	< 1		
MR-1210-38B	Marie Reed LC	1st floor between Stairwell 7 and sink	12/10/14	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
MES-1231-1A	Maury ES	1st Floor Hallway adjacent to E121	12/31/14	< 1		
MES-1231-2B	Maury ES	1st floor hallway adjacent to E121	12/31/14	< 1		
MES-1231-3A	Maury ES	1st floor inside Multipurpose room adjacent to Kitchen	12/31/14	< 1		
MES-1231-4B	Maury ES	1st floor inside Multipurpose room adjacent to Kitchen	12/31/14	< 1		
MES-1231-5A	Maury ES	1st Floor inside Classroom E125	12/31/14	< 1		
MES-1231-6B	Maury ES	1st Floor inside Classroom E125	12/31/14	< 1		
MES-1231-7A	Maury ES	1st Floor inside Classroom E140	12/31/14	< 1		
MES-1231-8B	Maury ES	1st Floor inside Classroom E140	12/31/14	< 1		
MES-1231-9A	Maury ES	1st Floor inside Classroom E135	12/31/14	< 1		
MES-1231-10B	Maury ES	1st Floor inside Classroom E135	12/31/14	< 1		
MES-1231-11A	Maury ES	Basement Floor inside Classroom W010	12/31/14	< 1		
MES-1231-12B	Maury ES	Basement Floor inside Classroom W010	12/31/14	< 1		
MES-1231-13A	Maury ES	Basement Floor inside Classroom W030	12/31/14	< 1		
MES-1231-14B	Maury ES	Basement Floor inside Classroom W030	12/31/14	< 1		
MES-1231-15A	Maury ES	Basement floor lobby adjacent to Storage room W022 (high)	12/31/14	< 1		
MES-1231-16B	Maury ES	Basement floor lobby adjacent to Storage room W022 (high)	12/31/14	1.1		
MES-1231-17A	Maury ES	Basement floor lobby adjacent to Storage room W022 (low)	12/31/14	1.2		
MES-1231-18B	Maury ES	Basement floor lobby adjacent to Storage room W022 (low)	12/31/14	< 1		
MES-1231-19A	Maury ES	1st Floor in Stairwell ST4	12/31/14	< 1		
MES-1231-20B	Maury ES	1st Floor in Stairwell ST4	12/31/14	< 1		
MES-1231-21A	Maury ES	2nd Floor in Stairwell ST4	12/31/14	< 1		
MES-1231-22B	Maury ES	2nd Floor in Stairwell ST4	12/31/14	< 1		
MES-1231-23A	Maury ES	2nd Floor Hallway adjacent to Class room E213	12/31/14	< 1		
MES-1231-24B	Maury ES	2nd Floor Hallway adjacent to Class room E213	12/31/14	< 1		
MES-1231-25A	Maury ES	2nd Floor inside Classroom E230	12/31/14	< 1		
MES-1231-26B	Maury ES	2nd Floor inside Classroom E230	12/31/14	< 1		
MES-1231-27A	Maury ES	2nd Floor inside Classroom E240	12/31/14	< 1		
MES-1231-28B	Maury ES	2nd Floor inside Classroom E240	12/31/14	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
MRL-0713-1A	Marie Reed LC	First floor hallway near the main entrance on the left	7/13/15	< 1		
MRL-0713-1B	Marie Reed LC	First floor hallway near the main entrance on the left	7/13/15	< 1		
MRL-0713-2A	Marie Reed LC	First floor hallway near the general office & girls rest room	7/13/15	< 1		
MRL-0713-2B	Marie Reed LC	First floor hallway near the general office & girls rest room	7/13/15	< 1		
MRL-0713-3A	Marie Reed LC	First floor Inside small cafeteria	7/13/15	1.3		
MRL-0713-3B	Marie Reed LC	First floor hallway small cafeteria	7/13/15	1.1		
MRL-0713-4A	Marie Reed LC	First floor near Auditorium entrance	7/13/15	< 1		
MRL-0713-4B	Marie Reed LC	First floor near Auditorium entrance	7/13/15	< 1		
MRL-0713-5A	Marie Reed LC	First floor early childhood	7/13/15	< 1		
MRL-0713-5B	Marie Reed LC	First floor early childhood	7/13/15	< 1		
MRL-0713-6A	Marie Reed LC	First floor early childhood across storage 11	7/13/15	< 1		
MRL-0713-6B	Marie Reed LC	First floor early childhood across storage 11	7/13/15	< 1		
MRL-0713-7A	Marie Reed LC	First floor inside main office	7/13/15	< 1		
MRL-0713-7B	Marie Reed LC	First floor inside main office	7/13/15	2.1		
MRL-0713-8A	Marie Reed LC	Second floor near stairwell 1	7/13/15	< 1		
MRL-0713-8B	Marie Reed LC	Second floor near stairwell 1	7/13/15	< 1		

MRL-0713-9A	Marie Reed LC	Second floor near stairwell 2	7/13/15	< 1		
MRL-0713-9B	Marie Reed LC	Second floor near stairwell 2	7/13/15	< 1		
MRL-0713-10A	Marie Reed LC	Second floor near stairwell 3	7/13/15	< 1		
MRL-0713-10B	Marie Reed LC	Second floor near stairwell 3	7/13/15	< 1		
MRL-0713-11A	Marie Reed LC	Second floor near stairwell 4	7/13/15	< 1		
MRL-0713-11B	Marie Reed LC	Second floor near stairwell 4	7/13/15	< 1		
MRL-0713-12A	Marie Reed LC	Second floor near stairwell 5	7/13/15	2		
MRL-0713-12B	Marie Reed LC	Second floor near stairwell 5	7/13/15	11		
MRL-0713-13A	Marie Reed LC	Second floor near stairwell 6	7/13/15	< 1		
MRL-0713-13B	Marie Reed LC	Second floor near stairwell 6	7/13/15	< 1		
MRL-0713-14A	Marie Reed LC	Second floor near stairwell 7	7/13/15	< 1		
MRL-0713-14B	Marie Reed LC	Second floor near stairwell 7	7/13/15	< 1		
MRL-0713-15A	Marie Reed LC	Second floor near stairwell 8	7/13/15	< 1		
MRL-0713-15B	Marie Reed LC	Second floor near stairwell 8	7/13/15	< 1		
MRL-0713-16A	Marie Reed LC	Auditorium music practice	7/13/15	3.1		
MRL-0713-16B	Marie Reed LC	Auditorium music practice	7/13/15	3.3		
MRL-0713-17A	Marie Reed LC	Medical clinic near reception	7/13/15	< 1		
MRL-0713-17B	Marie Reed LC	Medical clinic near reception	7/13/15	1.4		
MRL-0713-18A	Marie Reed LC	Rear of the clinic near women's rest room	7/13/15	1.2		
MRL-0713-18B	Marie Reed LC	Rear of the clinic near women's rest room	7/13/15	2.1		
MRL-0713-19A	Marie Reed LC	UPO	7/13/15	5.9		
MRL-0713-19B	Marie Reed LC	UPO	7/13/15		18	Filter Installed
MRL-0713-20A	Marie Reed LC	Swimming pool	7/13/15	< 1		
MRL-0713-20B	Marie Reed LC	Swimming pool	7/13/15	< 1		
MRL-0713-21A	Marie Reed LC	Swimming pool near men's rest room	7/13/15	1.3		
MRL-0713-21B	Marie Reed LC	Swimming pool near men's rest room	7/13/15	1.4		
MRL-0713-22A	Marie Reed LC	Swimming pool inside men's locker room	7/13/15	4.4		
MRL-0713-22B	Marie Reed LC	Swimming pool inside men's locker room	7/13/15	7.3		
MRL-0713-23A	Marie Reed LC	Outside Sockerfield ( high)	7/13/15	1.1		
MRL-0713-23B	Marie Reed LC	Outside Sockerfield (high)	7/13/15	< 1		
MRL-0713-24A	Marie Reed LC	Outside Sockerfield(low)	7/13/15	< 1		
MRL-0713-24B	Marie Reed LC	Outside Sockerfield(low)	7/13/15	< 1		
MRL-0713-25A	Marie Reed LC	Recreation center gym	7/13/15	< 1		
MRL-0713-25B	Marie Reed LC	Recreation center gym	7/13/15	< 1		
MRL-0713-26A	Marie Reed LC	Near mail rest room	7/13/15	2.5		
MRL-0713-26B	Marie Reed LC	Near mail rest room	7/13/15	3.3		
MRL-0713-27A	Marie Reed LC	Near women's rest room outside the gym	7/13/15	< 1		
MRL-0713-27B	Marie Reed LC	Near women's rest room outside the gym	7/13/15	< 1		
<b>Percentage of Passed Samples</b>						<b>98.15%</b>
<b>Percentage of Failed Samples</b>						<b>1.85%</b>
MH-0326-1A	McKinley HS	3rd Floor hallway across classroom 366	3/26/15	< 1		
MH-0326-1B	McKinley HS	3rd Floor hallway across classroom 366	3/26/15	< 1		
MH-0326-2A	McKinley HS	3rd Floor hallway across classroom 3370-A	3/26/15	< 1		
MH-0326-2B	McKinley HS	3rd Floor hallway across classroom 3370-A	3/26/15	< 1		
MH-0326-3A	McKinley HS	2nd Floor hallway across classroom 266-B	3/26/15	< 1		
MH-0326-3B	McKinley HS	2nd Floor hallway across classroom 266-B	3/26/15	< 1		
MH-0326-4A	McKinley HS	2nd Floor hallway across classroom 266-A	3/26/15	< 1		
MH-0326-4B	McKinley HS	2nd Floor hallway across classroom 266-A	3/26/15	< 1		
MH-0326-5A	McKinley HS	1st Floor hallway across classroom 158	3/26/15	< 1		
MH-0326-5B	McKinley HS	1st Floor hallway across classroom 158	3/26/15	< 1		
MH-0326-6A	McKinley HS	1st Floor hallway girl's rest room adjacent to room 159	3/26/15	< 1		
MH-0326-6B	McKinley HS	1st Floor hallway girl's rest room adjacent to room 159	3/26/15	< 1		
MH-0326-7A	McKinley HS	2nd Floor hallway at Gym (high)	3/26/15	< 1		
MH-0326-7B	McKinley HS	2nd Floor hallway at Gym (high)	3/26/15	< 1		
MH-0326-8A	McKinley HS	1st Floor hallway at Gym (high)	3/26/15	< 1		

MH-0326-8B	McKinley HS	1st Floor hallway at Gym (high)	3/26/15	< 1		
MH-0326-9A	McKinley HS	1st Floor hallway at Gym (low)	3/26/15	< 1		
MH-0326-9B	McKinley HS	1st Floor hallway at Gym (low)	3/26/15	< 1		
MH-0326-10A	McKinley HS	1st Floor hallway across room G103 (high)	3/26/15	< 1		
MH-0326-10B	McKinley HS	1st Floor hallway across room G103 (high)	3/26/15	< 1		
MH-0326-11A	McKinley HS	1st Floor hallway across room G103 (low)	3/26/15	< 1		
MH-0326-11B	McKinley HS	1st Floor hallway across room G103 (low)	3/26/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
MM-0326-1A	McKinley MS	1st Floor hallway in all purpose room adjacent to room 114C (high)	3/26/15	< 1		
MM-0326-1B	McKinley MS	1st Floor hallway in all purpose room adjacent to room 114C (high)	3/26/15	< 1		
MM-0326-2A	McKinley MS	1st Floor hallway in all purpose room adjacent to room 114C (low)	3/26/15	< 1		
MM-0326-2B	McKinley MS	1st Floor hallway in all purpose room adjacent to room 114C (low)	3/26/15	< 1		
MM-0326-3A	McKinley MS	1st floor hallway adjacent to room 114F (high)	3/26/15	< 1		
MM-0326-3B	McKinley MS	1st floor hallway adjacent to room 114F (high)	3/26/15	< 1		
MM-0326-4A	McKinley MS	1st floor hallway adjacent to room 114F (low)	3/26/15	< 1		
MM-0326-4B	McKinley MS	1st floor hallway adjacent to room 114F (low)	3/26/15	< 1		
MM-0326-5A	McKinley MS	1st Floor hallway across 115F (high)	3/26/15	< 1		
MM-0326-5B	McKinley MS	1st Floor hallway across 115F (high)	3/26/15	< 1		
MM-0326-6A	McKinley MS	1st Floor hallway across 115F (low)	3/26/15	< 1		
MM-0326-6B	McKinley MS	1st Floor hallway across 115F (low)	3/26/15	< 1		
MM-0326-7A	McKinley MS	3rd Floor hallway adjacent to room 302 (high)	3/26/15	< 1		
MM-0326-7B	McKinley MS	3rd Floor hallway adjacent to room 302 (high)	3/26/15	< 1		
MM-0326-8A	McKinley MS	3rd Floor hallway adjacent to room 302 (low)	3/26/15	< 1		
MM-0326-8B	McKinley MS	3rd Floor hallway adjacent to room 302 (low)	3/26/15	< 1		
MM-0326-9A	McKinley MS	2nd Floor hallway adjacent to room 202 (high)	3/26/15	< 1		
MM-0326-9B	McKinley MS	2nd Floor hallway adjacent to room 202 (high)	3/26/15	< 1		
MM-0326-10A	McKinley MS	2nd Floor hallway adjacent to room 202 (low)	3/26/15	< 1		
MM-0326-10B	McKinley MS	2nd Floor hallway adjacent to room 202 (low)	3/26/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
EME-0708-1A	Meyer ES	Second Floor hallway adjacent to Rm 215	7/8/15	< 1		
EME-0708-1B	Meyer ES	Second Floor hallway adjacent to Rm 215	7/8/15	< 1		
EME0708-2A	Meyer ES	Second Floor hallway adjacent to women's rest room near Rm 205	7/8/15	< 1		
EME-0708-2B	Meyer ES	Second Floor hallway adjacent to women's rest room near Rm 205	7/8/15	< 1		
EME-0708-3A	Meyer ES	First Floor hallway adjacent to Rm 143	7/8/15	< 1		
EME-0708-3B	Meyer ES	First Floor hallway adjacent to Rm 143	7/8/15	< 1		
EME-0708-4A	Meyer ES	First Floor hallway adjacent to women's & men's rest rooms	7/8/15	< 1		
EME-0708-4B	Meyer ES	First Floor hallway adjacent to women's & men's rest rooms	7/8/15	< 1		
EME-0708-5A	Meyer ES	First Floor Hallway across Rm 115	7/8/15	< 1		
EME-0708-5B	Meyer ES	First Floor Hallway across Rm 115	7/8/15	< 1		
EME-0708-6A	Meyer ES	Basement Hallway adjacent to rest rooms near Rm 5	7/8/15	< 1		
EME-0708-6B	Meyer ES	Basement Hallway adjacent to rest rooms near Rm 5	7/8/15	< 1		
EME-0708-7A	Meyer ES	Basement hallway across Rm14	7/8/15	< 1		
EME-0708-7B	Meyer ES	Basement hallway across Rm14	7/8/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
MES-0326-1A	Miner ES	2nd floor hallway adjacent to Boy's Room across from Room 209 (high)	3/26/15	< 1		
MES-0326-1B	Miner ES	2nd floor hallway adjacent to Boy's Room across from Room 209 (high)	3/26/15	< 1		
MES-0326-2A	Miner ES	2nd floor hallway adjacent to Boy's Room across from Room 209 (low)	3/26/15	< 1		
MES-0326-2B	Miner ES	2nd floor hallway adjacent to Boy's Room across from Room 209 (low)	3/26/15	< 1		

MES-0326-3A	Miner ES	2nd floor inside Classroom 215	3/26/15	< 1		
MES-0326-3B	Miner ES	2nd floor inside Classroom 215	3/26/15	< 1		
MES-0326-4A	Miner ES	2nd floor inside Classroom 217	3/26/15	< 1		
MES-0326-4B	Miner ES	2nd floor inside Classroom 217	3/26/15	< 1		
MES-0326-5A	Miner ES	2nd floor inside Classroom 219	3/26/15	< 1		
MES-0326-5B	Miner ES	2nd floor inside Classroom 219	3/26/15	< 1		
MES-0326-6A	Miner ES	2nd floor inside Classroom 213	3/26/15	< 1		
MES-0326-6B	Miner ES	2nd floor inside Classroom 213	3/26/15	< 1		
MES-0326-7A	Miner ES	2nd floor inside Classroom 231	3/26/15	< 1		
MES-0326-7B	Miner ES	2nd floor inside Classroom 231	3/26/15	< 1		
MES-0326-8A	Miner ES	2nd floor inside Classroom 233	3/26/15	< 1		
MES-0326-8B	Miner ES	2nd floor inside Classroom 233	3/26/15	< 1		
MES-0326-9A	Miner ES	2nd floor inside Classroom 251	3/26/15	< 1		
MES-0326-9B	Miner ES	2nd floor inside Classroom 251	3/26/15	< 1		
MES-0326-10A	Miner ES	2nd floor hallway adjacent to Room 228 Planning, in open area	3/26/15	< 1		
MES-0326-10B	Miner ES	2nd floor hallway adjacent to Room 228 Planning, in open area	3/26/15	< 1		
MES-0326-11A	Miner ES	2nd floor inside Classroom 253	3/26/15	< 1		
MES-0326-11B	Miner ES	2nd floor inside Classroom 253	3/26/15	< 1		
MES-0326-12A	Miner ES	2nd floor inside Classroom 234	3/26/15	< 1		
MES-0326-12B	Miner ES	2nd floor inside Classroom 234	3/26/15	< 1		
MES-0326-13A	Miner ES	2nd floor inside Classroom 238	3/26/15		89	Filter Installed
MES-0326-13B	Miner ES	2nd floor inside Classroom 238	3/26/15	5.1		
MES-0326-14A	Miner ES	2nd floor hallway across from Art Room 255 (high)	3/26/15	< 1		
MES-0326-14B	Miner ES	2nd floor hallway across from Art Room 255 (high)	3/26/15	< 1		
MES-0326-15A	Miner ES	2nd floor hallway across from Art Room 255 (low)	3/26/15	< 1		
MES-0326-15B	Miner ES	2nd floor hallway across from Art Room 255 (low)	3/26/15	< 1		
MES-0326-16A	Miner ES	2nd floor inside Classroom 211	3/26/15	< 1		
MES-0326-16B	Miner ES	2nd floor inside Classroom 211	3/26/15	< 1		
MES-0326-17A	Miner ES	2nd floor inside Classroom 209	3/26/15	< 1		
MES-0326-17B	Miner ES	2nd floor inside Classroom 209	3/26/15	< 1		
MES-0326-18A	Miner ES	1st floor hallway across from Cafeteria (high)	3/26/15	< 1		
MES-0326-18B	Miner ES	1st floor hallway across from Cafeteria (high)	3/26/15	< 1		
MES-0326-19A	Miner ES	1st floor hallway across from Cafeteria (low)	3/26/15	< 1		
MES-0326-19B	Miner ES	1st floor hallway across from Cafeteria (low)	3/26/15	< 1		
MES-0326-20A	Miner ES	1st floor hallway across from Gym (high)	3/26/15	< 1		
MES-0326-20B	Miner ES	1st floor hallway across from Gym (high)	3/26/15	< 1		
MES-0326-21A	Miner ES	1st floor hallway across from Gym (low)	3/26/15	< 1		
MES-0326-21B	Miner ES	1st floor hallway across from Gym (low)	3/26/15	< 1		
MES-0326-22A	Miner ES	1st floor inside Classroom 132	3/26/15	< 1		
MES-0326-22B	Miner ES	1st floor inside Classroom 132	3/26/15	< 1		
MES-0326-23A	Miner ES	1st floor inside Classroom 130	3/26/15	< 1		
MES-0326-23B	Miner ES	1st floor inside Classroom 130	3/26/15	< 1		
MES-0326-24A	Miner ES	1st floor inside Classroom 137	3/26/15	< 1		
MES-0326-24B	Miner ES	1st floor inside Classroom 137	3/26/15	< 1		
MES-0326-25A	Miner ES	1st floor inside Classroom 135	3/26/15	< 1		
MES-0326-25B	Miner ES	1st floor inside Classroom 135	3/26/15	< 1		
MES-0326-26A	Miner ES	1st floor inside Classroom 133	3/26/15	< 1		
MES-0326-26B	Miner ES	1st floor inside Classroom 133	3/26/15	< 1		
MES-0326-27A	Miner ES	1st floor inside Classroom 131	3/26/15	< 1		
MES-0326-27B	Miner ES	1st floor inside Classroom 131	3/26/15	< 1		
MES-0326-28A	Miner ES	1st floor inside Classroom 129	3/26/15	< 1		
MES-0326-28B	Miner ES	1st floor inside Classroom 129	3/26/15	< 1		
MES-0326-29A	Miner ES	1st floor inside Classroom 127	3/26/15	< 1		
MES-0326-29B	Miner ES	1st floor inside Classroom 127	3/26/15	< 1		
MES-0326-30A	Miner ES	1st floor inside Classroom 121	3/26/15	< 1		

MES-0326-30B	Miner ES	1st floor inside Classroom 121	3/26/15	< 1		
MES-0326-31A	Miner ES	1st floor inside Classroom 117	3/26/15	< 1		
MES-0326-31B	Miner ES	1st floor inside Classroom 117	3/26/15	< 1		
MES-0326-32A	Miner ES	1st floor inside Classroom 123	3/26/15	< 1		
MES-0326-32B	Miner ES	1st floor inside Classroom 123	3/26/15	< 1		
MES-0326-33A	Miner ES	1st floor inside Classroom 119	3/26/15	< 1		
MES-0326-33B	Miner ES	1st floor inside Classroom 119	3/26/15	< 1		
MES-0326-34A	Miner ES	1st floor inside Classroom 115	3/26/15	< 1		
MES-0326-34B	Miner ES	1st floor inside Classroom 115	3/26/15	< 1		
MES-0326-35A	Miner ES	1st floor inside Classroom 101	3/26/15	< 1		
MES-0326-35B	Miner ES	1st floor inside Classroom 101	3/26/15	< 1		
MES-0326-36A	Miner ES	1st floor inside Classroom 103	3/26/15	< 1		
MES-0326-36B	Miner ES	1st floor inside Classroom 103	3/26/15	< 1		
MES-0326-37A	Miner ES	1st floor hallway adjacent to Room 112 Kitchen/Laundry in open area	3/26/15	< 1		
MES-0326-37B	Miner ES	1st floor hallway adjacent to Room 112 Kitchen/Laundry in open area	3/26/15	< 1		
MES-0326-38A	Miner ES	1st floor inside Classroom 105	3/26/15	< 1		
MES-0326-38B	Miner ES	1st floor inside Classroom 105	3/26/15	< 1		
MES-0326-39A	Miner ES	1st floor inside Classroom 107	3/26/15	< 1		
MES-0326-39B	Miner ES	1st floor inside Classroom 107	3/26/15	< 1		
MES-0326-40A	Miner ES	1st floor inside Classroom 109	3/26/15	< 1		
MES-0326-40B	Miner ES	1st floor inside Classroom 109	3/26/15	< 1		
MES-0326-41A	Miner ES	1st floor inside Classroom 111	3/26/15	< 1		
MES-0326-41B	Miner ES	1st floor inside Classroom 111	3/26/15	< 1		
<b>Percentage of Passed Samples</b>						<b>98.78%</b>
<b>Percentage of Failed Samples</b>						<b>1.22%</b>
MES-0303-1A	Moten ES	3rd floor hallway adjacent to Janitor's Closet 319	3/3/15	< 1		
MES-0303-1B	Moten ES	3rd floor hallway adjacent to Janitor's Closet 319	3/3/15	< 1		
MES-0303-2A	Moten ES	3rd floor hallway adjacent to Classroom 327	3/3/15	< 1		
MES-0303-2B	Moten ES	3rd floor hallway adjacent to Classroom 327	3/3/15	< 1		
MES-0303-3A	Moten ES	3rd floor hallway adjacent to Boy's Room 314 (high)	3/3/15	< 1		
MES-0303-3B	Moten ES	3rd floor hallway adjacent to Boy's Room 314 (high)	3/3/15	< 1		
MES-0303-4A	Moten ES	3rd floor hallway adjacent to Boy's Room 314 (low)	3/3/15	< 1		
MES-0303-4B	Moten ES	3rd floor hallway adjacent to Boy's Room 314 (low)	3/3/15	1.8		
MES-0303-5A	Moten ES	3rd floor hallway adjacent to Girl's Room 301 (high)	3/3/15	< 1		
MES-0303-5B	Moten ES	3rd floor hallway adjacent to Girl's Room 301 (high)	3/3/15	< 1		
MES-0303-6A	Moten ES	3rd floor hallway adjacent to Girl's Room 301 (low)	3/3/15	< 1		
MES-0303-6B	Moten ES	3rd floor hallway adjacent to Girl's Room 301 (low)	3/3/15	< 1		
MES-0303-7A	Moten ES	2nd floor hallway adjacent to Girl's Room 202 (high)	3/3/15	< 1		
MES-0303-7B	Moten ES	2nd floor hallway adjacent to Girl's Room 202 (high)	3/3/15	< 1		
MES-0303-8A	Moten ES	2nd floor hallway adjacent to Girl's Room 202 (low)	3/3/15	< 1		
MES-0303-8B	Moten ES	2nd floor hallway adjacent to Girl's Room 202 (low)	3/3/15	< 1		
MES-0303-9A	Moten ES	2nd floor hallway adjacent to Boy's Room 211 (high)	3/3/15	< 1		
MES-0303-9B	Moten ES	2nd floor hallway adjacent to Boy's Room 211 (high)	3/3/15	< 1		
MES-0303-10A	Moten ES	2nd floor hallway adjacent to Boy's Room 211 (low)	3/3/15	< 1		
MES-0303-10B	Moten ES	2nd floor hallway adjacent to Boy's Room 211 (low)	3/3/15	< 1		
MES-0303-11A	Moten ES	2nd floor hallway adjacent to Janitor's Closet 219	3/3/15	< 1		
MES-0303-11B	Moten ES	2nd floor hallway adjacent to Janitor's Closet 219	3/3/15	< 1		
MES-0303-12A	Moten ES	2nd floor hallway adjacent to Stairwell C	3/3/15	< 1		
MES-0303-12B	Moten ES	2nd floor hallway adjacent to Stairwell C	3/3/15	< 1		
MES-0303-13A	Moten ES	1st floor hallway adjacent to Stairwell C	3/3/15	< 1		
MES-0303-13B	Moten ES	1st floor hallway adjacent to Stairwell C	3/3/15	< 1		
MES-0303-14A	Moten ES	1st floor hallway adjacent to Janitor's Closet 127	3/3/15	< 1		
MES-0303-14B	Moten ES	1st floor hallway adjacent to Janitor's Closet 127	3/3/15	< 1		
MES-0303-15A	Moten ES	1st floor hallway adjacent to Boy's Room 119 (high)	3/3/15	< 1		
MES-0303-15B	Moten ES	1st floor hallway adjacent to Boy's Room 119 (high)	3/3/15	< 1		

MES-0303-16A	Moten ES	1st floor hallway adjacent to Boy's Room 119 (low)	3/3/15	< 1		
MES-0303-16B	Moten ES	1st floor hallway adjacent to Boy's Room 119 (low)	3/3/15	< 1		
MES-0303-17A	Moten ES	1st floor hallway adjacent to Girl's Room 103 (high)	3/3/15	< 1		
MES-0303-17B	Moten ES	1st floor hallway adjacent to Girl's Room 103 (high)	3/3/15	< 1		
MES-0303-18A	Moten ES	1st floor hallway adjacent to Girl's Room 103 (low)	3/3/15	< 1		
MES-0303-18B	Moten ES	1st floor hallway adjacent to Girl's Room 103 (low)	3/3/15	< 1		
MES-0303-19A	Moten ES	Ground floor hallway adjacent to Girl's Room G06 (high)	3/3/15	< 1		
MES-0303-19B	Moten ES	Ground floor hallway adjacent to Girl's Room G06 (high)	3/3/15	< 1		
MES-0303-20A	Moten ES	Ground floor hallway adjacent to Girl's Room G06 (low)	3/3/15	< 1		
MES-0303-20B	Moten ES	Ground floor hallway adjacent to Girl's Room G06 (low)	3/3/15	< 1		
MES-0303-21A	Moten ES	Ground floor hallway adjacent to Records Room G10 (high)	3/3/15	< 1		
MES-0303-21B	Moten ES	Ground floor hallway adjacent to Records Room G10 (high)	3/3/15	< 1		
MES-0303-22A	Moten ES	Ground floor hallway adjacent to Records Room G10 (low)	3/3/15	< 1		
MES-0303-22B	Moten ES	Ground floor hallway adjacent to Records Room G10 (low)	3/3/15	< 1		
MES-0303-23A	Moten ES	Ground floor hallway adjacent to Janitor's Closet G26	3/3/15	< 1		
MES-0303-23B	Moten ES	Ground floor hallway adjacent to Janitor's Closet G26	3/3/15	< 1		
MES-0303-24A	Moten ES	Ground floor hallway adjacent to Stairwell C	3/3/15	< 1		
MES-0303-24B	Moten ES	Ground floor hallway adjacent to Stairwell C	3/3/15	< 1		
MES-0303-25A	Moten ES	Basement floor hallway adjacent to Stairwell C	3/3/15	< 1		
MES-0303-25B	Moten ES	Basement floor hallway adjacent to Stairwell C	3/3/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
ME-0626-1A	Murch ES	1st floor hallway across room K4	6/26/15	< 1		
ME-0626-1B	Murch ES	1st floor hallway across room K4	6/26/15	< 1		
ME-0626-2A	Murch ES	1st floor inside gym	6/26/15	< 1		
ME-0626-2B	Murch ES	1st floor inside gym	6/26/15	< 1		
ME-0626-3A	Murch ES	1st floor near stairwell C adjacent to room 106	6/26/15	< 1		
ME-0626-3B	Murch ES	1st floor near stairwell C adjacent to room 106	6/26/15	< 1		
ME-0626-4A	Murch ES	1st floor hallway across room104	6/26/15	< 1		
ME-0626-4B	Murch ES	1st floor hallway across room104	6/26/15	< 1		
ME-0626-5A	Murch ES	2nd floor hallway adjacent to room 208	6/26/15	< 1		
ME-0626-5B	Murch ES	2nd floor hallway adjacent to room 208	6/26/15	< 1		
ME-0626-6A	Murch ES	2nd floor hallway adjacent to room 200A	6/26/15	< 1		
ME-0626-6B	Murch ES	2nd floor hallway adjacent to room 200A	6/26/15	< 1		
ME-0626-7A	Murch ES	2nd floor hallway adjacent to room 207	6/26/15	< 1		
ME-0626-7B	Murch ES	2nd floor hallway adjacent to room 207	6/26/15	< 1		
ME-0626-8A	Murch ES	1st floor hallway adjacent to room 101	6/26/15	< 1		
ME-0626-8B	Murch ES	1st floor hallway adjacent to room 101	6/26/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
NES-1224-1A	Nalle ES	2nd floor hallway across from Classroom 214 (high)	12/24/14	< 1		
NES-1224-2B	Nalle ES	2nd floor hallway across from Classroom 214 (high)	12/24/14	< 1		
NES-1224-3A	Nalle ES	2nd floor hallway across from Classroom 214 (low)	12/24/14	< 1		
NES-1224-4B	Nalle ES	2nd floor hallway across from Classroom 214 (low)	12/24/14	< 1		
NES-1224-5A	Nalle ES	1st floor hallway adjacent to Custodian Closet 111 (high)	12/24/14	< 1		
NES-1224-6B	Nalle ES	1st floor hallway adjacent to Custodian Closet 111 (high)	12/24/14	< 1		
NES-1224-7A	Nalle ES	1st floor hallway adjacent to Custodian Closet 111 (low)	12/24/14	< 1		
NES-1224-8B	Nalle ES	1st floor hallway adjacent to Custodian Closet 111 (low)	12/24/14	< 1		
NES-1224-9A	Nalle ES	Basement floor hallway across from Social Worker 005 (high)	12/24/14	< 1		
NES-1224-10B	Nalle ES	Basement floor hallway across from Social Worker 005 (high)	12/24/14	< 1		
NES-1224-11A	Nalle ES	Basement floor hallway across from Social Worker 005 (low)	12/24/14	< 1		
NES-1224-12B	Nalle ES	Basement floor hallway across from Social Worker 005 (low)	12/24/14	< 1		
NES-1224-13A	Nalle ES	1st floor inside Classroom 104	12/24/14	< 1		
NES-1224-14B	Nalle ES	1st floor inside Classroom 104	12/24/14	< 1		
NES-1224-15A	Nalle ES	1st floor inside Classroom 106	12/24/14	< 1		

NES-1224-16B	Nalle ES	1st floor inside Classroom 106	12/24/14	< 1		
NES-1224-17A	Nalle ES	1st floor inside Health Suite 107	12/24/14	< 1		
NES-1224-18B	Nalle ES	1st floor inside Health Suite 107	12/24/14	< 1		
NES-1224-19A	Nalle ES	1st floor inside Classroom 110	12/24/14	< 1		
NES-1224-20B	Nalle ES	1st floor inside Classroom 110	12/24/14	< 1		
NES-1224-21A	Nalle ES	1st floor inside Classroom 112	12/24/14	< 1		
NES-1224-22B	Nalle ES	1st floor inside Classroom 112	12/24/14	< 1		
NES-1224-23A	Nalle ES	1st floor inside Classroom 118	12/24/14	< 1		
NES-1224-24B	Nalle ES	1st floor inside Classroom 118	12/24/14	< 1		
NES-1224-25A	Nalle ES	1st floor inside Classroom 123	12/24/14	< 1		
NES-1224-26B	Nalle ES	1st floor inside Classroom 123	12/24/14	< 1		
NES-1224-27A	Nalle ES	1st floor inside Classroom 128	12/24/14	< 1		
NES-1224-28B	Nalle ES	1st floor inside Classroom 128	12/24/14	< 1		
NES-1224-29A	Nalle ES	1st floor inside Classroom 130	12/24/14	< 1		
NES-1224-30B	Nalle ES	1st floor inside Classroom 130	12/24/14	< 1		
NES-1224-31A	Nalle ES	1st floor inside Classroom 132	12/24/14	< 1		
NES-1224-32B	Nalle ES	1st floor inside Classroom 132	12/24/14	3.5		
					<b>Percentage of Passed Samples</b>	<b>100.00%</b>
					<b>Percentage of Failed Samples</b>	<b>0.00%</b>
NES-0716-1A	Noyes ES	First floor hallway across room 105 (low)	7/16/15	< 1		
NES-0716-1B	Noyes ES	First floor hallway across room 105 (low)	7/16/15	< 1		
NES-0716-2A	Noyes ES	First floor hallway across room 105 (high)	7/16/15	< 1		
NES-0716-2B	Noyes ES	First floor hallway across room 105 (high)	7/16/15	< 1		
NES-0716-3A	Noyes ES	First floor hallway adjacent to room 116 (low)	7/16/15	< 1		
NES-0716-3B	Noyes ES	First floor hallway adjacent to room 116 (low)	7/16/15	< 1		
NES-0716-4A	Noyes ES	First floor hallway adjacent to room 116 (high)	7/16/15	< 1		
NES-0716-4B	Noyes ES	First floor hallway adjacent to room 116 (high)	7/16/15	< 1		
NES-0716-5A	Noyes ES	First floor hallway adjacent to room 135	7/16/15	< 1		
NES-0716-5B	Noyes ES	First floor hallway adjacent to room 135	7/16/15	< 1		
NES-0716-6A	Noyes ES	First floor hallway adjacent to room 133	7/16/15	9.8		
NES-0716-6B	Noyes ES	First floor hallway adjacent to room 133	7/16/15	< 1		
NES-0716-7A	Noyes ES	First floor hallway adjacent to room 134	7/16/15	< 1		
NES-0716-7B	Noyes ES	First floor hallway adjacent to room 134	7/16/15	< 1		
NES-0716-8A	Noyes ES	First floor hallway adjacent to room 132	7/16/15	< 1		
NES-0716-8B	Noyes ES	First floor hallway adjacent to room 132	7/16/15	< 1		
NES-0716-9A	Noyes ES	First floor hallway adjacent to room 131	7/16/15	< 1		
NES-0716-9B	Noyes ES	First floor hallway adjacent to room 131	7/16/15	< 1		
NES-0716-10A	Noyes ES	First floor hallway adjacent to room 129	7/16/15	< 1		
NES-0716-10B	Noyes ES	First floor hallway adjacent to room 129	7/16/15	< 1		
NES-0716-11A	Noyes ES	First floor hallway adjacent to room 128	7/16/15	< 1		
NES-0716-11B	Noyes ES	First floor hallway adjacent to room 128	7/16/15	< 1		
NES-0716-12A	Noyes ES	First floor hallway adjacent to room 130	7/16/15	< 1		
NES-0716-12B	Noyes ES	First floor hallway adjacent to room 130	7/16/15	< 1		
NES-0716-13A	Noyes ES	Second floor hallway adjacent to room 216	7/16/15	< 1		
NES-0716-13B	Noyes ES	Second floor hallway adjacent to room 216	7/16/15	< 1		
NES-0716-14A	Noyes ES	Second floor hallway adjacent to room 214	7/16/15	< 1		
NES-0716-14B	Noyes ES	Second floor hallway adjacent to room 214	7/16/15	< 1		
NES-0716-15A	Noyes ES	Second floor hallway adjacent to room 213	7/16/15	< 1		
NES-0716-15B	Noyes ES	Second floor hallway adjacent to room 213	7/16/15	< 1		
NES-0716-16A	Noyes ES	Second floor hallway adjacent to room 205	7/16/15	< 1		
NES-0716-16B	Noyes ES	Second floor hallway adjacent to room 205	7/16/15	< 1		
NES-0716-17A	Noyes ES	Second floor hallway adjacent to room 206	7/16/15	< 1		
NES-0716-17B	Noyes ES	Second floor hallway adjacent to room 206	7/16/15	< 1		
NES-0716-18A	Noyes ES	Second floor hallway adjacent to room 203	7/16/15	< 1		
NES-0716-18B	Noyes ES	Second floor hallway adjacent to room 203	7/16/15	< 1		

NES-0716-19A	Noyes ES	Second floor hallway adjacent to room 204	7/16/15	1.4		
NES-0716-19B	Noyes ES	Second floor hallway adjacent to room 204	7/16/15	< 1		
NES-0716-20A	Noyes ES	Second floor hallway near stairwell C (high)	7/16/15	< 1		
NES-0716-20B	Noyes ES	Second floor hallway near stairwell C (high)	7/16/15	< 1		
NES-0716-21A	Noyes ES	First floor hallway adjacent to auditorium (low)	7/16/15	< 1		
NES-0716-21B	Noyes ES	First floor hallway adjacent to auditorium (low)	7/16/15	< 1		
NES-0716-22A	Noyes ES	First floor hallway adjacent to auditorium (high)	7/16/15	< 1		
NES-0716-22B	Noyes ES	First floor hallway adjacent to auditorium (high)	7/16/15	< 1		
NES-0716-23A	Noyes ES	Second floor hallway near stairwell A (high)	7/16/15	< 1		
NES-0716-23B	Noyes ES	Second floor hallway near stairwell A (high)	7/16/15	< 1		
NES-0716-24A	Noyes ES	Second floor hallway near stairwell A (low)	7/16/15	< 1		
NES-0716-24B	Noyes ES	Second floor hallway near stairwell A (low)	7/16/15	< 1		
NES-0716-25A	Noyes ES	Second floor hallway near stairwell C (low)	7/16/15	< 1		
NES-0716-25B	Noyes ES	Second floor hallway near stairwell C (low)	7/16/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
OES-0602-1A	Orr ES	4th Floor hallway adjacent to Teachers RR	6/2/15	< 1		
OES-0602-1B	Orr ES	4th Floor hallway adjacent to Teachers RR	6/2/15	< 1		
OES-0602-2A	Orr ES	4th Floor hallway across speech room	6/2/15	< 1		
OES-0602-2B	Orr ES	4th Floor hallway across speech room	6/2/15	< 1		
OES-0602-3A	Orr ES	3rd Floor hallway across reading laboratory	6/2/15	< 1		
OES-0602-3B	Orr ES	3rd Floor hallway across reading laboratory	6/2/15	< 1		
OES-0602-4A	Orr ES	3rd Floor hallway across speech room	6/2/15	< 1		
OES-0602-4B	Orr ES	3rd Floor hallway across speech room	6/2/15	< 1		
OES-0602-5A	Orr ES	2nd Floor hallway across reading laboratory	6/2/15	< 1		
OES-0602-5B	Orr ES	2nd Floor hallway across reading laboratory	6/2/15	< 1		
OES-0602-6A	Orr ES	2nd Floor hallway across speech room	6/2/15	< 1		
OES-0602-6B	Orr ES	2nd Floor hallway across speech room	6/2/15	< 1		
OES-0602-7A	Orr ES	1st Floor main hallway at the GYM	6/2/15	< 1		
OES-0602-7B	Orr ES	1st Floor main hallway at the GYM	6/2/15	< 1		
OES-0602-8A	Orr ES	1st Floor inside the gym, adjacent to Rec: director's room	6/2/15	< 1		
OES-0602-8B	Orr ES	1st Floor inside the gym, adjacent to Rec: director's room	6/2/15	< 1		
OES-0602-9A	Orr ES	1st Floor inside the gym adjacent to Kitchen	6/2/15	< 1		
OES-0602-9B	Orr ES	1st Floor inside the gym adjacent to Kitchen	6/2/15	< 1		
OES-0602-10A	Orr ES	1st Floor hallway across GYM	6/2/15	< 1		
OES-0602-10B	Orr ES	1st Floor hallway across GYM	6/2/15	< 1		
OES-0602-11A	Orr ES	1st Floor hallway across main office.	6/2/15	< 1		
OES-0602-11B	Orr ES	1st Floor hallway across main office.	6/2/15	< 1		
OES-0602-12A	Orr ES	1st Floor inside Pre-k Ms. Morgan	6/2/15	< 1		
OES-0602-12B	Orr ES	1st Floor inside Pre-k Ms. Morgan	6/2/15	< 1		
OES-0602-13A	Orr ES	1st Floor inside Pre-k Ms. Bridges	6/2/15	< 1		
OES-0602-13B	Orr ES	1st Floor inside Pre-k Ms. Bridges	6/2/15	< 1		
OES-0602-14A	Orr ES	1st Floor inside Pre-k Ms. Dodson	6/2/15	< 1		
OES-0602-14B	Orr ES	1st Floor inside Pre-k Ms. Dodson	6/2/15	< 1		
OES-0602-15A	Orr ES	1st Floor inside Pre-k Ms. Johnson	6/2/15	< 1		
OES-0602-15B	Orr ES	1st Floor inside Pre-k Ms. Johnson	6/2/15	< 1		
OES-0602-16A	Orr ES	1st Floor hallway across Kitchen	6/2/15	< 1		
OES-0602-16B	Orr ES	1st Floor hallway across Kitchen	6/2/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
OES-1231-1A	Oyster ES	4th floor inside Classroom 401	12/31/14	1.3		
OES-1231-2B	Oyster ES	4th floor inside Classroom 401	12/31/14	1.2		
OES-1231-3A	Oyster ES	4th floor inside Classroom 405	12/31/14	< 1		
OES-1231-4B	Oyster ES	4th floor inside Classroom 405	12/31/14	< 1		
OES-1231-5A	Oyster ES	4th floor inside Classroom 407	12/31/14	< 1		

OES-1231-6B	Oyster ES	4th floor inside Classroom 407	12/31/14	< 1		
OES-1231-7A	Oyster ES	4th floor hallway between Boy's and Girl's Rooms (high)	12/31/14	< 1		
OES-1231-8B	Oyster ES	4th floor hallway between Boy's and Girl's Rooms (high)	12/31/14	< 1		
OES-1231-9A	Oyster ES	4th floor hallway between Boy's and Girl's Rooms (low)	12/31/14	< 1		
OES-1231-10B	Oyster ES	4th floor hallway between Boy's and Girl's Rooms (low)	12/31/14	< 1		
OES-1231-11A	Oyster ES	4th floor inside Classroom 410	12/31/14	< 1		
OES-1231-12B	Oyster ES	4th floor inside Classroom 410	12/31/14	< 1		
OES-1231-13A	Oyster ES	4th floor inside Classroom 412	12/31/14	< 1		
OES-1231-14B	Oyster ES	4th floor inside Classroom 412	12/31/14	< 1		
OES-1231-15A	Oyster ES	4th floor inside Classroom 415	12/31/14	< 1		
OES-1231-16B	Oyster ES	4th floor inside Classroom 415	12/31/14	< 1		
OES-1231-17A	Oyster ES	3rd floor inside Classroom 316	12/31/14	< 1		
OES-1231-18B	Oyster ES	3rd floor inside Classroom 316	12/31/14	< 1		
OES-1231-19A	Oyster ES	3rd floor inside Classroom 313	12/31/14	< 1		
OES-1231-20B	Oyster ES	3rd floor inside Classroom 313	12/31/14	< 1		
OES-1231-21A	Oyster ES	3rd floor hallway across from Pump Room 312 (high)	12/31/14	< 1		
OES-1231-22B	Oyster ES	3rd floor hallway across from Pump Room 312 (high)	12/31/14	< 1		
OES-1231-23A	Oyster ES	3rd floor hallway across from Pump Room 312 (low)	12/31/14	< 1		
OES-1231-24B	Oyster ES	3rd floor hallway across from Pump Room 312 (low)	12/31/14	< 1		
OES-1231-25A	Oyster ES	3rd floor inside Classroom 308	12/31/14	< 1		
OES-1231-26B	Oyster ES	3rd floor inside Classroom 308	12/31/14	< 1		
OES-1231-27A	Oyster ES	3rd floor inside Classroom 304	12/31/14	< 1		
OES-1231-28B	Oyster ES	3rd floor inside Classroom 304	12/31/14	< 1		
OES-1231-29A	Oyster ES	3rd floor inside Classroom 301	12/31/14	< 1		
OES-1231-30B	Oyster ES	3rd floor inside Classroom 301	12/31/14	< 1		
OES-1231-31A	Oyster ES	2nd floor inside Classroom 201	12/31/14	< 1		
OES-1231-32B	Oyster ES	2nd floor inside Classroom 201	12/31/14	< 1		
OES-1231-33A	Oyster ES	2nd floor inside Gym (high)	12/31/14	< 1		
OES-1231-34B	Oyster ES	2nd floor inside Gym (high)	12/31/14	< 1		
OES-1231-35A	Oyster ES	2nd floor inside Gym (low)	12/31/14	< 1		
OES-1231-36B	Oyster ES	2nd floor inside Gym (low)	12/31/14	< 1		
OES-1231-37A	Oyster ES	2nd floor inside Classroom 202	12/31/14	< 1		
OES-1231-38B	Oyster ES	2nd floor inside Classroom 202	12/31/14	< 1		
OES-1231-39A	Oyster ES	2nd floor hallway between Boy's and Girl's Rooms (high)	12/31/14	< 1		
OES-1231-40B	Oyster ES	2nd floor hallway between Boy's and Girl's Rooms (high)	12/31/14	< 1		
OES-1231-41A	Oyster ES	2nd floor hallway between Boy's and Girl's Rooms (low)	12/31/14	< 1		
OES-1231-42B	Oyster ES	2nd floor hallway between Boy's and Girl's Rooms (low)	12/31/14	< 1		
OES-1231-43A	Oyster ES	2nd floor inside Classroom 210	12/31/14	< 1		
OES-1231-44B	Oyster ES	2nd floor inside Classroom 210	12/31/14	< 1		
OES-1231-45A	Oyster ES	2nd floor inside Classroom 211	12/31/14	< 1		
OES-1231-46B	Oyster ES	2nd floor inside Classroom 211	12/31/14	< 1		
OES-1231-47A	Oyster ES	1st floor hallway between Boy's and Girl's Rooms (high)	12/31/14	< 1		
OES-1231-48B	Oyster ES	1st floor hallway between Boy's and Girl's Rooms (high)	12/31/14	< 1		
OES-1231-49A	Oyster ES	1st floor hallway between Boy's and Girl's Rooms (low)	12/31/14	< 1		
OES-1231-50B	Oyster ES	1st floor hallway between Boy's and Girl's Rooms (low)	12/31/14	< 1		
OES-1231-51A	Oyster ES	1st floor inside Classroom 107	12/31/14	< 1		
OES-1231-52B	Oyster ES	1st floor inside Classroom 107	12/31/14	< 1		
OES-1231-53A	Oyster ES	1st floor inside Classroom 104	12/31/14	< 1		
OES-1231-54B	Oyster ES	1st floor inside Classroom 104	12/31/14	< 1		
OES-1231-55A	Oyster ES	3rd floor inside Classroom 309	12/31/14	< 1		
OES-1231-56B	Oyster ES	3rd floor inside Classroom 309	12/31/14	< 1		
				<b>Percentage of Passed Samples</b>		<b>100.00%</b>
				<b>Percentage of Failed Samples</b>		<b>0.00%</b>
PE-0605-1A	Patterson MS	3rd Floor hallway adjacent to janitor closet 302 (high)	6/5/15	< 1		
PE-0605-1B	Patterson MS	3rd Floor hallway adjacent to janitor closet 302 (high)	6/5/15	< 1		

PE-0605-2A	Patterson MS	3rd Floor hallway adjacent to janitor closet 302 (low)	6/5/15	< 1		
PE-0605-2B	Patterson MS	3rd Floor hallway adjacent to janitor closet 302 (low)	6/5/15	< 1		
PE-0605-3A	Patterson MS	2nd Floor hallway adjacent to janitor closet 208A (high)	6/5/15	< 1		
PE-0605-3B	Patterson MS	2nd Floor hallway adjacent to janitor closet 208A (high)	6/5/15	< 1		
PE-0605-4A	Patterson MS	2nd Floor hallway adjacent to janitor closet 208A (low)	6/5/15	< 1		
PE-0605-4B	Patterson MS	2nd Floor hallway adjacent to janitor closet 208A (low)	6/5/15	< 1		
PE-0605-5A	Patterson MS	1st Floor hallway adjacent to janitor closet 110 (high)	6/5/15	< 1		
PE-0605-5B	Patterson MS	1st Floor hallway adjacent to janitor closet 110 (high)	6/5/15	< 1		
PE-0605-6A	Patterson MS	1st Floor hallway adjacent to janitor closet 110 (low)	6/5/15	< 1		
PE-0605-6B	Patterson MS	1st Floor hallway adjacent to janitor closet 110 (low)	6/5/15	< 1		
PE-0605-7A	Patterson MS	1st Floor inside cafeteria (high)	6/5/15	< 1		
PE-0605-7B	Patterson MS	1st Floor inside cafeteria (high)	6/5/15	< 1		
PE-0605-8A	Patterson MS	1st Floor inside cafeteria (low)	6/5/15	< 1		
PE-0605-8B	Patterson MS	1st Floor inside cafeteria (low)	6/5/15	< 1		
PE-0605-9A	Patterson MS	3rd Floor inside classroom 312	6/5/15	< 1		
PE-0605-9B	Patterson MS	3rd Floor inside classroom 312	6/5/15	< 1		
PE-0605-10A	Patterson MS	3rd Floor inside classroom 311	6/5/15	< 1		
PE-0605-10B	Patterson MS	3rd Floor inside classroom 311	6/5/15	< 1		
PE-0605-11A	Patterson MS	3rd Floor inside classroom 321	6/5/15	< 1		
PE-0605-11B	Patterson MS	3rd Floor inside classroom 321	6/5/15	< 1		
PE-0605-12A	Patterson MS	3rd Floor inside classroom 307	6/5/15	< 1		
PE-0605-12B	Patterson MS	3rd Floor inside classroom 307	6/5/15	< 1		
PE-0605-13A	Patterson MS	3rd Floor inside classroom 316	6/5/15	< 1		
PE-0605-13B	Patterson MS	3rd Floor inside classroom 316	6/5/15	< 1		
PE-0605-14A	Patterson MS	3rd Floor inside classroom 324	6/5/15	< 1		
PE-0605-14B	Patterson MS	3rd Floor inside classroom 324	6/5/15	< 1		
PE-0605-15A	Patterson MS	3rd Floor inside classroom 323	6/5/15	< 1		
PE-0605-15B	Patterson MS	3rd Floor inside classroom 323	6/5/15	< 1		
PE-0605-16A	Patterson MS	3rd Floor inside classroom 317	6/5/15	< 1		
PE-0605-16B	Patterson MS	3rd Floor inside classroom 317	6/5/15	< 1		
PE-0605-17A	Patterson MS	2nd Floor inside classroom 214	6/5/15	< 1		
PE-0605-17B	Patterson MS	2nd Floor inside classroom 214	6/5/15	< 1		
PE-0605-18A	Patterson MS	2nd Floor inside classroom 215	6/5/15	< 1		
PE-0605-18B	Patterson MS	2nd Floor inside classroom 215	6/5/15	< 1		
PE-0605-19A	Patterson MS	2nd Floor inside classroom 213	6/5/15	< 1		
PE-0605-19B	Patterson MS	2nd Floor inside classroom 213	6/5/15	< 1		
PE-0605-20A	Patterson MS	2nd Floor inside classroom 216	6/5/15	< 1		
PE-0605-20B	Patterson MS	2nd Floor inside classroom 216	6/5/15	< 1		
PE-0605-21A	Patterson MS	2nd Floor inside classroom 218	6/5/15	< 1		
PE-0605-21B	Patterson MS	2nd Floor inside classroom 218	6/5/15	< 1		
PE-0605-22A	Patterson MS	2nd Floor inside classroom 220	6/5/15	< 1		
PE-0605-22B	Patterson MS	2nd Floor inside classroom 220	6/5/15	< 1		
PE-0605-23A	Patterson MS	2nd Floor inside classroom 225	6/5/15	< 1		
PE-0605-23B	Patterson MS	2nd Floor inside classroom 225	6/5/15	< 1		
PE-0605-24A	Patterson MS	2nd Floor inside classroom 221	6/5/15	< 1		
PE-0605-24B	Patterson MS	2nd Floor inside classroom 221	6/5/15	< 1		
PE-0605-25A	Patterson MS	2nd Floor inside classroom 224	6/5/15	< 1		
PE-0605-25B	Patterson MS	2nd Floor inside classroom 224	6/5/15	< 1		
PE-0605-26A	Patterson MS	2nd Floor inside classroom 223	6/5/15	< 1		
PE-0605-26B	Patterson MS	2nd Floor inside classroom 223	6/5/15	< 1		
PE-0605-27A	Patterson MS	2nd Floor inside classroom 222	6/5/15	< 1		
PE-0605-27B	Patterson MS	2nd Floor inside classroom 222	6/5/15	< 1		
PE-0605-28A	Patterson MS	2nd Floor inside classroom 230	6/5/15	< 1		
PE-0605-28B	Patterson MS	2nd Floor inside classroom 230	6/5/15	< 1		
PE-0605-29A	Patterson MS	2nd Floor inside classroom 232	6/5/15	< 1		

PE-0605-29B	Patterson MS	2nd Floor inside classroom 232	6/5/15	< 1		
PE-0605-30A	Patterson MS	1st Floor inside classroom 115	6/5/15	< 1		
PE-0605-30B	Patterson MS	1st Floor inside classroom 115	6/5/15	< 1		
PE-0605-31A	Patterson MS	1st Floor inside classroom 123	6/5/15	< 1		
PE-0605-31B	Patterson MS	1st Floor inside classroom 123	6/5/15	< 1		
PE-0605-32A	Patterson MS	1st Floor inside classroom 119	6/5/15	< 1		
PE-0605-32B	Patterson MS	1st Floor inside classroom 119	6/5/15	< 1		
PE-0605-33A	Patterson MS	1st Floor inside classroom 120	6/5/15	< 1		
PE-0605-33B	Patterson MS	1st Floor inside classroom 120	6/5/15	< 1		
PE-0605-34A	Patterson MS	1st Floor inside classroom 125	6/5/15	< 1		
PE-0605-34B	Patterson MS	1st Floor inside classroom 125	6/5/15	< 1		
PE-0605-35A	Patterson MS	1st Floor inside classroom 127	6/5/15	< 1		
PE-0605-35B	Patterson MS	1st Floor inside classroom 127	6/5/15	< 1		
PE-0605-36A	Patterson MS	1st Floor inside classroom 131	6/5/15	< 1		
PE-0605-36B	Patterson MS	1st Floor inside classroom 131	6/5/15	< 1		
PE-0605-37A	Patterson MS	1st Floor inside classroom 132	6/5/15	< 1		
PE-0605-37B	Patterson MS	1st Floor inside classroom 132	6/5/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
PE-0224-1A	Payne ES	1st Floor inside classroom 161	2/24/15	< 1		
PE-0224-1B	Payne ES	1st Floor inside classroom 161	2/24/15	< 1		
PE-0224-2A	Payne ES	1st Floor inside classroom 190	2/24/15	< 1		
PE-0224-2B	Payne ES	1st Floor inside classroom 190	2/24/15	< 1		
PE-0224-3A	Payne ES	1st Floor inside classroom 168	2/24/15	< 1		
PE-0224-3B	Payne ES	1st Floor inside classroom 168	2/24/15	< 1		
PE-0224-4A	Payne ES	1st Floor inside classroom 187	2/24/15	< 1		
PE-0224-4B	Payne ES	1st Floor inside classroom 187	2/24/15	< 1		
PE-0224-5A	Payne ES	1st Floor hallway across classroom 184 (high)	2/24/15	< 1		
PE-0224-5B	Payne ES	1st Floor hallway across classroom 184 (high)	2/24/15	< 1		
PE-0224-6A	Payne ES	1st Floor hallway across classroom 184 (low)	2/24/15	< 1		
PE-0224-6B	Payne ES	1st Floor hallway across classroom 184 (low)	2/24/15	< 1		
PE-0224-7A	Payne ES	1st Floor inside classroom 184	2/24/15	< 1		
PE-0224-7B	Payne ES	1st Floor inside classroom 184	2/24/15	< 1		
PE-0224-8A	Payne ES	1st Floor inside classroom 172	2/24/15	< 1		
PE-0224-8B	Payne ES	1st Floor inside classroom 172	2/24/15	< 1		
PE-0224-9A	Payne ES	1st Floor inside classroom 181	2/24/15	< 1		
PE-0224-9B	Payne ES	1st Floor inside classroom 181	2/24/15	< 1		
PE-0224-10A	Payne ES	1st Floor hallway adjacent to classroom 180 (high)	2/24/15	< 1		
PE-0224-10B	Payne ES	1st Floor hallway adjacent to classroom 180 (high)	2/24/15	< 1		
PE-0224-11A	Payne ES	1st Floor hallway adjacent to classroom 180 (low)	2/24/15	< 1		
PE-0224-11B	Payne ES	1st Floor hallway adjacent to classroom 180 (low)	2/24/15	< 1		
PE-0224-12A	Payne ES	1st Floor hallway adjacent to room 105 Health Suite	2/24/15	< 1		
PE-0224-12B	Payne ES	1st Floor hallway adjacent to room 105 Health Suite	2/24/15	< 1		
PE-0224-13A	Payne ES	2nd Floor hallway adjacent to janitor closet room 257	2/24/15	< 1		
PE-0224-13B	Payne ES	2nd Floor hallway adjacent to janitor closet room 257	2/24/15	< 1		
PE-0224-14A	Payne ES	1st Floor hallway adjacent to cafeteria (high)	2/24/15	< 1		
PE-0224-14B	Payne ES	1st Floor hallway adjacent to cafeteria (high)	2/24/15	< 1		
PE-0224-15A	Payne ES	1st Floor hallway adjacent to cafeteria (low)	2/24/15	< 1		
PE-0224-15B	Payne ES	1st Floor hallway adjacent to cafeteria (low)	2/24/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
PES-1231-1A	Peabody ES	Basement floor hallway adjacent to Girl's Room (high)	12/31/14	< 1		
PES-1231-2B	Peabody ES	Basement floor hallway adjacent to Girl's Room (high)	12/31/14	< 1		
PES-1231-3A	Peabody ES	Basement floor hallway adjacent to Girl's Room (low)	12/31/14	< 1		
PES-1231-4B	Peabody ES	Basement floor hallway adjacent to Girl's Room (low)	12/31/14	< 1		

PES-1231-5A	Peabody ES	3rd floor inside Classroom 303	12/31/14	< 1		
PES-1231-6B	Peabody ES	3rd floor inside Classroom 303	12/31/14	< 1		
PES-1231-7A	Peabody ES	3rd floor inside Classroom 306	12/31/14	< 1		
PES-1231-8B	Peabody ES	3rd floor inside Classroom 306	12/31/14	< 1		
PES-1231-9A	Peabody ES	3rd floor inside Classroom 307	12/31/14	< 1		
PES-1231-10B	Peabody ES	3rd floor inside Classroom 307	12/31/14	< 1		
PES-1231-11A	Peabody ES	3rd floor inside Classroom 304	12/31/14	< 1		
PES-1231-12B	Peabody ES	3rd floor inside Classroom 304	12/31/14	< 1		
PES-1231-13A	Peabody ES	2nd floor inside Classroom 203	12/31/14	< 1		
PES-1231-14B	Peabody ES	2nd floor inside Classroom 203	12/31/14	< 1		
PES-1231-15A	Peabody ES	2nd floor inside Classroom 204	12/31/14	< 1		
PES-1231-16B	Peabody ES	2nd floor inside Classroom 204	12/31/14	< 1		
PES-1231-17A	Peabody ES	2nd floor inside Classroom 206	12/31/14	< 1		
PES-1231-18B	Peabody ES	2nd floor inside Classroom 206	12/31/14	< 1		
PES-1231-19A	Peabody ES	2nd floor inside Classroom 207	12/31/14	< 1		
PES-1231-20B	Peabody ES	2nd floor inside Classroom 207	12/31/14	< 1		
PES-1231-21A	Peabody ES	1st floor inside Classroom 103	12/31/14	< 1		
PES-1231-22B	Peabody ES	1st floor inside Classroom 103	12/31/14	< 1		
PES-1231-23A	Peabody ES	1st floor inside Classroom 104	12/31/14	< 1		
PES-1231-24B	Peabody ES	1st floor inside Classroom 104	12/31/14	< 1		
PES-1231-25A	Peabody ES	1st floor inside Classroom 106	12/31/14	< 1		
PES-1231-26B	Peabody ES	1st floor inside Classroom 106	12/31/14	< 1		
PES-1231-27A	Peabody ES	1st floor inside Classroom 107	12/31/14	< 1		
PES-1231-28B	Peabody ES	1st floor inside Classroom 107	12/31/14	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
PHS-0810-1A	Phelps HS	First floor hallway adjacent to room C110	8/20/15			
PHS-0810-1B	Phelps HS	First floor hallway adjacent to room C110	8/20/15			
PHS-0810-2A	Phelps HS	First floor hallway adjacent to room C108	8/20/15			
PHS-0810-2B	Phelps HS	First floor hallway adjacent to room C108	8/20/15			
PHS-0810-3A	Phelps HS	Basement hallway adjacent to room S005	8/20/15			
PHS-0810-3B	Phelps HS	Basement hallway adjacent to room S005	8/20/15			
PHS-0810-4A	Phelps HS	Basement hallway across to room S001	8/20/15			
PHS-0810-4B	Phelps HS	Basement hallway across to room S001	8/20/15			
PHS-0810-5A	Phelps HS	Second floor hallway adjacent to room S206	8/20/15			
PHS-0810-5B	Phelps HS	Second floor hallway adjacent to room S206	8/20/15			
PHS-0810-6A	Phelps HS	Second floor hallway adjacent to room S211	8/20/15			
PHS-0810-6B	Phelps HS	Second floor hallway adjacent to room S211	8/20/15			
PHS-0810-7A	Phelps HS	First floor hallway adjacent to room T104	8/20/15			
PHS-0810-7B	Phelps HS	First floor hallway adjacent to room T104	8/20/15			
PHS-0810-8A	Phelps HS	First floor hallway adjacent to room T106	8/20/15			
PHS-0810-8B	Phelps HS	First floor hallway adjacent to room T106	8/20/15			
<b>Percentage of Passed Samples</b>						<b>0.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
PE-0325-1A	Plummer ES	2nd Floor hallway adjacent to room 309 (high)	3/25/15	< 1		
PE-0325-1B	Plummer ES	2nd Floor hallway adjacent to room 309 (high)	3/25/15	< 1		
PE-0325-2A	Plummer ES	2nd Floor hallway adjacent to room 309 (low)	3/25/15	< 1		
PE-0325-2B	Plummer ES	2nd Floor hallway adjacent to room 309 (low)	3/25/15	< 1		
PE-0325-3A	Plummer ES	1st Floor inside cafeteria	3/25/15	< 1		
PE-0325-3B	Plummer ES	1st Floor inside cafeteria	3/25/15	< 1		
PE-0325-4A	Plummer ES	1st Floor inside classroom 221	3/25/15	< 1		
PE-0325-4B	Plummer ES	1st Floor inside classroom 221	3/25/15	< 1		
PE-0325-5A	Plummer ES	1st Floor inside classroom 216	3/25/15	< 1		
PE-0325-5B	Plummer ES	1st Floor inside classroom 216	3/25/15	< 1		
PE-0325-6A	Plummer ES	1st Floor inside classroom 219	3/25/15	< 1		

PE-0325-6B	Plummer ES	1st Floor inside classroom 219	3/25/15	< 1		
PE-0325-7A	Plummer ES	1st Floor inside classroom 214	3/25/15	< 1		
PE-0325-7B	Plummer ES	1st Floor inside classroom 214	3/25/15	< 1		
PE-0325-8A	Plummer ES	1st Floor inside classroom 212	3/25/15	< 1		
PE-0325-8B	Plummer ES	1st Floor inside classroom 212	3/25/15	< 1		
PE-0325-9A	Plummer ES	1st Floor hallway adjacent to classroom 217 (high)	3/25/15	< 1		
PE-0325-9B	Plummer ES	1st Floor hallway adjacent to classroom 217 (high)	3/25/15	< 1		
PE-0325-10A	Plummer ES	1st Floor hallway adjacent to classroom 217 (low)	3/25/15	< 1		
PE-0325-10B	Plummer ES	1st Floor hallway adjacent to classroom 217 (low)	3/25/15	< 1		
PE-0325-11A	Plummer ES	1st Floor inside classroom 206	3/25/15	< 1		
PE-0325-11B	Plummer ES	1st Floor inside classroom 206	3/25/15	< 1		
PE-0325-12A	Plummer ES	1st Floor inside classroom 204	3/25/15	< 1		
PE-0325-12B	Plummer ES	1st Floor inside classroom 204	3/25/15	< 1		
PE-0325-13A	Plummer ES	1st Floor inside classroom 202	3/25/15	< 1		
PE-0325-13B	Plummer ES	1st Floor inside classroom 202	3/25/15	< 1		
PE-0325-14A	Plummer ES	1st Floor inside classroom 201	3/25/15	< 1		
PE-0325-14B	Plummer ES	1st Floor inside classroom 201	3/25/15	< 1		
PE-0325-15A	Plummer ES	1st Floor inside classroom 203	3/25/15	< 1		
PE-0325-15B	Plummer ES	1st Floor inside classroom 203	3/25/15	< 1		
PE-0325-16A	Plummer ES	Ground Floor Gym (high)	3/25/15	< 1		
PE-0325-16B	Plummer ES	Ground Floor Gym (high)	3/25/15	< 1		
PE-0325-17A	Plummer ES	Ground Floor Gym (low)	3/25/15	< 1		
PE-0325-17B	Plummer ES	Ground Floor Gym (low)	3/25/15	< 1		
PE-0325-18A	Plummer ES	Ground Floor hallway adjacent to staff lounge (high)	3/25/15	< 1		
PE-0325-18B	Plummer ES	Ground Floor hallway adjacent to staff lounge (high)	3/25/15	< 1		
PE-0325-19A	Plummer ES	Ground Floor hallway adjacent to staff lounge (low)	3/25/15	< 1		
PE-0325-19B	Plummer ES	Ground Floor hallway adjacent to staff lounge (low)	3/25/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
PE-0211-1A	Powell ES	2nd floor hallway adjacent to classroom 203	2/11/15	< 1		
PE-0211-1B	Powell ES	2nd floor hallway adjacent to classroom 203	2/11/15	< 1		
PE-0211-2A	Powell ES	2nd floor inside classroom 207	2/11/15		71	Filter Installed
PE-0211-2B	Powell ES	2nd floor inside classroom 207	2/11/15	13		
PE-0211-3A	Powell ES	2nd floor hallway adjacent to classroom 206 (high)	2/11/15	< 1		
PE-0211-3B	Powell ES	2nd floor hallway adjacent to classroom 206 (high)	2/11/15	< 1		
PE-0211-4A	Powell ES	2nd floor hallway adjacent to classroom 206 (low)	2/11/15	< 1		
PE-0211-4B	Powell ES	2nd floor hallway adjacent to classroom 206 (low)	2/11/15	< 1		
PE-0211-5A	Powell ES	2nd floor inside classroom 206	2/11/15	1.1		
PE-0211-5B	Powell ES	2nd floor inside classroom 206	2/11/15	< 1		
PE-0211-6A	Powell ES	2nd floor inside classroom 204	2/11/15	< 1		
PE-0211-6B	Powell ES	2nd floor inside classroom 204	2/11/15	< 1		
PE-0211-7A	Powell ES	2nd floor hallway adjacent to classroom 201 (high)	2/11/15	< 1		
PE-0211-7B	Powell ES	2nd floor hallway adjacent to classroom 201 (high)	2/11/15	< 1		
PE-0211-8A	Powell ES	2nd floor hallway adjacent to classroom 201 (low)	2/11/15	< 1		
PE-0211-8B	Powell ES	2nd floor hallway adjacent to classroom 201 (low)	2/11/15	< 1		
PE-0211-9A	Powell ES	2nd floor inside classroom 202	2/11/15	< 1		
PE-0211-9B	Powell ES	2nd floor inside classroom 202	2/11/15	< 1		
PE-0211-10A	Powell ES	2nd floor inside classroom 201	2/11/15	< 1		
PE-0211-10B	Powell ES	2nd floor inside classroom 201	2/11/15	< 1		
PE-0211-11A	Powell ES	1st floor inside classroom 101	2/11/15	< 1		
PE-0211-11B	Powell ES	1st floor inside classroom 101	2/11/15	< 1		
PE-0211-12A	Powell ES	1st floor inside classroom 102	2/11/15	< 1		
PE-0211-12B	Powell ES	1st floor inside classroom 102	2/11/15	< 1		
PE-0211-13A	Powell ES	1st floor hallway adjacent to classroom 101 (high)	2/11/15	< 1		
PE-0211-13B	Powell ES	1st floor hallway adjacent to classroom 101 (high)	2/11/15	< 1		

PE-0211-14A	Powell ES	1st floor hallway adjacent to classroom 101 (low)	2/11/15	< 1		
PE-0211-14B	Powell ES	1st floor hallway adjacent to classroom 101 (low)	2/11/15	< 1		
PE-0211-15A	Powell ES	1st floor inside classroom 104	2/11/15	< 1		
PE-0211-15B	Powell ES	1st floor inside classroom 104	2/11/15	< 1		
PE-0211-16A	Powell ES	1st floor inside classroom 105	2/11/15	< 1		
PE-0211-16B	Powell ES	1st floor inside classroom 105	2/11/15	< 1		
PE-0211-17A	Powell ES	1st floor hallway adjacent to classroom 105 (high)	2/11/15	< 1		
PE-0211-17B	Powell ES	1st floor hallway adjacent to classroom 105 (high)	2/11/15	< 1		
PE-0211-18A	Powell ES	1st floor hallway adjacent to classroom 105 (low)	2/11/15	< 1		
PE-0211-18B	Powell ES	1st floor hallway adjacent to classroom 105 (low)	2/11/15	< 1		
PE-0211-19A	Powell ES	1st floor inside classroom 106	2/11/15	< 1		
PE-0211-19B	Powell ES	1st floor inside classroom 106	2/11/15	< 1		
PE-0211-20A	Powell ES	1st floor hallway adjacent to office room 104	2/11/15	< 1		
PE-0211-20B	Powell ES	1st floor hallway adjacent to office room 104	2/11/15	< 1		
PE-0211-21A	Powell ES	1st floor inside cafeteria	2/11/15	< 1		
PE-0211-21B	Powell ES	1st floor inside cafeteria	2/11/15	< 1		
PE-0211-22A	Powell ES	1st floor hallway in portable, adjacent to classroom P3 (high)	2/11/15	< 1		
PE-0211-22B	Powell ES	1st floor hallway in portable, adjacent to classroom P3 (high)	2/11/15	< 1		
PE-0211-23A	Powell ES	1st floor hallway in portable, adjacent to classroom P3 (low)	2/11/15	< 1		
PE-0211-23B	Powell ES	1st floor hallway in portable, adjacent to classroom P3 (low)	2/11/15	< 1		
<b>Percentage of Passed Samples</b>						<b>97.83%</b>
<b>Percentage of Failed Samples</b>						<b>2.17%</b>
PES-113-1A	Prospect LC (Goding ES)	4th Floor Hallway In front of Class 408, adjacent to Teachers Rest Room	1/13/15	< 1		
PES-113-1B	Prospect LC (Goding ES)	4th Floor Hallway In front of Class 408, adjacent to Teachers Rest Room	1/13/15	< 1		
PES-113-2A	Prospect LC (Goding ES)	4th Floor Hallway adjacent to Classroom 403	1/13/15	< 1		
PES-113-2B	Prospect LC (Goding ES)	4th Floor Hallway adjacent to Classroom 403	1/13/15	< 1		
PES-113-3A	Prospect LC (Goding ES)	3rd Floor Hallway adjacent to Classroom 303	1/13/15	< 1		
PES-113-3B	Prospect LC (Goding ES)	3rd Floor Hallway adjacent to Classroom 303	1/13/15	< 1		
PES-113-4A	Prospect LC (Goding ES)	3rd Floor Hallway in front of Library adjacent to teachers rest room	1/13/15	3.7		
PES-113-4B	Prospect LC (Goding ES)	3rd Floor Hallway in front of Library adjacent to teachers rest room	1/13/15	1.4		
PES-113-5A	Prospect LC (Goding ES)	2nd Floor Hallway in front of Classroom 206 adjacent to teachers rest room	1/13/15	< 1		
PES-113-5B	Prospect LC (Goding ES)	2nd Floor Hallway in front of Classroom 206 adjacent to teachers rest room	1/13/15	< 1		
PES-113-6A	Prospect LC (Goding ES)	2nd Floor Hallway adjacent to classroom 203	1/13/15	< 1		
PES-113-6B	Prospect LC (Goding ES)	2nd Floor Hallway adjacent to classroom 203	1/13/15	< 1		
PES-113-7A	Prospect LC (Goding ES)	1st Floor Hallway in front of health suit, adjacent to Supply room	1/13/15	1.3		
PES-113-7B	Prospect LC (Goding ES)	1st Floor Hallway in front of health suit, adjacent to Supply room	1/13/15	< 1		
PES-113-8A	Prospect LC (Goding ES)	1st floor Hallway adjacent to classroom 103	1/13/15	< 1		
PES-113-8B	Prospect LC (Goding ES)	1st floor Hallway adjacent to classroom 103	1/13/15	< 1		
PES-113-9A	Prospect LC (Goding ES)	Ground floor cafeteria	1/13/15	1.9		
PES-113-9B	Prospect LC (Goding ES)	Ground floor cafeteria	1/13/15	1.6		
PES-113-10A	Prospect LC (Goding ES)	Ground floor Hallway adjacent to custodian closet	1/13/15	< 1		
PES-113-10B	Prospect LC (Goding ES)	Ground floor Hallway adjacent to custodian closet	1/13/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
RH-0507-1A	Randle Highlands ES	2nd floor hallway adjacent to Custodian Closet 2214 (high)	5/7/15	< 1		
RH-0507-1B	Randle Highlands ES	2nd floor hallway adjacent to Custodian Closet 2214 (high)	5/7/15	< 1		
RH-0507-2A	Randle Highlands ES	2nd floor hallway adjacent to Custodian Closet 2214 (low)	5/7/15	< 1		
RH-0507-2B	Randle Highlands ES	2nd floor hallway adjacent to Custodian Closet 2214 (low)	5/7/15	< 1		
RH-0507-3A	Randle Highlands ES	2nd floor inside Vestibule 2226 (high)	5/7/15	< 1		
RH-0507-3B	Randle Highlands ES	2nd floor inside Vestibule 2226 (high)	5/7/15	< 1		
RH-0507-4A	Randle Highlands ES	2nd floor inside Vestibule 2226 (low)	5/7/15	< 1		

RH-0507-4B	Randle Highlands ES	2nd floor inside Vestibule 2226 (low)	5/7/15	< 1		
RH-0507-5A	Randle Highlands ES	2nd floor inside Vestibule between Rm 2201 and 2203 (high)	5/7/15	< 1		
RH-0507-5B	Randle Highlands ES	2nd floor inside Vestibule between Rm 2201 and 2203 (high)	5/7/15	< 1		
RH-0507-6A	Randle Highlands ES	2nd floor inside Vestibule between Rm 2201 and 2203 (low)	5/7/15	< 1		
RH-0507-6B	Randle Highlands ES	2nd floor inside Vestibule between Rm 2201 and 2203 (low)	5/7/15	< 1		
RH-0507-7A	Randle Highlands ES	1st floor hallway adjacent to Science Classroom 2114 (high)	5/7/15	< 1		
RH-0507-7B	Randle Highlands ES	1st floor hallway adjacent to Science Classroom 2114 (high)	5/7/15	< 1		
RH-0507-8A	Randle Highlands ES	1st floor hallway adjacent to Science Classroom 2114 (low)	5/7/15	< 1		
RH-0507-8B	Randle Highlands ES	1st floor hallway adjacent to Science Classroom 2114 (low)	5/7/15	< 1		
RH-0507-9A	Randle Highlands ES	1st floor inside Vestibule 2131 (high)	5/7/15	< 1		
RH-0507-9B	Randle Highlands ES	1st floor inside Vestibule 2131 (high)	5/7/15	< 1		
RH-0507-10A	Randle Highlands ES	1st floor inside Vestibule 2131 (low)	5/7/15	< 1		
RH-0507-10B	Randle Highlands ES	1st floor inside Vestibule 2131 (low)	5/7/15	< 1		
RH-0507-11A	Randle Highlands ES	1st floor inside Vestibule 2126 (high)	5/7/15	< 1		
RH-0507-11B	Randle Highlands ES	1st floor inside Vestibule 2126 (high)	5/7/15	< 1		
RH-0507-12A	Randle Highlands ES	1st floor inside Vestibule 2126 (low)	5/7/15	< 1		
RH-0507-12B	Randle Highlands ES	1st floor inside Vestibule 2126 (low)	5/7/15	< 1		
RH-0507-13A	Randle Highlands ES	1st floor inside Vestibule 2121 (high)	5/7/15	< 1		
RH-0507-13B	Randle Highlands ES	1st floor inside Vestibule 2121 (high)	5/7/15	< 1		
RH-0507-14A	Randle Highlands ES	1st floor inside Vestibule 2121 (low)	5/7/15	< 1		
RH-0507-14B	Randle Highlands ES	1st floor inside Vestibule 2121 (low)	5/7/15	< 1		
RH-0507-15A	Randle Highlands ES	Ground floor hallway adjacent to Custodian Closet 2014 (high)	5/7/15	< 1		
RH-0507-15B	Randle Highlands ES	Ground floor hallway adjacent to Custodian Closet 2014 (high)	5/7/15	< 1		
RH-0507-16A	Randle Highlands ES	Ground floor hallway adjacent to Custodian Closet 2014 (low)	5/7/15	< 1		
RH-0507-16B	Randle Highlands ES	Ground floor hallway adjacent to Custodian Closet 2014 (low)	5/7/15	< 1		
RH-0507-17A	Randle Highlands ES	Ground floor inside Vestibule 2031 (high)	5/7/15	< 1		
RH-0507-17B	Randle Highlands ES	Ground floor inside Vestibule 2031 (high)	5/7/15	< 1		
RH-0507-18A	Randle Highlands ES	Ground floor inside Vestibule 2031 (low)	5/7/15	< 1		
RH-0507-18B	Randle Highlands ES	Ground floor inside Vestibule 2031 (low)	5/7/15	< 1		
RH-0507-19A	Randle Highlands ES	Ground floor inside Vestibule 2026 (high)	5/7/15	< 1		
RH-0507-19B	Randle Highlands ES	Ground floor inside Vestibule 2026 (high)	5/7/15	< 1		
RH-0507-20A	Randle Highlands ES	Ground floor inside Vestibule 2026 (low)	5/7/15	< 1		
RH-0507-20B	Randle Highlands ES	Ground floor inside Vestibule 2026 (low)	5/7/15	< 1		
RH-0507-21A	Randle Highlands ES	Ground floor inside Vestibule 2021 (high)	5/7/15	< 1		
RH-0507-21B	Randle Highlands ES	Ground floor inside Vestibule 2021 (high)	5/7/15	< 1		
RH-0507-22A	Randle Highlands ES	Ground floor inside Vestibule 2021 (low)	5/7/15	< 1		
RH-0507-22B	Randle Highlands ES	Ground floor inside Vestibule 2021 (low)	5/7/15	< 1		
RH-0507-23A	Randle Highlands ES	Ground floor hallway across from Gym	5/7/15	< 1		
RH-0507-23B	Randle Highlands ES	Ground floor hallway across from Gym	5/7/15	< 1		
RH-0507-24A	Randle Highlands ES	Basement floor hallway adjacent to Custodian Closet 2B14 (high)	5/7/15	< 1		
RH-0507-24B	Randle Highlands ES	Basement floor hallway adjacent to Custodian Closet 2B14 (high)	5/7/15	< 1		
RH-0507-25A	Randle Highlands ES	Basement floor hallway adjacent to Custodian Closet 2B14 (low)	5/7/15	< 1		
RH-0507-25B	Randle Highlands ES	Basement floor hallway adjacent to Custodian Closet 2B14 (low)	5/7/15	< 1		
RH-0507-26A	Randle Highlands ES	Basement floor inside Vestibule 2B31 (high)	5/7/15	< 1		
RH-0507-26B	Randle Highlands ES	Basement floor inside Vestibule 2B31 (high)	5/7/15	< 1		
RH-0507-27A	Randle Highlands ES	Basement floor inside Vestibule 2B31 (low)	5/7/15	< 1		
RH-0507-27B	Randle Highlands ES	Basement floor inside Vestibule 2B31 (low)	5/7/15	< 1		
RH-0507-28A	Randle Highlands ES	Basement floor inside Vestibule 2B26 (low)	5/7/15	< 1		
RH-0507-28B	Randle Highlands ES	Basement floor inside Vestibule 2B26 (low)	5/7/15	< 1		
RH-0507-29A	Randle Highlands ES	Basement floor inside Vestibule 2B21 (high)	5/7/15	< 1		
RH-0507-29B	Randle Highlands ES	Basement floor inside Vestibule 2B21 (high)	5/7/15	< 1		
RH-0507-30A	Randle Highlands ES	Basement floor inside Vestibule 2B21 (low)	5/7/15	< 1		
RH-0507-30B	Randle Highlands ES	Basement floor inside Vestibule 2B21 (low)	5/7/15	< 1		
				<b>Percentage of Passed Samples</b>		<b>100.00%</b>
				<b>Percentage of Failed Samples</b>		<b>0.00%</b>

RE-0226-1A	Raymond ES	3rd Floor hallway adjacent to class room 30	2/26/15	< 1		
RE-0226-1B	Raymond ES	3rd Floor hallway adjacent to class room 30	2/26/15	< 1		
RE-0226-2A	Raymond ES	3rd Floor hallway adjacent to class room 36	2/26/15	< 1		
RE-0226-2B	Raymond ES	3rd Floor hallway adjacent to class room 36	2/26/15	< 1		
RE-0226-3A	Raymond ES	2nd Floor hallway adjacent to classroom 22	2/26/15	< 1		
RE-0226-3B	Raymond ES	2nd Floor hallway adjacent to classroom 22	2/26/15	< 1		
RE-0226-4A	Raymond ES	2nd Floor hallway adjacent to classroom 210	2/26/15	< 1		
RE-0226-4B	Raymond ES	2nd Floor hallway adjacent to classroom 210	2/26/15	< 1		
RE-0226-5A	Raymond ES	2nd Floor hallway across classroom 217	2/26/15	< 1		
RE-0226-5B	Raymond ES	2nd Floor hallway across classroom 217	2/26/15	< 1		
RE-0226-6A	Raymond ES	1st Floor inside classroom 117	2/26/15	< 1		
RE-0226-6B	Raymond ES	1st Floor inside classroom 117	2/26/15	1.1		
RE-0226-7A	Raymond ES	1st Floor inside classroom 116	2/26/15	< 1		
RE-0226-7B	Raymond ES	1st Floor inside classroom 116	2/26/15	< 1		
RE-0226-8A	Raymond ES	1st Floor hallway across classroom 115	2/26/15	< 1		
RE-0226-8B	Raymond ES	1st Floor hallway across classroom 115	2/26/15	< 1		
RE-0226-9A	Raymond ES	1st Floor inside classroom 115	2/26/15	1.7		
RE-0226-9B	Raymond ES	1st Floor inside classroom 115	2/26/15	< 1		
RE-0226-10A	Raymond ES	1st Floor inside classroom 113	2/26/15	< 1		
RE-0226-10B	Raymond ES	1st Floor inside classroom 113	2/26/15	< 1		
RE-0226-11A	Raymond ES	1st Floor inside classroom 110	2/26/15	< 1		
RE-0226-11B	Raymond ES	1st Floor inside classroom 110	2/26/15	< 1		
RE-0226-12A	Raymond ES	1st Floor hallway adjacent to classroom 110	2/26/15	< 1		
RE-0226-12B	Raymond ES	1st Floor hallway adjacent to classroom 110	2/26/15	< 1		
RE-0226-13A	Raymond ES	1st Floor inside classroom 111	2/26/15	< 1		
RE-0226-13B	Raymond ES	1st Floor inside classroom 111	2/26/15	< 1		
RE-0226-14A	Raymond ES	1st Floor hallway adjacent to main office	2/26/15	< 1		
RE-0226-14B	Raymond ES	1st Floor hallway adjacent to main office	2/26/15	< 1		
RE-0226-15A	Raymond ES	1st Floor hallway across the Kitchen	2/26/15	< 1		
RE-0226-15B	Raymond ES	1st Floor hallway across the Kitchen	2/26/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
RE-0624-1A	Ross ES	Basement inside cafeteria (high)	6/24/15	< 1		
RE-0624-1B	Ross ES	Basement inside cafeteria (high)	6/24/15	< 1		
RE-0624-2A	Ross ES	Basement inside cafeteria (low)	6/24/15	< 1		
RE-0624-2B	Ross ES	Basement inside cafeteria (low)	6/24/15	< 1		
RE-0624-3A	Ross ES	Basement hallway across main office (high)	6/24/15	< 1		
RE-0624-3B	Ross ES	Basement hallway across main office (high)	6/24/15	< 1		
RE-0624-4A	Ross ES	Basement hallway across main office (low)	6/24/15	< 1		
RE-0624-4B	Ross ES	Basement hallway across main office (low)	6/24/15	< 1		
RE-0624-5A	Ross ES	1st Floor hallway adjacent to room 105 (high)	6/24/15	< 1		
RE-0624-5B	Ross ES	1st Floor hallway adjacent to room 105 (high)	6/24/15	< 1		
RE-0624-6A	Ross ES	1st Floor hallway adjacent to room 105 (low)	6/24/15	< 1		
RE-0624-6B	Ross ES	1st Floor hallway adjacent to room 105 (low)	6/24/15	< 1		
RE-0624-7A	Ross ES	2nd Floor hallway adjacent to room 204 (low)	6/24/15	< 1		
RE-0624-7B	Ross ES	2nd Floor hallway adjacent to room 204 (low)	6/24/15	< 1		
RE-0624-8A	Ross ES	2nd Floor hallway adjacent to room 204 (high)	6/24/15	< 1		
RE-0624-8B	Ross ES	2nd Floor hallway adjacent to room 204 (high)	6/24/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SES-0602-1A	Savoy ES	3rd Floor hallway across room 300 (high)	6/2/15	< 1		
SES-0602-1B	Savoy ES	3rd Floor hallway across room 300 (high)	6/2/15	< 1		
SES-0602-2A	Savoy ES	3rd Floor hallway across room 300 (low)	6/2/15	< 1		
SES-0602-2B	Savoy ES	3rd Floor hallway across room 300 (low)	6/2/15	< 1		
SES-0602-3A	Savoy ES	3rd Floor hallway across room 307 (high)	6/2/15	< 1		

SES-0602-3B	Savoy ES	3rd Floor hallway across room 307 (high)	6/2/15	< 1		
SES-0602-4A	Savoy ES	3rd Floor hallway across room 307 (low)	6/2/15	< 1		
SES-0602-4B	Savoy ES	3rd Floor hallway across room 307 (low)	6/2/15	< 1		
SES-0602-5A	Savoy ES	2nd Floor adjacent to room 203 (high)	6/2/15	< 1		
SES-0602-5B	Savoy ES	2nd Floor adjacent to room 203 (high)	6/2/15	< 1		
SES-0602-6A	Savoy ES	2nd Floor adjacent to room 203 (low)	6/2/15	< 1		
SES-0602-6B	Savoy ES	2nd Floor adjacent to room 203 (low)	6/2/15	< 1		
SES-0602-7A	Savoy ES	2nd Floor hallway across room 209 (high)	6/2/15	< 1		
SES-0602-7B	Savoy ES	2nd Floor hallway across room 209 (high)	6/2/15	< 1		
SES-0602-8A	Savoy ES	2nd Floor hallway across room 209 (low)	6/2/15	< 1		
SES-0602-8B	Savoy ES	2nd Floor hallway across room 209 (low)	6/2/15	< 1		
SES-0602-9A	Savoy ES	1st Floor inside class room 109	6/2/15	< 1		
SES-0602-9B	Savoy ES	1st Floor inside class room 109	6/2/15	< 1		
SES-0602-10A	Savoy ES	1st Floor inside class room 111	6/2/15	< 1		
SES-0602-10B	Savoy ES	1st Floor inside class room 111	6/2/15	< 1		
SES-0602-11A	Savoy ES	1st Floor inside class room 113	6/2/15	< 1		
SES-0602-11B	Savoy ES	1st Floor inside class room 113	6/2/15	< 1		
SES-0602-12A	Savoy ES	1st Floor inside class room 115	6/2/15	< 1		
SES-0602-12A	Savoy ES	1st Floor inside class room 115	6/2/15	< 1		
SES-0602-13A	Savoy ES	1st Floor inside class room 122	6/2/15	< 1		
SES-0602-13B	Savoy ES	1st Floor inside class room 122	6/2/15	< 1		
SES-0602-14A	Savoy ES	1st Floor inside class room 120	6/2/15	< 1		
SES-0602-14B	Savoy ES	1st Floor inside class room 120	6/2/15	< 1		
SES-0602-15A	Savoy ES	1st Floor hallway across room 107 (high)	6/2/15	< 1		
SES-0602-15B	Savoy ES	1st Floor hallway across room 107 (high)	6/2/15	< 1		
SES-0602-16A	Savoy ES	1st Floor hallway across room 107 (low)	6/2/15	< 1		
SES-0602-16B	Savoy ES	1st Floor hallway across room 107 (low)	6/2/15	< 1		
SES-0602-17A	Savoy ES	1st Floor hallway adjacent to cafeteria (high)	6/2/15	< 1		
SES-0602-17B	Savoy ES	1st Floor hallway adjacent to cafeteria (high)	6/2/15	< 1		
SES-0602-18B	Savoy ES	1st Floor hallway adjacent to cafeteria (low)	6/2/15	< 1		
SES-0602-18A	Savoy ES	1st Floor hallway adjacent to cafeteria (low)	6/2/15	< 1		
SES-0602-19B	Savoy ES	2nd Floor inside library (high)	6/2/15	< 1		
SES-0602-19A	Savoy ES	2nd Floor inside library (high)	6/2/15	< 1		
SES-0602-20B	Savoy ES	2nd Floor inside library (low)	6/2/15	< 1		
SES-0602-20A	Savoy ES	2nd Floor inside library (low)	6/2/15	< 1		
SES-0602-21B	Savoy ES	1st Floor lobby at TMA office (high)	6/2/15	< 1		
SES-0602-21B	Savoy ES	1st Floor lobby at TMA office (high)	6/2/15	< 1		
SES-0602-22B	Savoy ES	1st Floor lobby at TMA office (low)	6/2/15	< 1		
SES-0602-22B	Savoy ES	1st Floor lobby at TMA office (low)	6/2/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SWW-0129-1A	School Without Walls HS	3RD Floor Hallway across room 306 (High)	1/29/15	< 1		
SWW-0129-1B	School Without Walls HS	3RD Floor Hallway across room 306 (High)	1/29/15	< 1		
SWW-0129-2A	School Without Walls HS	3RD Floor Hallway across room 306 (Low)	1/29/15	< 1		
SWW-0129-2B	School Without Walls HS	3RD Floor Hallway across room 306 (Low)	1/29/15	< 1		
SWW-0129-3A	School Without Walls HS	2nd Floor hallway across room 206 (High)	1/29/15	< 1		
SWW-0129-3B	School Without Walls HS	2nd Floor hallway across room 206 (High)	1/29/15	< 1		
SWW-0129-4A	School Without Walls HS	2nd Floor hallway across room 206 (Low)	1/29/15	< 1		
SWW-0129-4B	School Without Walls HS	2nd Floor hallway across room 206 (Low)	1/29/15	< 1		
SWW-0129-5A	School Without Walls HS	1st Floor hallway across room 106 (High)	1/29/15	< 1		
SWW-0129-5B	School Without Walls HS	1st Floor hallway across room 106 (High)	1/29/15	< 1		
SWW-0129-6A	School Without Walls HS	1st Floor hallway across room 106 (Low)	1/29/15	< 1		
SWW-0129-6B	School Without Walls HS	1st Floor hallway across room 106 (Low)	1/29/15	< 1		
SWW-0129-7A	School Without Walls HS	Basement floor hallway adjacent to room 07 (High)	1/29/15	< 1		
SWW-0129-7B	School Without Walls HS	Basement floor hallway adjacent to room 07 (High)	1/29/15	< 1		

SWW-0129-8A	School Without Walls HS	Basement floor hallway adjacent to room 07 (Low)	1/29/15	< 1		
SWW-0129-8B	School Without Walls HS	Basement floor hallway adjacent to room 07 (Low)	1/29/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SE-0701-1A	Seaton ES	Third Floor inside Rm 307	7/1/15	< 1		
SE-0701-1B	Seaton ES	Third Floor inside Rm 307	7/1/15	< 1		
SE-0701-2A	Seaton ES	Third Floor inside Rm 309	7/1/15	< 1		
SE-0701-2B	Seaton ES	Third Floor inside Rm 309	7/1/15	< 1		
SE-0701-3A	Seaton ES	Third Floor Hallway adjacent to Rm 306	7/1/15	1.1		
SE-0701-3B	Seaton ES	Third Floor Hallway adjacent to Rm 306	7/1/15	< 1		
SE-0701-4A	Seaton ES	Third Floor Hallway adjacent to Girls' room	7/1/15	< 1		
SE-0701-4B	Seaton ES	Third Floor Hallway adjacent to Girls' room	7/1/15	< 1		
SE-0701-5A	Seaton ES	Second Floor Hallway adjacent to Rm 206	7/1/15	< 1		
SE-0701-5B	Seaton ES	Second Floor Hallway adjacent to Rm 206	7/1/15	< 1		
SE-0701-6A	Seaton ES	Second Floor Hallway adjacent to Girls' room	7/1/15	< 1		
SE-0701-6B	Seaton ES	Second Floor Hallway adjacent to Girls' room	7/1/15	< 1		
SE-0701-7A	Seaton ES	First Floor Hallway adjacent to Rm 106	7/1/15	< 1		
SE-0701-7B	Seaton ES	First Floor Hallway adjacent to Rm 106	7/1/15	< 1		
SE-0701-8A	Seaton ES	First Floor Hallway adjacent to restrooms	7/1/15	< 1		
SE-0701-8B	Seaton ES	First Floor Hallway adjacent to restrooms	7/1/15	< 1		
SE-0701-9A	Seaton ES	First Floor Hallway adjacent to Rm 109	7/1/15	< 1		
SE-0701-9B	Seaton ES	First Floor Hallway adjacent to Rm 109	7/1/15	< 1		
SE-0701-10A	Seaton ES	First Floor Hallway adjacent to Rm 111	7/1/15	< 1		
SE-0701-10B	Seaton ES	First Floor Hallway adjacent to Rm 111	7/1/15	< 1		
SE-0701-11A	Seaton ES	First Floor inside nurse's room	7/1/15	< 1		
SE-0701-11B	Seaton ES	First Floor inside nurse's room	7/1/15	< 1		
SE-0701-12A	Seaton ES	First Floor inside cafeteria	7/1/15	< 1		
SE-0701-12B	Seaton ES	First Floor inside cafeteria	7/1/15	< 1		
SE-0701-13A	Seaton ES	First Floor inside Rm 122	7/1/15	< 1		
SE-0701-13B	Seaton ES	First Floor inside Rm 122	7/1/15	< 1		
SE-0701-14A	Seaton ES	First Floor inside Rm 124	7/1/15	< 1		
SE-0701-14B	Seaton ES	First Floor inside Rm 124	7/1/15	< 1		
SE-0701-15A	Seaton ES	First Floor inside Rm 127	7/1/15	< 1		
SE-0701-15B	Seaton ES	First Floor inside Rm 127	7/1/15	< 1		
SE-0701-16A	Seaton ES	First Floor inside Rm 125	7/1/15	< 1		
SE-0701-16B	Seaton ES	First Floor inside Rm 125	7/1/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SH-0710-1A	Sharpe Health School	First floor adjacent to principal's office	7/10/15	< 1		
SH-0710-1B	Sharpe Health School	First floor adjacent to principal's office	7/10/15	< 1		
SH-0710-2A	Sharpe Health School	First floor hallway between women's restroom and book store	7/10/15	< 1		
SH-0710-2B	Sharpe Health School	First floor hallway between women's restroom and book store	7/10/15	< 1		
SH-0710-3A	Sharpe Health School	First floor hallway between soda court and health lane	7/10/15	< 1		
SH-0710-3B	Sharpe Health School	First floor hallway between soda court and health lane	7/10/15	< 1		
SH-0710-4A	Sharpe Health School	First floor inside cafeteria	7/10/15	< 1		
SH-0710-4B	Sharpe Health School	First floor inside cafeteria	7/10/15	< 1		
SH-0710-5A	Sharpe Health School	First floor hallway across dining room	7/10/15	< 1		
SH-0710-5B	Sharpe Health School	First floor hallway across dining room	7/10/15	< 1		
SH-0710-6A	Sharpe Health School	First floor hallway adjacent to room 207	7/10/15	< 1		
SH-0710-6B	Sharpe Health School	First floor hallway adjacent to room 207	7/10/15	< 1		
SH-0710-7A	Sharpe Health School	First floor near the pool area	7/10/15	< 1		
SH-0710-7B	Sharpe Health School	First floor near the pool area	7/10/15	< 1		
SH-0710-8A	Sharpe Health School	First floor hallway adjacent to room 106	7/10/15	< 1		
SH-0710-8B	Sharpe Health School	First floor hallway adjacent to room 106	7/10/15	< 1		

SH-0710-9A	Sharpe Health School	First Floor hallway between health lane and elementary avenue (across men's locker room)	7/10/15	< 1		
SH-0710-9B	Sharpe Health School	First Floor hallway between health lane and elementary avenue (across men's locker room)	7/10/15	< 1		
SH-0710-10A	Sharpe Health School	First Floor Hallway across room 15	7/10/15	< 1		
SH-0710-10B	Sharpe Health School	First Floor Hallway across room 15	7/10/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SES-0129-1A	Shepherd ES	2nd floor hallway across from Classroom C204 (high)	1/29/15	< 1		
SES-0129-1B	Shepherd ES	2nd floor hallway across from Classroom C204 (high)	1/29/15	< 1		
SES-0129-2A	Shepherd ES	2nd floor hallway across from Classroom C204 (low)	1/29/15	< 1		
SES-0129-2B	Shepherd ES	2nd floor hallway across from Classroom C204 (low)	1/29/15	< 1		
SES-0129-3A	Shepherd ES	2nd floor hallway across from Classroom C203 (high)	1/29/15	< 1		
SES-0129-3B	Shepherd ES	2nd floor hallway across from Classroom C203 (high)	1/29/15	< 1		
SES-0129-4A	Shepherd ES	2nd floor hallway across from Classroom C203 (low)	1/29/15	< 1		
SES-0129-4B	Shepherd ES	2nd floor hallway across from Classroom C203 (low)	1/29/15	< 1		
SES-0129-5A	Shepherd ES	2nd floor hallway adjacent to Classroom A210	1/29/15	< 1		
SES-0129-5B	Shepherd ES	2nd floor hallway adjacent to Classroom A210	1/29/15	< 1		
SES-0129-6A	Shepherd ES	2nd floor hallway adjacent to Classroom A201	1/29/15	< 1		
SES-0129-6B	Shepherd ES	2nd floor hallway adjacent to Classroom A201	1/29/15	< 1		
SES-0129-7A	Shepherd ES	1st floor inside Classroom A101	1/29/15	< 1		
SES-0129-7B	Shepherd ES	1st floor inside Classroom A101	1/29/15	< 1		
SES-0129-8A	Shepherd ES	1st floor inside Classroom A102	1/29/15	< 1		
SES-0129-8B	Shepherd ES	1st floor inside Classroom A102	1/29/15	< 1		
SES-0129-9A	Shepherd ES	1st floor inside Classroom 103	1/29/15	< 1		
SES-0129-9B	Shepherd ES	1st floor inside Classroom 103	1/29/15	< 1		
SES-0129-10A	Shepherd ES	1st floor hallway adjacent to Classroom A106	1/29/15	< 1		
SES-0129-10B	Shepherd ES	1st floor hallway adjacent to Classroom A106	1/29/15	< 1		
SES-0129-11A	Shepherd ES	1st floor inside Classroom 106	1/29/15	< 1		
SES-0129-11B	Shepherd ES	1st floor inside Classroom 106	1/29/15	< 1		
SES-0129-12A	Shepherd ES	1st floor hallway across from Classroom B105 (high)	1/29/15	< 1		
SES-0129-12B	Shepherd ES	1st floor hallway across from Classroom B105 (high)	1/29/15	< 1		
SES-0129-13A	Shepherd ES	1st floor hallway across from Classroom B105 (low)	1/29/15	< 1		
SES-0129-13B	Shepherd ES	1st floor hallway across from Classroom B105 (low)	1/29/15	< 1		
SES-0129-14A	Shepherd ES	Ground floor hallway adjacent to Classroom AG104 (high)	1/29/15	< 1		
SES-0129-14B	Shepherd ES	Ground floor hallway adjacent to Classroom AG104 (high)	1/29/15	< 1		
SES-0129-15A	Shepherd ES	Ground floor hallway adjacent to Classroom AG104 (low)	1/29/15	< 1		
SES-0129-15B	Shepherd ES	Ground floor hallway adjacent to Classroom AG104 (low)	1/29/15	< 1		
SES-0129-16A	Shepherd ES	Ground floor inside Cafeteria	1/29/15	< 1		
SES-0129-16B	Shepherd ES	Ground floor inside Cafeteria	1/29/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SES-0604-1A	Simon ES	3rd Floor hallway adjacent to storage room 305	6/4/15	< 1		
SES-0604-1B	Simon ES	3rd Floor hallway adjacent to storage room 305	6/4/15	< 1		
SES-0604-2A	Simon ES	2nd Floor hallway adjacent to Janitor closet 211	6/4/15	< 1		
SES-0604-2B	Simon ES	2nd Floor hallway adjacent to Janitor closet 211	6/4/15	< 1		
SES-0604-3A	Simon ES	2nd Floor hallway adjacent to Janitor closet 205	6/4/15	< 1		
SES-0604-3B	Simon ES	2nd Floor hallway adjacent to Janitor closet 205	6/4/15	< 1		
SES-0604-4A	Simon ES	1st Floor hallway adjacent to storage 105	6/4/15	< 1		
SES-0604-4B	Simon ES	1st Floor hallway adjacent to storage 105	6/4/15	< 1		
SES-0604-5A	Simon ES	1st Floor hallway adjacent to Janitor closet 116	6/4/15	< 1		
SES-0604-5B	Simon ES	1st Floor hallway adjacent to Janitor closet 116	6/4/15	< 1		
SES-0604-6A	Simon ES	1st Floor inside class room 115	6/4/15	< 1		
SES-0604-6B	Simon ES	1st Floor inside class room 115	6/4/15	< 1		
SES-0604-7A	Simon ES	Ground Floor hallway across storage 005	6/4/15	< 1		

SES-0604-7B	Simon ES	Ground Floor hallway across storage 005	6/4/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SE-0325-1A	Smothers ES	3rd Floor hallway adjacent to class room 310	3/25/15	< 1		
SE-0325-1B	Smothers ES	3rd Floor hallway adjacent to class room 310	3/25/15	< 1		
SE-0325-2A	Smothers ES	3rd Floor hallway adjacent to class room 301	3/25/15	< 1		
SE-0325-2B	Smothers ES	3rd Floor hallway adjacent to class room 301	3/25/15	< 1		
SE-0325-3A	Smothers ES	2nd Floor hallway adjacent to classroom 201	3/25/15	< 1		
SE-0325-3B	Smothers ES	2nd Floor hallway adjacent to classroom 201	3/25/15	< 1		
SE-0325-4A	Smothers ES	2nd Floor hallway adjacent to classroom 212	3/25/15	< 1		
SE-0325-4B	Smothers ES	2nd Floor hallway adjacent to classroom 212	3/25/15	2.2		
SE-0325-5A	Smothers ES	1st Floor hallway adjacent to classroom 108	3/25/15	< 1		
SE-0325-5B	Smothers ES	1st Floor hallway adjacent to classroom 108	3/25/15	< 1		
SE-0325-6A	Smothers ES	1st Floor hallway adjacent to classroom 104	3/25/15	< 1		
SE-0325-6B	Smothers ES	1st Floor hallway adjacent to classroom 104	3/25/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SM-0310-1A	Sousa MS	3rd Floor inside classroom B304 (science room- clockwise sink 1)	3/10/15	< 1		
SM-0310-1B	Sousa MS	3rd Floor inside classroom B304 (science room-clockwise sink 1)	3/10/15	< 1		
SM-0310-2A	Sousa MS	3rd Floor inside classroom B304 (science room- Sink 2)	3/10/15		16	Filter Installed
SM-0310-2B	Sousa MS	3rd Floor inside classroom B304 (science room sink 2)	3/10/15	< 1		
SM-0310-3A	Sousa MS	3rd Floor inside classroom B304 (science room sink 3)	3/10/15	< 1		
SM-0310-3B	Sousa MS	3rd Floor inside classroom B304 (science room sink 3)	3/10/15	< 1		
SM-0310-4A	Sousa MS	3rd Floor inside classroom B304 (science room sink 4)	3/10/15	< 1		
SM-0310-4B	Sousa MS	3rd Floor inside classroom B304 (science room sink 4)	3/10/15	< 1		
SM-0310-5A	Sousa MS	3rd Floor inside classroom B304 (science room sink 5)	3/10/15	< 1		
SM-0310-5B	Sousa MS	3rd Floor inside classroom B304 (science room sink 5)	3/10/15	< 1		
SM-0310-6A	Sousa MS	3rd Floor inside classroom B304 (science room sink 6)	3/10/15	2.3		
SM-0310-6B	Sousa MS	3rd Floor inside classroom B304 (science room sink 6)	3/10/15	< 1		
SM-0310-7A	Sousa MS	3rd Floor inside classroom A309 (science room- clockwise sink 1)	3/10/15	< 1		
SM-0310-7B	Sousa MS	3rd Floor inside classroom A309 (science room- clockwise sink 1)	3/10/15	< 1		
SM-0310-8A	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 2)	3/10/15	6.9		
SM-0310-8B	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 2)	3/10/15	< 1		
SM-0310-9A	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 3)	3/10/15		44	Filter Installed
SM-0310-9B	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 3)	3/10/15	7.4		
SM-0310-10A	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 4)	3/10/15		22	Filter Installed
SM-0310-10B	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 4)	3/10/15	3.7		
SM-0310-11A	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 5)	3/10/15	< 1		
SM-0310-11B	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 5)	3/10/15	< 1		
SM-0310-12A	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 6)	3/10/15	< 1		
SM-0310-12B	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 6)	3/10/15	< 1		
SM-0310-13A	Sousa MS	3rd Floor hallway across classroom A302 (high)	3/10/15	< 1		
SM-0310-13B	Sousa MS	3rd Floor hallway across classroom A302 (high)	3/10/15	< 1		
SM-0310-14A	Sousa MS	3rd Floor hallway across classroom A302 (low)	3/10/15	< 1		
SM-0310-14B	Sousa MS	3rd Floor hallway across classroom A302 (low)	3/10/15	< 1		
SM-0310-15A	Sousa MS	3rd Floor hallway adjacent to classroom C301	3/10/15	< 1		
SM-0310-15B	Sousa MS	3rd Floor hallway adjacent to classroom C301	3/10/15	< 1		
SM-0310-16A	Sousa MS	2nd Floor hallway adjacent to classroom C201 (high)	3/10/15	< 1		
SM-0310-16B	Sousa MS	2nd Floor hallway adjacent to classroom C201 (high)	3/10/15	< 1		
SM-0310-17A	Sousa MS	3rd Floor inside classroom A309 (science room- clockwise sink 1)	3/10/15	< 1		
SM-0310-17B	Sousa MS	3rd Floor inside classroom A309 (science room- clockwise sink 1)	3/10/15	< 1		
SM-0310-18A	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 2)	3/10/15	< 1		
SM-0310-18B	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 2)	3/10/15	< 1		
SM-0310-19A	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 3)	3/10/15	< 1		
SM-0310-19B	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 3)	3/10/15	< 1		

SM-0310-20A	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 4)	3/10/15	< 1		
SM-0310-20B	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 4)	3/10/15	< 1		
SM-0310-21A	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 5)	3/10/15	1.3		
SM-0310-21B	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 5)	3/10/15	< 1		
SM-0310-22A	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 6)	3/10/15	< 1		
SM-0310-22B	Sousa MS	3rd Floor inside classroom A309 (science room- Sink 6)	3/10/15	< 1		
SM-0310-23A	Sousa MS	3rd Floor hallway across classroom A302 (high)	3/10/15	4.1		
SM-0310-23B	Sousa MS	3rd Floor hallway across classroom A302 (high)	3/10/15	< 1		
SM-0310-24A	Sousa MS	3rd Floor hallway across classroom A302 (low)	3/10/15	< 1		
SM-0310-24B	Sousa MS	3rd Floor hallway across classroom A302 (low)	3/10/15	< 1		
SM-0310-25A	Sousa MS	3rd Floor hallway adjacent to classroom C301	3/10/15	< 1		
SM-0310-25B	Sousa MS	3rd Floor hallway adjacent to classroom C301	3/10/15	< 1		
SM-0310-26A	Sousa MS	2nd Floor hallway adjacent to classroom C201 (high)	3/10/15	< 1		
SM-0310-26B	Sousa MS	2nd Floor hallway adjacent to classroom C201 (high)	3/10/15	< 1		
SM-0310-27A	Sousa MS	2nd Floor inside classroom A209 (science room- Sink 4)	3/10/15	1.9		
SM-0310-27B	Sousa MS	2nd Floor inside classroom A209 (science room- Sink 4)	3/10/15	< 1		
SM-0310-28A	Sousa MS	2nd Floor inside classroom A209 (science room- Sink 5)	3/10/15	< 1		
SM-0310-28B	Sousa MS	2nd Floor inside classroom A209 (science room- Sink 5)	3/10/15	< 1		
SM-0310-29A	Sousa MS	2nd Floor inside classroom A209 (science room- Sink 6)	3/10/15	< 1		
SM-0310-29B	Sousa MS	2nd Floor inside classroom A209 (science room- Sink 6)	3/10/15	< 1		
SM-0310-30A	Sousa MS	2nd Floor hallway across classroom A202 (high)	3/10/15	< 1		
SM-0310-30B	Sousa MS	2nd Floor hallway across classroom A202 (high)	3/10/15	< 1		
SM-0310-31A	Sousa MS	2nd Floor hallway across classroom A202 (low)	3/10/15	< 1		
SM-0310-31B	Sousa MS	2nd Floor hallway across classroom A202 (low)	3/10/15	< 1		
SM-0310-32A	Sousa MS	1st Floor hallway adjacent to classroom C101 (high)	3/10/15	< 1		
SM-0310-32B	Sousa MS	1st Floor hallway adjacent to classroom C101 (high)	3/10/15	< 1		
SM-0310-33A	Sousa MS	1st Floor hallway adjacent to classroom C101 (low)	3/10/15	< 1		
SM-0310-33B	Sousa MS	1st Floor hallway adjacent to classroom C101 (low)	3/10/15	< 1		
SM-0310-34A	Sousa MS	1st Floor hallway across classroom A102 (high)	3/10/15	< 1		
SM-0310-34B	Sousa MS	1st Floor hallway across classroom A102 (high)	3/10/15	< 1		
SM-0310-35A	Sousa MS	1st Floor hallway across classroom A102 (low)	3/10/15	< 1		
SM-0310-35B	Sousa MS	1st Floor hallway across classroom A102 (low)	3/10/15	< 1		
SM-0310-36A	Sousa MS	1st Floor inside classroom B104 (science room- clockwise sink 1)	3/10/15	11		
SM-0310-36B	Sousa MS	1st Floor inside classroom B104 (science room- clockwise sink 1)	3/10/15	< 1		
SM-0310-37A	Sousa MS	1st Floor inside classroom B104 (science room- Sink 2)	3/10/15	7.5		
SM-0310-37B	Sousa MS	1st Floor inside classroom B104 (science room- Sink 2)	3/10/15	< 1		
SM-0310-38A	Sousa MS	1st Floor inside classroom B104 (science room- Sink 3)	3/10/15	3.2		
SM-0310-38B	Sousa MS	1st Floor inside classroom B104 (science room- Sink 3)	3/10/15	3.8		
SM-0310-39A	Sousa MS	1st Floor inside classroom B104 (science room- Sink 4)	3/10/15		250	Filter Installed
SM-0310-39B	Sousa MS	1st Floor inside classroom B104 (science room- Sink 4)	3/10/15		19	Filter Installed
SM-0310-40A	Sousa MS	1st Floor inside classroom B104 (science room- Sink 5)	3/10/15	6.7		
SM-0310-40B	Sousa MS	1st Floor inside classroom B104 (science room- Sink 5)	3/10/15	1.8		
SM-0310-41A	Sousa MS	1st Floor inside classroom B104 (science room- Sink 6)	3/10/15	< 1		
SM-0310-41B	Sousa MS	1st Floor inside classroom B104 (science room- Sink 6)	3/10/15	< 1		
SM-0310-42A	Sousa MS	1st Floor hallway adjacent to Gymnasium D111 (high)	3/10/15	< 1		
SM-0310-42B	Sousa MS	1st Floor hallway adjacent to Gymnasium D111 (high)	3/10/15	< 1		
SM-0310-43A	Sousa MS	1st Floor hallway adjacent to Gymnasium D111 (low)	3/10/15	< 1		
SM-0310-43B	Sousa MS	1st Floor hallway adjacent to Gymnasium D111 (low)	3/10/15	< 1		
SM-0310-44A	Sousa MS	1st Floor hallway adjacent to room B122	3/10/15	< 1		
SM-0310-44B	Sousa MS	1st Floor hallway adjacent to room B122	3/10/15	< 1		
SM-0310-45A	Sousa MS	1st Floor hallway adjacent to room B122	3/10/15	< 1		
SM-0310-45B	Sousa MS	1st Floor hallway adjacent to room B122	3/10/15	< 1		
<b>Percentage of Passed Samples</b>						<b>94.44%</b>
<b>Percentage of Failed Samples</b>						<b>5.56%</b>
STE-0603-1A	Stanton ES	3rd Floor hallway across class room 314 (high)	6/3/15	< 1		

STE-0603-1B	Stanton ES	3rd Floor hallway across class room 314 (high)	6/3/15	< 1		
STE-0603-2A	Stanton ES	3rd Floor hallway across class room 314 (low)	6/3/15	< 1		
STE-0603-2B	Stanton ES	3rd Floor hallway across class room 314 (low)	6/3/15	< 1		
STE-0603-3A	Stanton ES	3rd Floor hallway across class room 310 (high)	6/3/15	< 1		
STE-0603-3B	Stanton ES	3rd Floor hallway across class room 310 (high)	6/3/15	< 1		
STE-0603-4A	Stanton ES	3rd Floor hallway across class room 310 (low)	6/3/15	< 1		
STE-0603-4B	Stanton ES	3rd Floor hallway across class room 310 (low)	6/3/15	< 1		
STE-0603-5A	Stanton ES	2nd Floor hallway across class room 207 (high)	6/3/15	< 1		
STE-0603-5B	Stanton ES	2nd Floor hallway across class room 207 (high)	6/3/15	< 1		
STE-0603-6A	Stanton ES	2nd Floor hallway across class room 207 (low)	6/3/15	< 1		
STE-0603-6B	Stanton ES	2nd Floor hallway across class room 207 (low)	6/3/15	< 1		
STE-0603-7A	Stanton ES	2nd Floor hallway adjacent to class room 212 (High)	6/3/15	< 1		
STE-0603-7B	Stanton ES	2nd Floor hallway adjacent to class room 212 (High)	6/3/15	< 1		
STE-0603-8A	Stanton ES	2nd Floor hallway adjacent to class room 212 (low)	6/3/15	< 1		
STE-0603-8B	Stanton ES	2nd Floor hallway adjacent to class room 212 (low)	6/3/15	< 1		
STE-0603-9A	Stanton ES	1st Floor hallway across room 116 (high)	6/3/15	< 1		
STE-0603-9B	Stanton ES	1st Floor hallway across room 116 (high)	6/3/15	< 1		
STE-0603-10A	Stanton ES	1st Floor hallway across room 116 (low)	6/3/15	< 1		
STE-0603-10B	Stanton ES	1st Floor hallway across room 116 (low)	6/3/15	< 1		
STE-0603-11A	Stanton ES	1st Floor hallway adjacent to janitor closet 108A (high)	6/3/15	< 1		
STE-0603-11B	Stanton ES	1st Floor hallway adjacent to janitor closet 108A (high)	6/3/15	< 1		
STE-0603-12A	Stanton ES	1st Floor hallway adjacent to janitor closet 108A (low)	6/3/15	< 1		
STE-0603-12B	Stanton ES	1st Floor hallway adjacent to janitor closet 108A (low)	6/3/15	< 1		
STE-0603-13A	Stanton ES	Basement Floor hallway adjacent to B106A janitor closet (high)	6/3/15	< 1		
STE-0603-13B	Stanton ES	Basement Floor hallway adjacent to B106A janitor closet (high)	6/3/15	< 1		
STE-0603-14A	Stanton ES	Basement Floor hallway adjacent to B106A janitor closet (low)	6/3/15	< 1		
STE-0603-14B	Stanton ES	Basement Floor hallway adjacent to B106A janitor closet (low)	6/3/15	< 1		
STE-0603-15A	Stanton ES	Basement Floor inside cafeteria	6/3/15	< 1		
STE-0603-15B	Stanton ES	Basement Floor inside cafeteria	6/3/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SE-0320-1A	Stoddert ES	1st Floor inside classroom 142	3/20/15	< 1		
SE-0320-1B	Stoddert ES	1st Floor inside classroom 142	3/20/15	< 1		
SE-0320-2A	Stoddert ES	1st Floor inside classroom 144	3/20/15	< 1		
SE-0320-2B	Stoddert ES	1st Floor inside classroom 144	3/20/15	< 1		
SE-0320-3A	Stoddert ES	1st Floor inside classroom 147	3/20/15	< 1		
SE-0320-3B	Stoddert ES	1st Floor inside classroom 147	3/20/15	< 1		
SE-0320-4A	Stoddert ES	1st Floor inside classroom 145	3/20/15	< 1		
SE-0320-4B	Stoddert ES	1st Floor inside classroom 145	3/20/15	< 1		
SE-0320-5A	Stoddert ES	1st Floor inside classroom 146	3/20/15	< 1		
SE-0320-5B	Stoddert ES	1st Floor inside classroom 146	3/20/15	< 1		
SE-0320-6A	Stoddert ES	1st Floor hallway between 125-126 rest rooms	3/20/15	< 1		
SE-0320-6B	Stoddert ES	1st Floor hallway between 125-126 rest rooms	3/20/15	< 1		
SE-0320-7A	Stoddert ES	1st Floor hallway between 125-126 rest rooms	3/20/15	< 1		
SE-0320-7B	Stoddert ES	1st Floor hallway between 125-126 rest rooms	3/20/15	< 1		
SE-0320-8A	Stoddert ES	1st Floor inside classroom 132	3/20/15	< 1		
SE-0320-8B	Stoddert ES	1st Floor inside classroom 132	3/20/15	< 1		
SE-0320-9A	Stoddert ES	1st Floor inside classroom 133	3/20/15	< 1		
SE-0320-9B	Stoddert ES	1st Floor inside classroom 133	3/20/15	< 1		
SE-0320-10A	Stoddert ES	1st Floor inside classroom 134	3/20/15	< 1		
SE-0320-10B	Stoddert ES	1st Floor inside classroom 134	3/20/15	< 1		
SE-0320-11A	Stoddert ES	1st Floor inside classroom 131	3/20/15	< 1		
SE-0320-11B	Stoddert ES	1st Floor inside classroom 131	3/20/15	< 1		
SE-0320-12A	Stoddert ES	2nd Floor inside multipurpose rooms	3/20/15	< 1		
SE-0320-12B	Stoddert ES	2nd Floor inside multipurpose rooms	3/20/15	< 1		

SE-0320-13A	Stoddert ES	2nd Floor inside multipurpose rooms	3/20/15	< 1		
SE-0320-13B	Stoddert ES	2nd Floor inside multipurpose rooms	3/20/15	< 1		
SE-0320-14A	Stoddert ES	2nd Floor inside classroom 230	3/20/15	< 1		
SE-0320-14B	Stoddert ES	2nd Floor inside classroom 230	3/20/15	< 1		
SE-0320-15A	Stoddert ES	2nd Floor inside classroom 231	3/20/15	< 1		
SE-0320-15B	Stoddert ES	2nd Floor inside classroom 231	3/20/15	< 1		
SE-0320-16A	Stoddert ES	2nd Floor inside classroom 232	3/20/15	< 1		
SE-0320-16B	Stoddert ES	2nd Floor inside classroom 232	3/20/15	< 1		
SE-0320-17A	Stoddert ES	2nd Floor inside classroom 233	3/20/15	< 1		
SE-0320-17B	Stoddert ES	2nd Floor inside classroom 233	3/20/15	< 1		
SE-0320-18A	Stoddert ES	2nd Floor inside classroom 234	3/20/15	< 1		
SE-0320-18B	Stoddert ES	2nd Floor inside classroom 234	3/20/15	< 1		
SE-0320-19A	Stoddert ES	2nd Floor inside classroom 245	3/20/15	< 1		
SE-0320-19B	Stoddert ES	2nd Floor inside classroom 245	3/20/15	< 1		
SE-0320-20A	Stoddert ES	2nd Floor inside classroom 246	3/20/15	< 1		
SE-0320-20B	Stoddert ES	2nd Floor inside classroom 246	3/20/15	< 1		
SE-0320-21A	Stoddert ES	2nd Floor inside classroom 247	3/20/15	1		
SE-0320-21B	Stoddert ES	2nd Floor inside classroom 247	3/20/15	2.1		
SE-0320-22A	Stoddert ES	2nd Floor hallway between 225-226 rest rooms	3/20/15	< 1		
SE-0320-22B	Stoddert ES	2nd Floor hallway between 225-226 rest rooms	3/20/15	< 1		
SE-0320-23A	Stoddert ES	2nd Floor hallway between 225-226 rest rooms	3/20/15	< 1		
SE-0320-23B	Stoddert ES	2nd Floor hallway between 225-226 rest rooms	3/20/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
SH-0702-1A	Stuart Hobson MS	Second Floor Hallway adjacent to Rm 218	7/2/15	< 1		
SH-0702-1B	Stuart Hobson MS	Second Floor Hallway adjacent to Rm 218	7/2/15	< 1		
SH-0702-2A	Stuart Hobson MS	Second Floor Hallway across Rm 205	7/2/15	< 1		
SH-0702-2B	Stuart Hobson MS	Second Floor Hallway across Rm 205	7/2/15	< 1		
SH-0702-3A	Stuart Hobson MS	Third Floor Hallway adjacent to Rm 312	7/2/15	< 1		
SH-0702-3B	Stuart Hobson MS	Third Floor Hallway adjacent to Rm 312	7/2/15	< 1		
SH-0702-4A	Stuart Hobson MS	First Floor Hallway across Rm 109	7/2/15	< 1		
SH-0702-4B	Stuart Hobson MS	First Floor Hallway across Rm 109	7/2/15	< 1		
SH-0702-5A	Stuart Hobson MS	First Floor Hallway across Rm 118	7/2/15	1.1		
SH-0702-5B	Stuart Hobson MS	First Floor Hallway across Rm 118	7/2/15	1.2		
SH-0702-6A	Stuart Hobson MS	First Floor Hallway across Rm 105	7/2/15	< 1		
SH-0702-6B	Stuart Hobson MS	First Floor Hallway across Rm 105	7/2/15	< 1		
SH-0702-7A	Stuart Hobson MS	First Floor Inside Health Room 104	7/2/15	< 1		
SH-0702-7B	Stuart Hobson MS	First Floor Inside Health Room 104	7/2/15	< 1		
SH-0702-8A	Stuart Hobson MS	Basement Hallway near Rm G-09	7/2/15	< 1		
SH-0702-8B	Stuart Hobson MS	Basement Hallway near Rm G-09	7/2/15	< 1		
SH-0702-9A	Stuart Hobson MS	Inside Cafeteria Left	7/2/15	< 1		
SH-0702-9B	Stuart Hobson MS	Inside Cafeteria Left	7/2/15	< 1		
SH-0702-10A	Stuart Hobson MS	Inside Cafeteria Right	7/2/15	< 1		
SH-0702-10B	Stuart Hobson MS	Inside Cafeteria Right	7/2/15	< 1		
SH-0702-11A	Stuart Hobson MS	Basement Hallway near Rm G-05	7/2/15	< 1		
SH-0702-11B	Stuart Hobson MS	Basement Hallway near Rm G-05	7/2/15	< 1		
SH-0702-12A	Stuart Hobson MS	Basement Hallway near Gym G-15 H	7/2/15	< 1		
SH-0702-12B	Stuart Hobson MS	Basement Hallway near Gym G-15 H	7/2/15	< 1		
SH-0702-13A	Stuart Hobson MS	Basement Hallway near Gym G-15 L	7/2/15	< 1		
SH-0702-13B	Stuart Hobson MS	Basement Hallway near Gym G-15 L	7/2/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
TEC-0709-1A	Takoma EC	Third Floor hallway between stair 2 & elevator 323 high	7/9/15	< 1		
TEC-0709-1B	Takoma EC	Third Floor hallway between stair 2 & elevator 323 high	7/9/15	< 1		
TEC-0709-2A	Takoma EC	Third Floor hallway between stair 2 & elevator 323 low	7/9/15	< 1		

TEC-0709-2B	Takoma EC	Third Floor hallway between stair 2 & elevator 323 low	7/9/15	< 1		
TEC-0709-3A	Takoma EC	Third Floor hallway between stair 4 & elevator 327 high	7/9/15	< 1		
TEC-0709-3B	Takoma EC	Third Floor hallway between stair 4 & elevator 327 high	7/9/15	< 1		
TEC-0709-4A	Takoma EC	Third Floor hallway between stair 4 & elevator 327 low	7/9/15	< 1		
TEC-0709-4B	Takoma EC	Third Floor hallway between stair 4 & elevator 327 low	7/9/15	< 1		
TEC-0709-5A	Takoma EC	Second Floor hallway between stair 2 & elevator 224 high	7/9/15	< 1		
TEC-0709-5B	Takoma EC	Second Floor hallway between stair 2 & elevator 224 high	7/9/15	< 1		
TEC-0709-6A	Takoma EC	Second Floor hallway between stair 2 & elevator 224 low	7/9/15	< 1		
TEC-0709-6B	Takoma EC	Second Floor hallway between stair 2 & elevator 224 low	7/9/15	< 1		
TEC-0709-7A	Takoma EC	Second Floor hallway between stair 4 & elevator 234 high	7/9/15	< 1		
TEC-0709-7B	Takoma EC	Second Floor hallway between stair 4 & elevator 234 high	7/9/15	< 1		
TEC-0709-8A	Takoma EC	Second Floor hallway between stair 4 & elevator 234 low	7/9/15	< 1		
TEC-0709-8B	Takoma EC	Second Floor hallway between stair 4 & elevator 234 low	7/9/15	< 1		
TEC-0709-9A	Takoma EC	First Floor Hallway adjacent to Rm 141 high	7/9/15	< 1		
TEC-0709-9B	Takoma EC	First Floor Hallway adjacent to Rm 141 high	7/9/15	< 1		
TEC-0709-10A	Takoma EC	First Floor Hallway adjacent to Rm 141 low	7/9/15	< 1		
TEC-0709-10B	Takoma EC	First Floor Hallway adjacent to Rm 141 low	7/9/15	< 1		
TEC-0709-11A	Takoma EC	First Floor Hallway adjacent to Rm 133 high	7/9/15	< 1		
TEC-0709-11B	Takoma EC	First Floor Hallway adjacent to Rm 133 high	7/9/15	< 1		
TEC-0709-12A	Takoma EC	First Floor Hallway adjacent to Rm 133 low	7/9/15	< 1		
TEC-0709-12B	Takoma EC	First Floor Hallway adjacent to Rm 133 low	7/9/15	< 1		
TEC-0709-13A	Takoma EC	First Floor Hallway adjacent to Rm G107	7/9/15	< 1		
TEC-0709-13B	Takoma EC	First Floor Hallway adjacent to Rm G107	7/9/15	< 1		
TEC-0709-14A	Takoma EC	First Floor Hallway adjacent to Rm G115	7/9/15	< 1		
TEC-0709-14B	Takoma EC	First Floor Hallway adjacent to Rm G115	7/9/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
TES-0824-1A	Thomas ES	First Floor Hallway closer to main entrance	8/24/15	< 1		
TES-0824-1B	Thomas ES	First Floor Hallway closer to main entrance	8/24/15	< 1		
TES-0824-2A	Thomas ES	Second Floor Hallway closer to 220	8/24/15	< 1		
TES-0824-2B	Thomas ES	Second Floor Hallway closer to 220	8/24/15	< 1		
TES-0824-3A	Thomas ES	Second floor Adjacent to 215	8/24/15	< 1		
TES-0824-3B	Thomas ES	Second Floor Adjacent to 215	8/24/15	< 1		
TES-0824-4A	Thomas ES	Second Floor Adjacent to stair A Level 2 (high)	8/24/15	< 1		
TES-0824-4B	Thomas ES	Second Floor Adjacent to stair A Level 2( high)	8/24/15	< 1		
TES-0824-5A	Thomas ES	Second Floor Adjacent to stair A Level 2(Low)	8/24/15	< 1		
TES-0824-5B	Thomas ES	Second Floor Adjacent to stair A Level 2(Low)	8/24/15	< 1		
TES-0824-6A	Thomas ES	Second Floor Across stair B Level 2 (high)	8/24/15	< 1		
TES-0824-6B	Thomas ES	Second Floor Across stair B Level 2 (high)	8/24/15	< 1		
TES-0824-7A	Thomas ES	Second Floor Across stair B Level 2 (low)	8/24/15	< 1		
TES-0824-7B	Thomas ES	Second Floor Across stair B Level 2 (low)	8/24/15	< 1		
TES-0824-8A	Thomas ES	First Floor Across stair B Level 1 (high)	8/24/15	< 1		
TES-0824-8B	Thomas ES	First Floor Across stair B Level 1 (high)	8/24/15	< 1		
TES-0824-9A	Thomas ES	First Floor Across stair B Level 1 (low)	8/24/15	< 1		
TES-0824-9B	Thomas ES	Second Floor Across stair B Level 1 (low)	8/24/15	< 1		
TES-0824-10A	Thomas ES	First Floor Across stair A Level 1 (high)	8/24/15	< 1		
TES-0824-10B	Thomas ES	First Floor Across stair A Level 1 (high)	8/24/15	< 1		
TES-0824-11A	Thomas ES	First Floor Across stair A Level 1 (low)	8/24/15	< 1		
TES-0824-11B	Thomas ES	First Floor Across stair A Level 1 (low)	8/24/15	< 1		
TES-0824-12A	Thomas ES	First Floor Inside Principal's office	8/24/15	< 1		
TES-0824-12B	Thomas ES	First Floor Inside Principal's office	8/24/15	< 1		
TES-0824-13A	Thomas ES	Third Floor near stair A Level 1(high).	8/24/15	< 1		
TES-0824-13B	Thomas ES	Third Floor near stair A Level 1(high).	8/24/15	< 1		
TES-0824-14A	Thomas ES	Third Floor near stair A Level 1(low).	8/24/15	< 1		
TES-0824-14B	Thomas ES	Third Floor near stair A Level 1(low).	8/24/15	< 1		

			Percentage of Passed Samples			100.00%
			Percentage of Failed Samples			0.00%
THES-0729-1A	Thomson ES	Third Floor inside room 310	7/29/15	< 1		
THES-0729-1B	Thomson ES	Third Floor inside room 310	7/29/15	< 1		
THES-0729-2A	Thomson ES	Third Floor inside room 309	7/29/15	< 1		
THES-0729-2B	Thomson ES	Third Floor inside room 309	7/29/15	< 1		
THES-0729-3A	Thomson ES	Third Floor inside room 307	7/29/15	< 1		
THES-0729-3B	Thomson ES	Third Floor inside room 307	7/29/15	< 1		
THES-0729-4A	Thomson ES	Third Floor hallway adjacent to girls' room (high)	7/29/15	< 1		
THES-0729-4B	Thomson ES	Third Floor hallway adjacent to girls' room (high)	7/29/15	< 1		
THES-0729-5A	Thomson ES	Third Floor hallway adjacent to girls' room (low)	7/29/15	< 1		
THES-0729-5B	Thomson ES	Third Floor hallway adjacent to girls' room (low)	7/29/15	< 1		
THES-0729-6A	Thomson ES	Second Floor hallway adjacent to girls' room (high)	7/29/15	< 1		
THES-0729-6B	Thomson ES	Second Floor hallway adjacent to girls' room (high)	7/29/15	< 1		
THES-0729-7A	Thomson ES	Second Floor hallway adjacent to girls' room (low)	7/29/15	< 1		
THES-0729-7B	Thomson ES	Second Floor hallway adjacent to girls' room (low)	7/29/15	< 1		
THES-0729-8A	Thomson ES	Second Floor inside room 223	7/29/15	< 1		
THES-0729-8B	Thomson ES	Second Floor inside room 223	7/29/15	< 1		
THES-0729-9A	Thomson ES	Second Floor inside room 221	7/29/15	< 1		
THES-0729-9B	Thomson ES	Second Floor inside room 221	7/29/15	< 1		
THES-0729-10A	Thomson ES	Second Floor inside room 220	7/29/15	< 1		
THES-0729-10B	Thomson ES	Second Floor inside room 220	7/29/15	< 1		
THES-0729-11A	Thomson ES	Second Floor inside room 219	7/29/15	< 1		
THES-0729-11B	Thomson ES	Second Floor inside room 219	7/29/15	< 1		
THES-0729-12A	Thomson ES	Second Floor inside room 204	7/29/15	1.3		
THES-0729-12B	Thomson ES	Second Floor inside room 204	7/29/15	< 1		
THES-0729-13A	Thomson ES	Second Floor inside room 208	7/29/15	< 1		
THES-0729-13B	Thomson ES	Second Floor inside room 208	7/29/15	< 1		
THES-0729-14A	Thomson ES	Second Floor inside room 209	7/29/15	< 1		
THES-0729-14B	Thomson ES	Second Floor inside room 209	7/29/15	< 1		
THES-0729-15A	Thomson ES	Second Floor inside room 210	7/29/15		19	Filter Installed.
THES-0729-15B	Thomson ES	Second Floor inside room 210	7/29/15	1.1		
THES-0729-16A	Thomson ES	Second Floor inside room 211	7/29/15	< 1		
THES-0729-16B	Thomson ES	Second Floor inside room 211	7/29/15	< 1		
THES-0729-17A	Thomson ES	Second Floor inside room 215	7/29/15	< 1		
THES-0729-17B	Thomson ES	Second Floor inside room 215	7/29/15	< 1		
THES-0729-18A	Thomson ES	First Floor hallway adjacent to room 129 (high)	7/29/15	< 1		
THES-0729-18B	Thomson ES	First Floor hallway adjacent to room 129 (high)	7/29/15	< 1		
THES-0729-19A	Thomson ES	First Floor hallway adjacent to room 129 (low)	7/29/15	< 1		
THES-0729-19B	Thomson ES	First Floor hallway adjacent to room 129 (low)	7/29/15	< 1		
THES-0729-20A	Thomson ES	First Floor inside room 124	7/29/15	< 1		
THES-0729-20B	Thomson ES	First Floor inside room 124	7/29/15	< 1		
THES-0729-21A	Thomson ES	First Floor inside room 126	7/29/15	< 1		
THES-0729-21B	Thomson ES	First Floor inside room 126	7/29/15	< 1		
THES-0729-22A	Thomson ES	First Floor inside room 127	7/29/15	< 1		
THES-0729-22B	Thomson ES	First Floor inside room 127	7/29/15	< 1		
THES-0729-23A	Thomson ES	First Floor inside room 123	7/29/15	< 1		
THES-0729-23B	Thomson ES	First Floor inside room 123	7/29/15	< 1		
THES-0729-24A	Thomson ES	First Floor inside room 112	7/29/15	< 1		
THES-0729-24B	Thomson ES	First Floor inside room 112	7/29/15	< 1		
THES-0729-25A	Thomson ES	First Floor inside room 115	7/29/15	< 1		
THES-0729-25B	Thomson ES	First Floor inside room 115	7/29/15	< 1		
THES-0729-26A	Thomson ES	First Floor inside room 114	7/29/15	< 1		
THES-0729-26B	Thomson ES	First Floor inside room 114	7/29/15	< 1		
THES-0729-27A	Thomson ES	First Floor inside room 113	7/29/15	< 1		

THES-0729-27B	Thomson ES	First Floor inside room 113	7/29/15	< 1			
THES-0729-28A	Thomson ES	Basement Floor hallway adjacent to room B01 (high)	7/29/15	< 1			
THES-0729-28B	Thomson ES	Basement Floor hallway adjacent to room B01 (high)	7/29/15	< 1			
THES-0729-29A	Thomson ES	Basement Floor hallway adjacent to room B01 (low)	7/29/15	< 1			
THES-0729-29B	Thomson ES	Basement Floor hallway adjacent to room B01 (low)	7/29/15	< 1			
THES-0729-30A	Thomson ES	Basement Floor hallway adjacent to room G02 (high)	7/29/15	< 1			
THES-0729-30B	Thomson ES	Basement Floor hallway adjacent to room G02 (high)	7/29/15	< 1			
THES-0729-31A	Thomson ES	Basement Floor hallway adjacent to room G02 (low)	7/29/15	< 1			
THES-0729-31B	Thomson ES	Basement Floor hallway adjacent to room G02 (low)	7/29/15	< 1			
					<b>Percentage of Passed Samples</b>		<b>98.39%</b>
					<b>Percentage of Failed Samples</b>		<b>1.61%</b>
TES-0728-1A	Truesdell ES	First floor hallway across room 117	7/28/15	< 1			
TES-0728-1B	Truesdell ES	First floor hallway across room 117	7/28/15	< 1			
TES-0728-2A	Truesdell ES	First floor hallway across room 126	7/28/15	< 1			
TES-0728-2B	Truesdell ES	First floor hallway across room 126	7/28/15	< 1			
TES-0728-3A	Truesdell ES	Second floor hallway across room 218	7/28/15	< 1			
TES-0728-3B	Truesdell ES	Second floor hallway across room 218	7/28/15	< 1			
TES-0728-4A	Truesdell ES	Second floor hallway across room 227	7/28/15	< 1			
TES-0728-4B	Truesdell ES	Second floor hallway across room 227	7/28/15	< 1			
TES-0728-5A	Truesdell ES	Basement floor hallway adjacent to room 012	7/28/15	< 1			
TES-0728-5B	Truesdell ES	Basement floor hallway adjacent to room 012	7/28/15	< 1			
TES-0728-6A	Truesdell ES	Basement floor inside nurse's room	7/28/15	< 1			
TES-0728-6B	Truesdell ES	Basement floor inside nurse's room	7/28/15	< 1			
TES-0728-7A	Truesdell ES	Third floor hallway adjacent to room 308	7/28/15	< 1			
TES-0728-7B	Truesdell ES	Third floor hallway adjacent to room 308	7/28/15	< 1			
TES-0728-8A	Truesdell ES	Third floor hallway adjacent to room 300	7/28/15	< 1			
TES-0728-8B	Truesdell ES	Third floor hallway adjacent to room 300	7/28/15	< 1			
TES-0728-9A	Truesdell ES	Second floor hallway adjacent to room 200	7/28/15	< 1			
TES-0728-9B	Truesdell ES	Second floor hallway adjacent to room 200	7/28/15	< 1			
TES-0728-10A	Truesdell ES	Second floor inside room 200	7/28/15		15	Filter Installed.	
TES-0728-10B	Truesdell ES	Second floor inside room 200	7/28/15	1.3			
TES-0728-11A	Truesdell ES	Second floor hallway adjacent to room 212	7/28/15	< 1			
TES-0728-11B	Truesdell ES	Second floor hallway adjacent to room 212	7/28/15	< 1			
TES-0728-12A	Truesdell ES	Second floor inside room 216	7/28/15	< 1			
TES-0728-12B	Truesdell ES	Second floor inside room 216	7/28/15	< 1			
TES-0728-13A	Truesdell ES	Second floor inside room 217	7/28/15	1.1			
TES-0728-13B	Truesdell ES	Second floor inside room 217	7/28/15	< 1			
TES-0728-14A	Truesdell ES	First floor inside room 114	7/28/15	< 1			
TES-0728-14B	Truesdell ES	First floor inside room 114	7/28/15	< 1			
TES-0728-15A	Truesdell ES	First floor inside room 115	7/28/15	< 1			
TES-0728-15B	Truesdell ES	First floor inside room 115	7/28/15	< 1			
TES-0728-16A	Truesdell ES	First floor hallway adjacent to room 111	7/28/15	< 1			
TES-0728-16B	Truesdell ES	First floor hallway adjacent to room 111	7/28/15	< 1			
TES-0728-17A	Truesdell ES	First floor hallway across room 103	7/28/15	1.3			
TES-0728-17B	Truesdell ES	First floor hallway across room 103	7/28/15	< 1			
TES-0728-18A	Truesdell ES	First floor inside room 100	7/28/15	< 1			
TES-0728-18B	Truesdell ES	First floor inside room 100	7/28/15	< 1			
TES-0728-19A	Truesdell ES	First floor inside room 101	7/28/15	< 1			
TES-0728-19B	Truesdell ES	First floor inside room 101	7/28/15	< 1			
					<b>Percentage of Passed Samples</b>		<b>97.37%</b>
					<b>Percentage of Failed Samples</b>		<b>2.63%</b>
TES-0717-1A	Tubman ES	Third floor hallway adjacent to room 308	7/17/15	< 1			
TES-0717-1B	Tubman ES	Third floor hallway adjacent to room 308	7/17/15	< 1			
TES-0717-2A	Tubman ES	Third floor hallway adjacent to room 306	7/17/15	< 1			
TES-0717-2B	Tubman ES	Third floor hallway adjacent to room 306	7/17/15	< 1			

TES-0717-3A	Tubman ES	Third floor hallway adjacent to room 301	7/17/15	< 1		
TES-0717-3B	Tubman ES	Third floor hallway adjacent to room 301	7/17/15	< 1		
TES-0717-4A	Tubman ES	Second floor hallway adjacent to room 208	7/17/15	< 1		
TES-0717-4B	Tubman ES	Second floor hallway adjacent to room 208	7/17/15	< 1		
TES-0717-5A	Tubman ES	Second floor hallway adjacent to room 206	7/17/15	< 1		
TES-0717-5B	Tubman ES	Second floor hallway adjacent to room 206	7/17/15	< 1		
TES-0717-6A	Tubman ES	Second floor hallway adjacent to room 201	7/17/15	< 1		
TES-0717-6B	Tubman ES	Second floor hallway adjacent to room 201	7/17/15	< 1		
TES-0717-7A	Tubman ES	First floor hallway restrooms	7/17/15	< 1		
TES-0717-7B	Tubman ES	First floor hallway restrooms	7/17/15	< 1		
TES-0717-8A	Tubman ES	First floor hallway adjacent to room 110	7/17/15	< 1		
TES-0717-8B	Tubman ES	First floor hallway adjacent to room 110	7/17/15	< 1		
TES-0717-9A	Tubman ES	First floor hallway inside room 115	7/17/15	< 1		
TES-0717-9B	Tubman ES	First floor hallway inside room 115	7/17/15	< 1		
TES-0717-10A	Tubman ES	First floor hallway inside room 113	7/17/15	< 1		
TES-0717-10B	Tubman ES	First floor hallway inside room 113	7/17/15	< 1		
TES-0717-11A	Tubman ES	First floor hallway inside room 111	7/17/15	< 1		
TES-0717-11B	Tubman ES	First floor hallway inside room 111	7/17/15	< 1		
TES-0717-12A	Tubman ES	First floor hallway inside room 106	7/17/15	1.5		
TES-0717-12B	Tubman ES	First floor hallway inside room 106	7/17/15	< 1		
TES-0717-13A	Tubman ES	First floor hallway inside room 108	7/17/15	< 1		
TES-0717-13B	Tubman ES	First floor hallway inside room 108	7/17/15	< 1		
TES-0717-14A	Tubman ES	First floor hallway inside room 110	7/17/15	< 1		
TES-0717-14B	Tubman ES	First floor hallway inside room 110	7/17/15	< 1		
TES-0717-15A	Tubman ES	First floor hallway inside health room	7/17/15	< 1		
TES-0717-15B	Tubman ES	First floor hallway inside health room	7/17/15	< 1		
TES-0717-16A	Tubman ES	First floor hallway inside room 114	7/17/15	< 1		
TES-0717-16B	Tubman ES	First floor hallway inside room 114	7/17/15	< 1		
TES-0717-17A	Tubman ES	First floor hallway inside room 119	7/17/15	< 1		
TES-0717-17B	Tubman ES	First floor hallway inside room 119	7/17/15	< 1		
TES-0717-18A	Tubman ES	First floor hallway inside room 120	7/17/15	< 1		
TES-0717-18B	Tubman ES	First floor hallway inside room 120	7/17/15	< 1		
TES-0717-19A	Tubman ES	First floor hallway inside room 121	7/17/15	< 1		
TES-0717-19B	Tubman ES	First floor hallway inside room 121	7/17/15	< 1		
TES-0717-20A	Tubman ES	First floor hallway inside room 122	7/17/15	< 1		
TES-0717-20B	Tubman ES	First floor hallway inside room 122	7/17/15	< 1		
TES-0717-21A	Tubman ES	First floor hallway inside cafeteria	7/17/15	< 1		
TES-0717-21B	Tubman ES	First floor hallway inside cafeteria	7/17/15	< 1		
TES-0717-22A	Tubman ES	First floor hallway across multi-purpose room	7/17/15	< 1		
TES-0717-22B	Tubman ES	First floor hallway across multi-purpose room	7/17/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
TES-0603-1A	Turner ES	3rd Floor hallway across class room 324 (high)	6/3/15	< 1		
TES-0603-1B	Turner ES	3rd Floor hallway across class room 324 (high)	6/3/15	< 1		
TES-0603-2A	Turner ES	3rd Floor hallway across class room 324 (low)	6/3/15	< 1		
TES-0603-2B	Turner ES	3rd Floor hallway across class room 324 (low)	6/3/15	< 1		
TES-0603-3A	Turner ES	3rd Floor hallway across class room 316 (high)	6/3/15	< 1		
TES-0603-3B	Turner ES	3rd Floor hallway across class room 316 (high)	6/3/15	< 1		
TES-0603-4A	Turner ES	3rd Floor hallway across class room 316 (low)	6/3/15	< 1		
TES-0603-4B	Turner ES	3rd Floor hallway across class room 316 (low)	6/3/15	< 1		
TES-0603-5A	Turner ES	3rd Floor hallway adjacent to room (high)	6/3/15	< 1		
TES-0603-5B	Turner ES	3rd Floor hallway adjacent to room (high)	6/3/15	< 1		
TES-0603-6A	Turner ES	3rd Floor hallway adjacent to room (low)	6/3/15	< 1		
TES-0603-6B	Turner ES	3rd Floor hallway adjacent to room (low)	6/3/15	< 1		
TES-0603-7A	Turner ES	3rd Floor hallway adjacent to janitor closet 302 (high)	6/3/15	< 1		

TES-0603-7B	Turner ES	3rd Floor hallway adjacent to janitor closet 302 (high)	6/3/15	< 1		
TES-0603-8A	Turner ES	3rd Floor hallway adjacent to janitor closet 302 (low)	6/3/15	< 1		
TES-0603-8B	Turner ES	3rd Floor hallway adjacent to janitor closet 302 (low)	6/3/15	< 1		
TES-0603-9A	Turner ES	2nd Floor hallway across room 203 (high)	6/3/15	< 1		
TES-0603-9B	Turner ES	2nd Floor hallway across room 203 (high)	6/3/15	< 1		
TES-0603-10A	Turner ES	2nd Floor hallway across room 203 (low)	6/3/15	< 1		
TES-0603-10B	Turner ES	2nd Floor hallway across room 203 (low)	6/3/15	< 1		
TES-0603-11A	Turner ES	2nd Floor hallway across library (high)	6/3/15	< 1		
TES-0603-11B	Turner ES	2nd Floor hallway across library (high)	6/3/15	< 1		
TES-0603-12A	Turner ES	2nd Floor hallway across library (low)	6/3/15	< 1		
TES-0603-12B	Turner ES	2nd Floor hallway across library (low)	6/3/15	< 1		
TES-0603-13A	Turner ES	2nd Floor hallway across stair B (high)	6/3/15	< 1		
TES-0603-13B	Turner ES	2nd Floor hallway across stair B (high)	6/3/15	< 1		
TES-0603-14A	Turner ES	2nd Floor hallway across stair B (low)	6/3/15	< 1		
TES-0603-14B	Turner ES	2nd Floor hallway across stair B (low)	6/3/15	< 1		
TES-0603-15A	Turner ES	2nd Floor hallway across class room 221 (high)	6/3/15	< 1		
TES-0603-15B	Turner ES	2nd Floor hallway across class room 221 (high)	6/3/15	< 1		
TES-0603-16A	Turner ES	2nd Floor hallway across class room 221 (low)	6/3/15	< 1		
TES-0603-16B	Turner ES	2nd Floor hallway across class room 221 (low)	6/3/15	< 1		
TES-0603-17A	Turner ES	1st Floor hallway at main office (high)	6/3/15	< 1		
TES-0603-17B	Turner ES	1st Floor hallway at main office (high)	6/3/15	< 1		
TES-0603-18A	Turner ES	1st Floor hallway at main office (low)	6/3/15	< 1		
TES-0603-18B	Turner ES	1st Floor hallway at main office (low)	6/3/15	< 1		
TES-0603-19A	Turner ES	1st Floor lobby across Gymnasium (high)	6/3/15	< 1		
TES-0603-19B	Turner ES	1st Floor lobby across Gymnasium (high)	6/3/15	< 1		
TES-0603-20A	Turner ES	1st Floor lobby across Gymnasium (low)	6/3/15	< 1		
TES-0603-20B	Turner ES	1st Floor lobby across Gymnasium (low)	6/3/15	< 1		
TES-0603-21A	Turner ES	1st Floor hallway across stair B (high)	6/3/15	< 1		
TES-0603-21B	Turner ES	1st Floor hallway across stair B (high)	6/3/15	< 1		
TES-0603-22A	Turner ES	1st Floor hallway across stair B (low)	6/3/15	< 1		
TES-0603-22B	Turner ES	1st Floor hallway across stair B (low)	6/3/15	< 1		
TES-0603-23A	Turner ES	1st Floor hallway across class room 109 (high)	6/3/15	< 1		
TES-0603-23B	Turner ES	1st Floor hallway across class room 109 (high)	6/3/15	< 1		
TES-0603-24A	Turner ES	1st Floor hallway across class room 109 (low)	6/3/15	< 1		
TES-0603-24B	Turner ES	1st Floor hallway across class room 109 (low)	6/3/15	< 1		
TES-0603-25A	Turner ES	1st Floor hallway across class room 106 (high)	6/3/15	< 1		
TES-0603-25B	Turner ES	1st Floor hallway across class room 106 (high)	6/3/15	< 1		
TES-0603-26A	Turner ES	1st Floor hallway across class room 106 (low)	6/3/15	< 1		
TES-0603-26B	Turner ES	1st Floor hallway across class room 106 (low)	6/3/15	< 1		
TES-0603-27A	Turner ES	1st Floor inside class room 106	6/3/15	< 1		
TES-0603-27B	Turner ES	1st Floor inside class room 106	6/3/15	< 1		
TES-0603-28A	Turner ES	1st Floor inside class room 107	6/3/15	< 1		
TES-0603-28B	Turner ES	1st Floor inside class room 107	6/3/15	< 1		
TES-0603-29A	Turner ES	1st Floor inside class room 108	6/3/15	< 1		
TES-0603-29B	Turner ES	1st Floor inside class room 108	6/3/15	< 1		
TES-0603-30A	Turner ES	1st Floor inside class room 109	6/3/15	< 1		
TES-0603-30B	Turner ES	1st Floor inside class room 109	6/3/15	< 1		
TES-0603-31A	Turner ES	1st Floor inside class room 112	6/3/15	< 1		
TES-0603-31B	Turner ES	1st Floor inside class room 112	6/3/15	< 1		
TES-0603-32A	Turner ES	1st Floor inside class room 113	6/3/15	< 1		
TES-0603-32B	Turner ES	1st Floor inside class room 113	6/3/15	< 1		
TES-0603-33A	Turner ES	1st Floor inside class room 116	6/3/15	1.4		
TES-0603-33B	Turner ES	1st Floor inside class room 116	6/3/15	< 1		
TES-0603-34A	Turner ES	1st Floor inside class room 117	6/3/15	< 1		

TES-0603-34B	Turner ES	1st Floor inside class room 117	6/3/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
TE-0619-1A	Tyler ES	3rd Floor hallway adjacent to room 303	6/19/15	< 1		
TE -0619-1B	Tyler ES	3rd Floor hallway adjacent to room 303	6/19/15	< 1		
TE-0619-2A	Tyler ES	3rd Floor hallway across storage 312	6/19/15	< 1		
TE-0619-2B	Tyler ES	3rd Floor hallway across storage 312	6/19/15	< 1		
TE-0619-3A	Tyler ES	2nd Floor hallway adjacent to media center 204	6/19/15	< 1		
TE-0619-3B	Tyler ES	2nd Floor hallway adjacent to media center 204	6/19/15	< 1		
TE-0619-4A	Tyler ES	2nd Floor hallway across storage 211	6/19/15	< 1		
TE-0619-4B	Tyler ES	2nd Floor hallway across storage 211	6/19/15	< 1		
TE-0619-5A	Tyler ES	1st Floor hallway across storage 111 (high)	6/19/15	< 1		
TE-0619-5B	Tyler ES	1st Floor hallway across storage 111 (high)	6/19/15	< 1		
TE-0619-6A	Tyler ES	1st Floor hallway across storage 111 (low)	6/19/15	< 1		
TE-0619-6B	Tyler ES	1st Floor hallway across storage 111 (low)	6/19/15	< 1		
TE-0619-7A	Tyler ES	1st Floor hallway adjacent to room 142 (high)	6/19/15	< 1		
TE-0619-7B	Tyler ES	1st Floor hallway adjacent to room 142 (high)	6/19/15	< 1		
TE-0619-8A	Tyler ES	1st Floor hallway adjacent to room 142 (low)	6/19/15	< 1		
TE-0619-8B	Tyler ES	1st Floor hallway adjacent to room 142 (low)	6/19/15	< 1		
TE-0619-9A	Tyler ES	1st Floor hallway adjacent to electrical room 138 (high)	6/19/15	< 1		
TE-0619-9B	Tyler ES	1st Floor hallway adjacent to electrical room 138 (high)	6/19/15	< 1		
TE-0619-10A	Tyler ES	1st Floor hallway adjacent to electrical room 138 (low)	6/19/15	< 1		
TE-0619-10B	Tyler ES	1st Floor hallway adjacent to electrical room 138 (low)	6/19/15	< 1		
TE-0619-11A	Tyler ES	1st Floor cafeteria	6/19/15	< 1		
TE-0619-11B	Tyler ES	1st Floor cafeteria	6/19/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
VNE-0224-1A	Van Ness ES	3rd Floor hallway across room 302	2/24/15	< 1		
VNE-0224-1B	Van Ness ES	3rd Floor hallway across room 302	2/24/15	< 1		
VNE-0224-2A	Van Ness ES	2nd Floor hallway adjacent to room 209	2/24/15	< 1		
VNE-0224-2B	Van Ness ES	2nd Floor hallway adjacent to room 209	2/24/15	< 1		
VNE-0224-3A	Van Ness ES	1st Floor hallway across room 3	2/24/15	< 1		
VNE-0224-3B	Van Ness ES	1st Floor hallway across room 3	2/24/15	< 1		
VNE-0224-4A	Van Ness ES	Ground Floor hallway across auditorium	2/24/15	< 1		
VNE-0224-4B	Van Ness ES	Ground Floor hallway across auditorium	2/24/15	< 1		
VNE-0224-5A	Van Ness ES	Ground Floor hallway across room 13	2/24/15	< 1		
VNE-0224-5B	Van Ness ES	Ground Floor hallway across room 13	2/24/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
WJ-0423-1A	Walker Jones ES	3rd floor inside Staff Lounge	4/23/15	< 1		
WJ-0423-1B	Walker Jones ES	3rd floor inside Staff Lounge	4/23/15	< 1		
WJ-0423-2A	Walker Jones ES	3rd floor hallway adjacent to Girl's RR 309 (high)	4/23/15	< 1		
WJ-0423-2B	Walker Jones ES	3rd floor hallway adjacent to Girl's RR 309 (high)	4/23/15	< 1		
WJ-0423-3A	Walker Jones ES	3rd floor hallway adjacent to Girl's RR 309 (low)	4/23/15	< 1		
WJ-0423-3B	Walker Jones ES	3rd floor hallway adjacent to Girl's RR 309 (low)	4/23/15	< 1		
WJ-0423-4A	Walker Jones ES	3rd floor inside Classroom 320 (clockwise from left)	4/23/15	4.5		
WJ-0423-4B	Walker Jones ES	3rd floor inside Classroom 320	4/23/15	< 1		
WJ-0423-5A	Walker Jones ES	3rd floor inside Classroom 320	4/23/15		21	Filter Installed
WJ-0423-5B	Walker Jones ES	3rd floor inside Classroom 320	4/23/15	5.5		
WJ-0423-6A	Walker Jones ES	3rd floor inside Classroom 320	4/23/15		20	Filter Installed
WJ-0423-6B	Walker Jones ES	3rd floor inside Classroom 320	4/23/15	3.8		
WJ-0423-7A	Walker Jones ES	3rd floor inside Classroom 324 (clockwise from front entrance)	4/23/15	7.8		
WJ-0423-7B	Walker Jones ES	3rd floor inside Classroom 324	4/23/15	1.6		
WJ-0423-8A	Walker Jones ES	3rd floor inside Classroom 324	4/23/15	4.1		
WJ-0423-8B	Walker Jones ES	3rd floor inside Classroom 324	4/23/15		19	Filter Installed

WJ-0423-9A	Walker Jones ES	3rd floor inside Classroom 324	4/23/15	6.8		
WJ-0423-9B	Walker Jones ES	3rd floor inside Classroom 324	4/23/15	1.3		
WJ-0423-10A	Walker Jones ES	2nd floor inside Classroom 206	4/23/15	< 1		
WJ-0423-10B	Walker Jones ES	2nd floor inside Classroom 208	4/23/15	< 1		
WJ-0423-11A	Walker Jones ES	2nd floor inside Classroom 208	4/23/15	1.8		
WJ-0423-11B	Walker Jones ES	2nd floor inside Classroom 210	4/23/15	< 1		
WJ-0423-12A	Walker Jones ES	2nd floor inside Classroom 210	4/23/15	< 1		
WJ-0423-12B	Walker Jones ES	2nd floor inside Classroom 212	4/23/15	< 1		
WJ-0423-13A	Walker Jones ES	2nd floor inside Classroom 212	4/23/15	< 1		
WJ-0423-13B	Walker Jones ES	2nd floor inside Classroom 206	4/23/15	< 1		
WJ-0423-14A	Walker Jones ES	2nd floor hallway adjacent to Girl's RR (high)	4/23/15	< 1		
WJ-0423-14B	Walker Jones ES	2nd floor hallway adjacent to Girl's RR (high)	4/23/15	< 1		
WJ-0423-15A	Walker Jones ES	2nd floor hallway adjacent to Girl's RR (low)	4/23/15	< 1		
WJ-0423-15B	Walker Jones ES	2nd floor hallway adjacent to Girl's RR (low)	4/23/15	< 1		
WJ-0423-16A	Walker Jones ES	2nd floor inside Classroom 217	4/23/15	< 1		
WJ-0423-16B	Walker Jones ES	2nd floor inside Classroom 217	4/23/15	< 1		
WJ-0423-17A	Walker Jones ES	2nd floor inside Classroom 222	4/23/15	2.1		
WJ-0423-17B	Walker Jones ES	2nd floor inside Classroom 222	4/23/15	< 1		
WJ-0423-18A	Walker Jones ES	2nd floor inside Classroom 224	4/23/15	< 1		
WJ-0423-18B	Walker Jones ES	2nd floor inside Classroom 224	4/23/15	< 1		
WJ-0423-19A	Walker Jones ES	2nd floor inside Classroom 219	4/23/15	< 1		
WJ-0423-19B	Walker Jones ES	2nd floor inside Classroom 219	4/23/15	< 1		
WJ-0423-20A	Walker Jones ES	2nd floor inside Classroom 221	4/23/15	< 1		
WJ-0423-20B	Walker Jones ES	2nd floor inside Classroom 221	4/23/15	< 1		
WJ-0423-21A	Walker Jones ES	2nd floor inside Classroom 226	4/23/15	< 1		
WJ-0423-21B	Walker Jones ES	2nd floor inside Classroom 226	4/23/15	< 1		
WJ-0423-22A	Walker Jones ES	1st floor inside Classroom 103	4/23/15	< 1		
WJ-0423-22B	Walker Jones ES	1st floor inside Classroom 103	4/23/15	< 1		
WJ-0423-23A	Walker Jones ES	1st floor inside Classroom 104	4/23/15	< 1		
WJ-0423-23B	Walker Jones ES	1st floor inside Classroom 104	4/23/15	< 1		
WJ-0423-24A	Walker Jones ES	1st floor inside Classroom 105	4/23/15	< 1		
WJ-0423-24B	Walker Jones ES	1st floor inside Classroom 105	4/23/15	< 1		
WJ-0423-25A	Walker Jones ES	1st floor inside Classroom 106	4/23/15	< 1		
WJ-0423-25B	Walker Jones ES	1st floor inside Classroom 106	4/23/15	< 1		
WJ-0423-26A	Walker Jones ES	1st floor inside Classroom 108	4/23/15	1.7		
WJ-0423-26B	Walker Jones ES	1st floor inside Classroom 108	4/23/15	< 1		
WJ-0423-27A	Walker Jones ES	1st floor hallway adjacent to Girl's RR 111 (high)	4/23/15	< 1		
WJ-0423-27B	Walker Jones ES	1st floor hallway adjacent to Girl's RR 111 (high)	4/23/15	< 1		
WJ-0423-28A	Walker Jones ES	1st floor hallway adjacent to Girl's RR 111 (low)	4/23/15	< 1		
WJ-0423-28B	Walker Jones ES	1st floor hallway adjacent to Girl's RR 111 (low)	4/23/15	< 1		
WJ-0423-29A	Walker Jones ES	1st floor inside Classroom 115	4/23/15	< 1		
WJ-0423-29B	Walker Jones ES	1st floor inside Classroom 115	4/23/15	< 1		
WJ-0423-30A	Walker Jones ES	1st floor inside Classroom 120	4/23/15	< 1		
WJ-0423-30B	Walker Jones ES	1st floor inside Classroom 120	4/23/15	< 1		
WJ-0423-31A	Walker Jones ES	1st floor inside Classroom 122	4/23/15	< 1		
WJ-0423-31B	Walker Jones ES	1st floor inside Classroom 122	4/23/15	< 1		
WJ-0423-32A	Walker Jones ES	1st floor inside Classroom 117	4/23/15	< 1		
WJ-0423-32B	Walker Jones ES	1st floor inside Classroom 117	4/23/15	< 1		
WJ-0423-33A	Walker Jones ES	1st floor inside Health Suite 123	4/23/15	< 1		
WJ-0423-33B	Walker Jones ES	1st floor inside Health Suite 123	4/23/15	< 1		
WJ-0423-34A	Walker Jones ES	1st floor inside Classroom 126	4/23/15	< 1		
WJ-0423-34B	Walker Jones ES	1st floor inside Classroom 126	4/23/15	< 1		
WJ-0423-35A	Walker Jones ES	1st floor inside Classroom 128	4/23/15	< 1		
WJ-0423-35B	Walker Jones ES	1st floor inside Classroom 128	4/23/15	< 1		
WJ-0423-36A	Walker Jones ES	Lower Level hallway across from Classroom 032 (high)	4/23/15	< 1		

WJ-0423-36B	Walker Jones ES	Lower Level hallway across from Classroom 032 (high)	4/23/15	< 1		
WJ-0423-37A	Walker Jones ES	Lower Level hallway across from Classroom 032 (high)	4/23/15	< 1		
WJ-0423-37B	Walker Jones ES	Lower Level hallway across from Classroom 032 (high)	4/23/15	< 1		
WJ-0423-38A	Walker Jones ES	Lower Level inside Classroom 034	4/23/15	< 1		
WJ-0423-38B	Walker Jones ES	Lower Level inside Classroom 034	4/23/15	< 1		
<b>Percentage of Passed Samples</b>						<b>96.05%</b>
<b>Percentage of Failed Samples</b>						<b>3.95%</b>
WHS-1203-1A	Washington Metro HS@KC Lewis	3rd floor hallway between men's and women's rooms	12/3/14	< 1		
WHS-1203-2B	Washington Metro HS@KC Lewis	3rd floor hallway between men's and women's rooms	12/3/14	< 1		
WHS-1203-3A	Washington Metro HS@KC Lewis	3rd floor hallway adjacent to classroom 312	12/3/14	< 1		
WHS-1203-4B	Washington Metro HS@KC Lewis	3rd floor hallway adjacent to classroom 312	12/3/14	< 1		
WHS-1203-5A	Washington Metro HS@KC Lewis	2nd floor hallway adjacent to classroom 210	12/3/14	< 1		
WHS-1203-6B	Washington Metro HS@KC Lewis	2nd floor hallway adjacent to classroom 210	12/3/14	< 1		
WHS-1203-7A	Washington Metro HS@KC Lewis	2nd floor hallway adjacent to men's room	12/3/14	< 1		
WHS-1203-8B	Washington Metro HS@KC Lewis	2nd floor hallway adjacent to men's room	12/3/14	< 1		
WHS-1203-9A	Washington Metro HS@KC Lewis	1st floor hallway adjacent to classroom 106	12/3/14	< 1		
WHS-1203-10B	Washington Metro HS@KC Lewis	1st floor hallway adjacent to classroom 106	12/3/14	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
WES-0819-1B	Watkins ES	Fourth Floor Halway Adjacent to Room 407	8/19/15	< 1		
WES-0819-1A	Watkins ES	Fourth Floor Halway Adjacent to Room 407	8/19/15	< 1		
WES-0819-2A	Watkins ES	Fourth Floor Halway Adjacent to custodian's room	8/19/15	< 1		
WES-0819-2B	Watkins ES	Fourth Floor Halway Adjacent to custodian's room	8/19/15	< 1		
WES-0819-3A	Watkins ES	Fourth Floor Halway close to Room 400	8/19/15	< 1		
WES-0819-3B	Watkins ES	Fourth Floor Halway close to Room 400	8/19/15	< 1		
WES-0819-4A	Watkins ES	Third floor hallway adjacent to room 307	8/19/15	< 1		
WES-0819-4B	Watkins ES	Third floor hallway adjacent to room 307	8/19/15	< 1		
WES-0819-5A	Watkins ES	Third floor hallway adjacent to custodian's closet	8/19/15	< 1		
WES-0819-5B	Watkins ES	Third floor hallway adjacent to custodian's closet	8/19/15	< 1		
WES-0819-6A	Watkins ES	Third floor hallway across from the elevator	8/19/15	< 1		
WES-0819-6B	Watkins ES	Third floor hallway across from the elevator	8/19/15	< 1		
WES-0819-7A	Watkins ES	Second floor hallway adjacent to 207	8/19/15	< 1		
WES-0819-7B	Watkins ES	Second floor hallway adjacent to 207	8/19/15	< 1		
WES-0819-8A	Watkins ES	Second floor hallway adjacent to custodian's closet	8/19/15	< 1		
WES-0819-8B	Watkins ES	Second floor hallway adjacent to custodian's closet	8/19/15	< 1		
WES-0819-9A	Watkins ES	Second floor hallway across from elevator	8/19/15	< 1		
WES-0819-9B	Watkins ES	Second floor hallway across from elevator	8/19/15	< 1		
WES-0819-10A	Watkins ES	First floor hallway across from room 111	8/19/15	< 1		
WES-0819-10B	Watkins ES	First floor hallway across from room 111	8/19/15	< 1		
WES-0819-11A	Watkins ES	First floor hallway across from room 108	8/19/15	< 1		
WES-0819-11B	Watkins ES	First floor hallway across from room 108	8/19/15	< 1		
WES-0819-12A	Watkins ES	First floor hallway across elevator	8/19/15	< 1		
WES-0819-12B	Watkins ES	First floor hallway across elevator	8/19/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>

WES-0518-1A	West ES	3rd Floor inside Library	5/18/15	< 1		
WES-0518-1B	West ES	3rd Floor inside Library	5/18/15	< 1		
WES-0518-2A	West ES	2nd Floor inside teacher's lounge	5/18/15	< 1		
WES-0518-2B	West ES	2nd Floor inside teacher's lounge	5/18/15	< 1		
WES-0518-3A	West ES	2nd Floor hallway across teacher's lounge	5/18/15	< 1		
WES-0518-3B	West ES	2nd Floor hallway across teacher's lounge	5/18/15	< 1		
WES-0518-4A	West ES	2nd Floor inside cafeteria adjacent to Kitchen	5/18/15	< 1		
WES-0518-4B	West ES	2nd Floor inside cafeteria adjacent to Kitchen	5/18/15	< 1		
WES-0518-5A	West ES	2nd Floor inside learning center across book storage (left)	5/18/15	< 1		
WES-0518-5B	West ES	2nd Floor inside learning center across book storage (left)	5/18/15	< 1		
WES-0518-6A	West ES	2nd Floor inside learning center across book storage (right)	5/18/15	< 1		
WES-0518-6B	West ES	2nd Floor inside learning center across book storage (right)	5/18/15	< 1		
WES-0518-7A	West ES	2nd Floor inside learning center adjacent to custodian closet (left)	5/18/15	< 1		
WES-0518-7B	West ES	2nd Floor inside learning center adjacent to custodian closet (left)	5/18/15	< 1		
WES-0518-8A	West ES	2nd Floor inside learning center adjacent to custodian closet (right)	5/18/15	< 1		
WES-0518-8B	West ES	2nd Floor inside learning center adjacent to custodian closet (right)	5/18/15	< 1		
WES-0518-9A	West ES	1st Floor entrance lobby	5/18/15	< 1		
WES-0518-9B	West ES	1st Floor entrance lobby	5/18/15	< 1		
WES-0518-10A	West ES	1st Floor inside class room Pre-K 4 Ms. Phillips adjacent to rest room	5/18/15	< 1		
WES-0518-10B	West ES	1st Floor inside class room Pre-K 4 Ms. Phillips adjacent to rest room	5/18/15	< 1		
WES-0518-11A	West ES	1st Floor inside class room Ms. Ballou's adjacent to rest room	5/18/15	< 1		
WES-0518-11B	West ES	1st Floor inside class room Ms. Ballou's adjacent to rest room	5/18/15	< 1		
WES-0518-12A	West ES	1st Floor hallway adjacent to general office	5/18/15	< 1		
WES-0518-12B	West ES	1st Floor hallway adjacent to general office	5/18/15	< 1		
WES-0518-13A	West ES	1st Floor hallway adjacent to women's rest room	5/18/15	< 1		
WES-0518-13B	West ES	1st Floor hallway adjacent to women's rest room	5/18/15	< 1		
WES-0518-14A	West ES	1st Floor inside classroom Pre-k 3	5/18/15	< 1		
WES-0518-14B	West ES	1st Floor inside classroom Pre-k 3	5/18/15	< 1		
WES-0518-15A	West ES	1st Floor inside health suite	5/18/15	< 1		
WES-0518-15B	West ES	1st Floor inside health suite	5/18/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
WEC-0514-1A	Wheatley EC	2nd floor hallway adjacent to Classroom 203 (high)	5/14/15	< 1		
WEC-0514-1B	Wheatley EC	2nd floor hallway adjacent to Classroom 203 (high)	5/14/15	< 1		
WEC-0514-2A	Wheatley EC	2nd floor hallway adjacent to Classroom 203 (low)	5/14/15	< 1		
WEC-0514-2B	Wheatley EC	2nd floor hallway adjacent to Classroom 203 (low)	5/14/15	< 1		
WEC-0514-3A	Wheatley EC	2nd floor inside Classroom 203	5/14/15	< 1		
WEC-0514-3B	Wheatley EC	2nd floor inside Classroom 203	5/14/15	< 1		
WEC-0514-4A	Wheatley EC	2nd floor inside Classroom 207	5/14/15	< 1		
WEC-0514-4B	Wheatley EC	2nd floor inside Classroom 207	5/14/15	< 1		
WEC-0514-5A	Wheatley EC	2nd floor inside Classroom 234	5/14/15	< 1		
WEC-0514-5B	Wheatley EC	2nd floor inside Classroom 234	5/14/15	< 1		
WEC-0514-6A	Wheatley EC	2nd floor hallway across from Student Service 232 (high)	5/14/15	< 1		
WEC-0514-6B	Wheatley EC	2nd floor hallway across from Student Service 232 (high)	5/14/15	< 1		
WEC-0514-7A	Wheatley EC	2nd floor hallway across from Student Service 232 (low)	5/14/15	< 1		
WEC-0514-7B	Wheatley EC	2nd floor hallway across from Student Service 232 (low)	5/14/15	< 1		
WEC-0514-8A	Wheatley EC	2nd floor inside Classroom 222	5/14/15	< 1		
WEC-0514-8B	Wheatley EC	2nd floor inside Classroom 222	5/14/15	< 1		
WEC-0514-9A	Wheatley EC	2nd floor inside Classroom 224	5/14/15	< 1		
WEC-0514-9B	Wheatley EC	2nd floor inside Classroom 224	5/14/15	< 1		
WEC-0514-10A	Wheatley EC	2nd floor inside Classroom 227	5/14/15	< 1		
WEC-0514-10B	Wheatley EC	2nd floor inside Classroom 227	5/14/15	< 1		
WEC-0514-11A	Wheatley EC	2nd floor inside Counselor Room 225	5/14/15	< 1		
WEC-0514-11B	Wheatley EC	2nd floor inside Counselor Room 225	5/14/15	2.1		
WEC-0514-12A	Wheatley EC	2nd floor inside Classroom 229	5/14/15	< 1		

WEC-0514-12B	Wheatley EC	2nd floor inside Classroom 229	5/14/15	< 1		
WEC-0514-13A	Wheatley EC	1st floor hallway adjacent to Classroom 103 (high)	5/14/15	< 1		
WEC-0514-13B	Wheatley EC	1st floor hallway adjacent to Classroom 103 (high)	5/14/15	< 1		
WEC-0514-14A	Wheatley EC	1st floor hallway adjacent to Classroom 103 (low)	5/14/15	< 1		
WEC-0514-14B	Wheatley EC	1st floor hallway adjacent to Classroom 103 (low)	5/14/15	< 1		
WEC-0514-15A	Wheatley EC	1st floor inside Classroom 103	5/14/15	< 1		
WEC-0514-15B	Wheatley EC	1st floor inside Classroom 103	5/14/15	< 1		
WEC-0514-16A	Wheatley EC	1st floor inside Classroom 111	5/14/15	< 1		
WEC-0514-16B	Wheatley EC	1st floor inside Classroom 111	5/14/15	< 1		
WEC-0514-17A	Wheatley EC	1st floor inside Classroom 113	5/14/15	< 1		
WEC-0514-17B	Wheatley EC	1st floor inside Classroom 113	5/14/15	< 1		
WEC-0514-18A	Wheatley EC	1st floor inside Classroom 107	5/14/15	< 1		
WEC-0514-18B	Wheatley EC	1st floor inside Classroom 103	5/14/15	< 1		
WEC-0514-19A	Wheatley EC	1st floor inside Resource Classroom 136	5/14/15	< 1		
WEC-0514-19B	Wheatley EC	1st floor inside Resource Classroom 136	5/14/15	< 1		
WEC-0514-20A	Wheatley EC	1st floor inside Classroom 135	5/14/15	< 1		
WEC-0514-20B	Wheatley EC	1st floor inside Classroom 135	5/14/15	< 1		
WEC-0514-21A	Wheatley EC	1st floor hallway across from Storage Room 133 (high)	5/14/15	< 1		
WEC-0514-21B	Wheatley EC	1st floor hallway across from Storage Room 133 (high)	5/14/15	< 1		
WEC-0514-22A	Wheatley EC	1st floor hallway across from Storage Room 133 (low)	5/14/15	< 1		
WEC-0514-22B	Wheatley EC	1st floor hallway across from Storage Room 133 (low)	5/14/15	< 1		
WEC-0514-23A	Wheatley EC	1st floor inside Classroom 123	5/14/15	< 1		
WEC-0514-23B	Wheatley EC	1st floor inside Classroom 123	5/14/15	< 1		
WEC-0514-24A	Wheatley EC	1st floor inside Classroom 125	5/14/15	< 1		
WEC-0514-24B	Wheatley EC	1st floor inside Classroom 125	5/14/15	< 1		
WEC-0514-25A	Wheatley EC	1st floor inside Classroom 128	5/14/15	< 1		
WEC-0514-25B	Wheatley EC	1st floor inside Classroom 128	5/14/15	< 1		
WEC-0514-26A	Wheatley EC	1st floor inside Classroom 131	5/14/15	< 1		
WEC-0514-26B	Wheatley EC	1st floor inside Classroom 131	5/14/15	< 1		
WEC-0514-27A	Wheatley EC	Ground floor inside Classroom G31	5/14/15	< 1		
WEC-0514-27B	Wheatley EC	Ground floor inside Classroom G31	5/14/15	< 1		
WEC-0514-28A	Wheatley EC	Ground floor inside Classroom G05	5/14/15	2.7		
WEC-0514-28B	Wheatley EC	Ground floor inside Classroom G05	5/14/15	1.8		
WEC-0514-29A	Wheatley EC	Ground floor hallway adjacent to Conference Room (high)	5/14/15	< 1		
WEC-0514-29B	Wheatley EC	Ground floor hallway adjacent to Conference Room (high)	5/14/15	< 1		
WEC-0514-30A	Wheatley EC	Ground floor hallway adjacent to Conference Room (low)	5/14/15	< 1		
WEC-0514-30B	Wheatley EC	Ground floor hallway adjacent to Conference Room (low)	5/14/15	< 1		
WEC-0514-31A	Wheatley EC	Ground floor inside Classroom G51	5/14/15	< 1		
WEC-0514-31B	Wheatley EC	Ground floor inside Classroom G51	5/14/15	< 1		
WEC-0514-32A	Wheatley EC	Ground floor inside Classroom G54	5/14/15	< 1		
WEC-0514-32B	Wheatley EC	Ground floor inside Classroom G54	5/14/15	< 1		
WEC-0514-33A	Wheatley EC	Ground floor inside Classroom G57	5/14/15	< 1		
WEC-0514-33B	Wheatley EC	Ground floor inside Classroom G57	5/14/15	< 1		
WEC-0514-34A	Wheatley EC	Ground floor inside Classroom G59	5/14/15	< 1		
WEC-0514-34B	Wheatley EC	Ground floor inside Classroom G59	5/14/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
WES-0825-1A	Whittier ES	3rd Floor hallway Adjacent to 310	8/25/15	5.2		
WES-0825-1B	Whittier ES	3rd Floor hallway adjacent to 310	8/25/15	6.1		
WES-0825-2A	Whittier ES	2nd Floor hallway adjacent to Health Suite	8/25/15	< 1		
WES-0825-2B	Whittier ES	2nd Floor hallway adjacent to Health Suite	8/25/15	< 1		
WES-0825-3A	Whittier ES	2nd Floor hallway adjacent to 230	8/25/15	< 1		
WES-0825-3B	Whittier ES	2nd Floor hallway adjacent to 230	8/25/15	< 1		
WES-0825-4A	Whittier ES	1st Floor hallway adjacent to 138	8/25/15	< 1		

WES-0825-4B	Whittier ES	1st Floor hallway adjacent to 138	8/25/15	< 1		
WES-0825-5A	Whittier ES	1st Floor hallway across from Multipurpose Room	8/25/15	< 1		
WES-0825-5B	Whittier ES	1st Floor hallway across from Multipurpose Room	8/25/15	< 1		
WES-0825-6A	Whittier ES	2nd Floor hallway across 201	8/25/15	1.9		
WES-0825-6B	Whittier ES	2nd Floor hallway across 201	8/25/15	2.6		
WES-0825-7A	Whittier ES	3rd Floor hallway adj to 308	8/25/15	3.4		
WES-0825-7B	Whittier ES	3rd Floor hallway adj to 308	8/25/15	7.5		
WES-0825-8A	Whittier ES	3rd Floor hallway across 101	8/25/15	2.7		
WES-0825-8B	Whittier ES	3rd Floor hallway across 101	8/25/15	2.5		
WES-0825-9A	Whittier ES	Basement Floor across 002	8/25/15	< 1		
WES-0825-9B	Whittier ES	Basement Floor across 002	8/25/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
WHS-0723-1A	Wilson HS	First floor hallway adjacent to room 119	7/23/15	< 1		
WHS-0723-1B	Wilson HS	First floor hallway adjacent to room 119	7/23/15	< 1		
WHS-0723-2A	Wilson HS	First floor hallway adjacent to room 108A	7/23/15	< 1		
WHS-0723-2B	Wilson HS	First floor hallway adjacent to room 108A	7/23/15	< 1		
WHS-0723-3A	Wilson HS	First floor hallway adjacent to room B102	7/23/15	< 1		
WHS-0723-3B	Wilson HS	First floor hallway adjacent to room B102	7/23/15	< 1		
WHS-0723-4A	Wilson HS	First floor hallway adjacent to room B109	7/23/15	< 1		
WHS-0723-4B	Wilson HS	First floor hallway adjacent to room B109	7/23/15	< 1		
WHS-0723-5A	Wilson HS	Fourth floor hallway adjacent to room 421	7/23/15	< 1		
WHS-0723-5B	Wilson HS	Fourth floor hallway adjacent to room 421	7/23/15	< 1		
WHS-0723-6A	Wilson HS	Fourth floor hallway across room 420	7/23/15	< 1		
WHS-0723-6B	Wilson HS	Fourth floor hallway across room 420	7/23/15	< 1		
WHS-0723-7A	Wilson HS	Fourth floor hallway across room 412	7/23/15	< 1		
WHS-0723-7B	Wilson HS	Fourth floor hallway across room 412	7/23/15	< 1		
WHS-0723-8A	Wilson HS	Fourth floor hallway adjacent to room 412	7/23/15	< 1		
WHS-0723-8B	Wilson HS	Fourth floor hallway adjacent to room 412	7/23/15	< 1		
WHS-0723-9A	Wilson HS	Fourth floor hallway adjacent to room 402	7/23/15	< 1		
WHS-0723-9B	Wilson HS	Fourth floor hallway adjacent to room 402	7/23/15	< 1		
WHS-0723-10A	Wilson HS	Fourth floor hallway adjacent to room 431	7/23/15	< 1		
WHS-0723-10B	Wilson HS	Fourth floor hallway adjacent to room 431	7/23/15	< 1		
WHS-0723-11A	Wilson HS	Third floor hallway adjacent to room 321	7/23/15	< 1		
WHS-0723-11B	Wilson HS	Third floor hallway adjacent to room 321	7/23/15	< 1		
WHS-0723-12A	Wilson HS	Third floor hallway across room 320	7/23/15	< 1		
WHS-0723-12B	Wilson HS	Third floor hallway across room 320	7/23/15	< 1		
WHS-0723-13A	Wilson HS	Third floor hallway adjacent to room 314	7/23/15	< 1		
WHS-0723-13B	Wilson HS	Third floor hallway adjacent to room 314	7/23/15	< 1		
WHS-0723-14A	Wilson HS	Third floor hallway adjacent to room 312	7/23/15	< 1		
WHS-0723-14B	Wilson HS	Third floor hallway adjacent to room 312	7/23/15	< 1		
WHS-0723-15A	Wilson HS	Third floor hallway adjacent to room 331	7/23/15	< 1		
WHS-0723-15B	Wilson HS	Third floor hallway adjacent to room 331	7/23/15	< 1		
WHS-0723-16A	Wilson HS	Third floor hallway across room 302	7/23/15	< 1		
WHS-0723-16B	Wilson HS	Third floor hallway across room 302	7/23/15	< 1		
WHS-0723-17A	Wilson HS	Second floor hallway adjacent to room 223	7/23/15	< 1		
WHS-0723-17B	Wilson HS	Second floor hallway adjacent to room 223	7/23/15	< 1		
WHS-0723-18A	Wilson HS	Second floor hallway adjacent to room 222	7/23/15	< 1		
WHS-0723-18B	Wilson HS	Second floor hallway adjacent to room 222	7/23/15	< 1		
WHS-0723-19A	Wilson HS	Second floor hallway adjacent to room 213	7/23/15	< 1		
WHS-0723-19B	Wilson HS	Second floor hallway adjacent to room 213	7/23/15	< 1		
WHS-0723-20A	Wilson HS	Second floor hallway adjacent to room 211	7/23/15	< 1		
WHS-0723-20B	Wilson HS	Second floor hallway adjacent to room 211	7/23/15	< 1		

WHS-0723-21A	Wilson HS	Second floor hallway adjacent to room 202	7/23/15	< 1		
WHS-0723-21B	Wilson HS	Second floor hallway adjacent to room 202	7/23/15	< 1		
WHS-0723-22A	Wilson HS	Second floor hallway adjacent to room 232	7/23/15	< 1		
WHS-0723-22B	Wilson HS	Second floor hallway adjacent to room 232	7/23/15	< 1		
WHS-0723-23A	Wilson HS	Second floor hallway adjacent to room B202	7/23/15	< 1		
WHS-0723-23B	Wilson HS	Second floor hallway adjacent to room B202	7/23/15	< 1		
WHS-0723-24A	Wilson HS	Second floor hallway adjacent to room B209	7/23/15	< 1		
WHS-0723-24B	Wilson HS	Second floor hallway adjacent to room B209	7/23/15	< 1		
WHS-0723-25A	Wilson HS	Second floor hallway adjacent to room C207 (high)	7/23/15	< 1		
WHS-0723-25B	Wilson HS	Second floor hallway adjacent to room C207 (high)	7/23/15	< 1		
WHS-0723-26A	Wilson HS	Second floor hallway adjacent to room C207 (low)	7/23/15	< 1		
WHS-0723-26B	Wilson HS	Second floor hallway adjacent to room C207 (low)	7/23/15	< 1		
WHS-0723-27A	Wilson HS	Second floor hallway adjacent to room C204 (high)	7/23/15	< 1		
WHS-0723-27B	Wilson HS	Second floor hallway adjacent to room C204 (high)	7/23/15	< 1		
WHS-0723-28A	Wilson HS	Second floor hallway adjacent to room C204 (low)	7/23/15	< 1		
WHS-0723-28B	Wilson HS	Second floor hallway adjacent to room C204 (low)	7/23/15	< 1		
WHS-0723-29A	Wilson HS	Third floor hallway adjacent to room B301	7/23/15	< 1		
WHS-0723-29B	Wilson HS	Third floor hallway adjacent to room B301	7/23/15	< 1		
WHS-0723-30A	Wilson HS	Third floor hallway adjacent to room B308	7/23/15	< 1		
WHS-0723-30B	Wilson HS	Third floor hallway adjacent to room B308	7/23/15	< 1		
WHS-0723-31A	Wilson HS	Second floor hallway adjacent to room A203b	7/23/15	< 1		
WHS-0723-31B	Wilson HS	Second floor hallway adjacent to room A203b	7/23/15	< 1		
WHS-0723-32A	Wilson HS	Second floor inside auxiliary gymnasium (high)	7/23/15	< 1		
WHS-0723-32B	Wilson HS	Second floor inside auxiliary gymnasium (high)	7/23/15	< 1		
WHS-0723-33A	Wilson HS	Second floor inside auxiliary gymnasium (low)	7/23/15	< 1		
WHS-0723-33B	Wilson HS	Second floor inside auxiliary gymnasium (low)	7/23/15	< 1		
WHS-0723-34A	Wilson HS	First floor inside boys' locker room (high)	7/23/15	< 1		
WHS-0723-34B	Wilson HS	First floor inside boys' locker room (high)	7/23/15	< 1		
WHS-0723-35A	Wilson HS	First floor inside boys' locker room (low)	7/23/15	< 1		
WHS-0723-35B	Wilson HS	First floor inside boys' locker room (low)	7/23/15	< 1		
WHS-0723-36A	Wilson HS	Second floor inside fitness center (high)	7/23/15	< 1		
WHS-0723-36B	Wilson HS	Second floor inside fitness center (high)	7/23/15	< 1		
WHS-0723-37A	Wilson HS	Second floor inside fitness center (low)	7/23/15	< 1		
WHS-0723-37B	Wilson HS	Second floor inside fitness center (low)	7/23/15	< 1		
WHS-0723-38A	Wilson HS	First floor inside girls' locker room (high)	7/23/15	< 1		
WHS-0723-38B	Wilson HS	First floor inside girls' locker room (high)	7/23/15	< 1		
WHS-0723-39A	Wilson HS	First floor inside girls' locker room (low)	7/23/15	< 1		
WHS-0723-39B	Wilson HS	First floor inside girls' locker room (low)	7/23/15	< 1		
<b>Percentage of Passed Samples</b>						<b>100.00%</b>
<b>Percentage of Failed Samples</b>						<b>0.00%</b>
HDW-0324-1A	Woodson SHS ( H.D. )	3rd floor hallway adjacent to Lab 342	3/24/15	< 1		
HDW-0324-1B	Woodson SHS ( H.D. )	3rd floor hallway adjacent to Lab 342	3/24/15	< 1		
HDW-0324-2A	Woodson SHS ( H.D. )	3rd floor hallway adjacent to Lab 333	3/24/15	< 1		
HDW-0324-2B	Woodson SHS ( H.D. )	3rd floor hallway adjacent to Lab 333	3/24/15	< 1		
HDW-0324-3A	Woodson SHS ( H.D. )	1st floor hallway adjacent to Main Office (high)	3/24/15	< 1		
HDW-0324-3B	Woodson SHS ( H.D. )	1st floor hallway adjacent to Main Office (high)	3/24/15	< 1		
HDW-0324-4A	Woodson SHS ( H.D. )	1st floor hallway adjacent to Main Office (low)	3/24/15	< 1		
HDW-0324-4B	Woodson SHS ( H.D. )	1st floor hallway adjacent to Main Office (low)	3/24/15	< 1		
HDW-0324-5A	Woodson SHS ( H.D. )	1st floor inside Cafeteria (high)	3/24/15	< 1		
HDW-0324-5B	Woodson SHS ( H.D. )	1st floor inside Cafeteria (high)	3/24/15	< 1		
HDW-0324-6A	Woodson SHS ( H.D. )	1st floor inside Cafeteria (low)	3/24/15	< 1		
HDW-0324-6B	Woodson SHS ( H.D. )	1st floor inside Cafeteria (low)	3/24/15	< 1		
HDW-0324-7A	Woodson SHS ( H.D. )	1st floor hallway adjacent to Ticket Room 153 (high)	3/24/15	< 1		
HDW-0324-7B	Woodson SHS ( H.D. )	1st floor hallway adjacent to Ticket Room 153 (high)	3/24/15	< 1		
HDW-0324-8A	Woodson SHS ( H.D. )	1st floor hallway adjacent to Ticket Room 153 (low)	3/24/15	< 1		

HDW-0324-8B	Woodson SHS ( H.D. )	1st floor hallway adjacent to Ticket Room 153 (low)	3/24/15	< 1		
HDW-0324-9A	Woodson SHS ( H.D. )	Lower level inside Pool Room (high)	3/24/15	< 1		
HDW-0324-9B	Woodson SHS ( H.D. )	Lower level inside Pool Room (high)	3/24/15	< 1		
HDW-0324-10A	Woodson SHS ( H.D. )	Lower level inside Pool Room (low)	3/24/15	< 1		
HDW-0324-10B	Woodson SHS ( H.D. )	Lower level inside Pool Room (low)	3/24/15	< 1		
HDW-0324-11A	Woodson SHS ( H.D. )	Lower level hallway near Stair 3 (high)	3/24/15	< 1		
HDW-0324-11B	Woodson SHS ( H.D. )	Lower level hallway near Stair 3 (high)	3/24/15	< 1		
HDW-0324-12A	Woodson SHS ( H.D. )	Lower level hallway near Stair 3 (low)	3/24/15	< 1		
HDW-0324-12B	Woodson SHS ( H.D. )	Lower level hallway near Stair 3 (low)	3/24/15	< 1		
HDW-0324-13A	Woodson SHS ( H.D. )	Lower level inside Big Gym (high)	3/24/15	< 1		
HDW-0324-13B	Woodson SHS ( H.D. )	Lower level inside Big Gym (high)	3/24/15	< 1		
HDW-0324-14A	Woodson SHS ( H.D. )	Lower level inside Big Gym (low)	3/24/15	< 1		
HDW-0324-14B	Woodson SHS ( H.D. )	Lower level inside Big Gym (low)	3/24/15	< 1		
HDW-0324-15A	Woodson SHS ( H.D. )	Lower level inside Small Gym (high)	3/24/15	< 1		
HDW-0324-15B	Woodson SHS ( H.D. )	Lower level inside Small Gym (high)	3/24/15	< 1		
HDW-0324-16A	Woodson SHS ( H.D. )	Lower level inside Small Gym (low)	3/24/15	< 1		
HDW-0324-16B	Woodson SHS ( H.D. )	Lower level inside Small Gym (low)	3/24/15	< 1		
HDW-0324-17A	Woodson SHS ( H.D. )	Lower level inside Weight Room (high)	3/24/15	< 1		
HDW-0324-17B	Woodson SHS ( H.D. )	Lower level inside Weight Room (high)	3/24/15	< 1		
HDW-0324-18A	Woodson SHS ( H.D. )	Lower level inside Weight Room (low)	3/24/15	< 1		
HDW-0324-18B	Woodson SHS ( H.D. )	Lower level inside Weight Room (low)	3/24/15	< 1		
HDW-0324-19A	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Electric Room 222 (high)	3/24/15	< 1		
HDW-0324-19B	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Electric Room 222 (high)	3/24/15	< 1		
HDW-0324-20A	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Electric Room 222 (low)	3/24/15	< 1		
HDW-0324-20B	Woodson SHS ( H.D. )	2nd floor hallway adjacent to Electric Room 222 (low)	3/24/15	< 1		
					<b>Percentage of Passed Samples</b>	<b>100.00%</b>
					<b>Percentage of Failed Samples</b>	<b>0.00%</b>
<b>Totals/Percentages of All Tested Schools</b>						
					<b>Total Number of Schools Tested</b>	<b>115</b>
					<b>Total Passed Samples</b>	<b>4155</b>
					<b>Total Failed Samples</b>	<b>28</b>
					<b>Total Samples Collected</b>	<b>4183</b>
					<b>Percentage of Passed Samples</b>	<b>99.33%</b>
					<b>Percentage of Failed Samples</b>	<b>0.67%</b>